


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: January 2023

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.16	N/A	N/A	N/A	0.16
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08
4	N/A	N/A	0.10	N/A	N/A	N/A	0.10
5	N/A	N/A	0.06	N/A	N/A	N/A	0.06
6	N/A	N/A	0.05	N/A	N/A	N/A	0.05
7	N/A	N/A	down	N/A	N/A	N/A	down
8	N/A	N/A	down	N/A	N/A	N/A	down
9	N/A	N/A	down	N/A	N/A	N/A	down
10	N/A	N/A	down	N/A	N/A	N/A	down
11	N/A	N/A	down	N/A	N/A	N/A	down
12	N/A	N/A	0.05	N/A	N/A	N/A	0.05
13	N/A	N/A	down	N/A	N/A	N/A	down
14	N/A	N/A	0.06	N/A	N/A	N/A	0.06
15	N/A	N/A	down	N/A	N/A	N/A	down
16	N/A	N/A	down	N/A	N/A	N/A	down
17	N/A	N/A	down	N/A	N/A	N/A	down
18	N/A	N/A	down	N/A	N/A	N/A	down
19	N/A	N/A	down	N/A	N/A	N/A	down
20	N/A	N/A	down	N/A	N/A	N/A	down
21	N/A	N/A	down	N/A	N/A	N/A	down
22	N/A	N/A	down	N/A	N/A	N/A	down
23	N/A	N/A	0.03	N/A	N/A	N/A	0.03
24	N/A	N/A	0.03	N/A	N/A	N/A	0.03
25	N/A	N/A	down	N/A	N/A	N/A	down
26	N/A	N/A	down	N/A	N/A	N/A	down
27	N/A	N/A	down	N/A	N/A	N/A	down
28	N/A	N/A	down	N/A	N/A	N/A	down
29	N/A	N/A	0.05	N/A	N/A	N/A	0.05
30	N/A	N/A	0.05	N/A	N/A	N/A	0.05
31	N/A	N/A	0.04	N/A	N/A	N/A	0.04

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES		C/T's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
All daily readings ≤ 5 NTU? YES			
Notes:		PRINTED NAME: Joe Rogers	
		SIGNATURE 	DATE 2/01/23
		PHONE #: (503) 723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: January 2023

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
01/01/23	6:00 AM	1.29	53	68	7.0	8.0	34	Yes	2870
01/02/23	6:00 AM	1.48	33	49	6.8	7.9	34	Yes	4455
01/03/23	6:00 AM	1.45	36	52	6.8	7.7	31	Yes	4251
01/04/23	6:00 AM	1.42	39	55	6.2	7.9	34	Yes	3956
01/05/23	6:00 AM	1.42	34	48	6.5	7.9	34	Yes	4513
01/06/23	6:00 AM	1.46	49	72	7.1	8.1	36	Yes	3006
01/07/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/08/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/09/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/10/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/11/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/12/23	6:00 AM	1.43	67	96	7.9	7.9	31	Yes	2255
01/13/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/14/23	6:00 AM	1.18	41	49	8.4	8.0	31	Yes	3764
01/15/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/16/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/17/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/18/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/19/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/20/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/21/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/22/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/23/23	6:00 AM	1.41	103	146	6.1	7.6	31	Yes	1463
01/24/23	6:00 AM	1.53	118	181	6.1	7.8	34	Yes	1298
01/25/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/26/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/27/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/28/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/29/23	6:00 AM	1.34	132	177	6.2	7.7	32	Yes	1171
01/30/23	6:00 AM	1.36	104	141	4.5	8.1	41	Yes	1478
01/31/23	6:00AM	1.51	44	66	4.1	7.7	37	Yes	3375

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day