


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: **NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: February 2023**

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.04	N/A	N/A	N/A	0.04
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.05	N/A	N/A	N/A	0.05
7	N/A	N/A	0.04	N/A	N/A	N/A	0.04
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
11	N/A	N/A	0.05	N/A	N/A	N/A	0.05
12	N/A	N/A	0.06	N/A	N/A	N/A	0.06
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
18	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
23	N/A	N/A	0.05	N/A	N/A	N/A	0.05
24	N/A	N/A	0.05	N/A	N/A	N/A	0.05
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
27	N/A	N/A	0.06	N/A	N/A	N/A	0.06
28	N/A	N/A	0.04	N/A	N/A	N/A	0.04

Slow Sand/Membrane/DE Filtration/ Unfiltered	<b>Monthly Summary</b>	
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>	CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>
All daily readings ≤ 5 NTU? <b>YES</b>	<b>PRINTED NAME: Joe Rogers</b>	
<b>Notes:</b>	<b>SIGNATURE</b> 	<b>DATE 3/01/23</b>
	<b>PHONE #: (503) 723-3505</b>	<b>CERT #: T-09162</b>

**OHA - Drinking Water Program - Surface Water Quality Data Form**

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: February 2023

**Membrane Filters**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
02/01/23	6:00 AM	1.52	118	179	5.2	7.8	35	Yes	1302
02/02/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/03/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/04/23	6:00 AM	1.57	43	67	6.2	7.8	34	Yes	3455
02/05/23	6:00 AM	1.54	42	65	5.6	7.6	32	Yes	3611
02/06/23	6:00 AM	1.44	43	62	5.5	7.9	36	Yes	3567
02/07/23	6:00 AM	1.46	73	107	5.9	8.2	40	Yes	2116
02/08/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/09/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/10/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/11/23	6:00 AM	1.46	95	138	7.1	7.9	33	Yes	1619
02/12/23	6:00 AM	1.46	112	164	7.1	8.0	34	Yes	1362
02/13/23	6:00 AM	1.44	91	131	6.7	8.2	38	Yes	1667
02/14/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/15/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/16/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/17/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/18/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/19/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/20/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/21/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/22/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/23/23	6:00 AM	1.36	108	147	4.5	7.7	35	Yes	1403
02/24/23	6:00 AM	1.34	83	112	6.8	8.1	36	Yes	1768
02/25/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/26/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/27/23	6:00 AM	1.47	119	175	5.8	7.5	30	Yes	1322
02/28/23	6:00 AM	1.64	117	193	5.8	7.5	31	Yes	1337

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day