


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: March 2023								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
2	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
6	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
7	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
8	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
13	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
14	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
15	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
16	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
17	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
18	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
21	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
22	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
23	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
24	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
25	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
26	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
27	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
28	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
30	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
31	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
Slow Sand/Membrane/DE Filtration/ Unfiltered				<b>Monthly Summary</b>				
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b> All daily readings ≤ 5 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 4/01/23	
				PHONE #: (503) -723-3505			CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: March 2023**

**Membrane Filters**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
03/01/23	6:00 AM	1.71	46	78	3.6	7.5	37	Yes	3318
03/02/23	6:00 AM	1.39	54	75	3.6	7.8	40	Yes	2929
03/03/23	6:00 AM	1.67	46	77	5.6	7.6	33	Yes	3333
03/04/23	6:00 AM	1.68	102	172	6.1	8.2	40	Yes	1496
03/05/23	6:00 AM	1.53	108	165	5.6	7.7	33	Yes	1424
03/06/23	6:00 AM	1.66	47	79	5.5	7.7	34	Yes	3238
03/07/23	6:00 AM	1.69	39	65	5.8	7.7	34	Yes	3970
03/08/23	6:00 AM	1.51	100	151	5.8	7.6	32	Yes	1494
03/09/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/10/23	6:00 AM	1.58	44	70	7.1	7.6	30	Yes	3420
03/11/23	6:00 AM	1.48	78	116	6.8	7.7	31	Yes	1937
03/12/23	6:00 AM	1.38	96	133	6.4	7.7	31	Yes	1571
03/13/23	6:00 AM	1.60	35	57	6.9	7.7	31	Yes	4380
03/14/23	6:00 AM	1.49	27	40	6.7	7.7	31	Yes	5770
03/15/23	6:00 AM	1.49	34	51	6.8	7.6	30	Yes	4461
03/16/23	6:00 AM	1.52	54	83	6.7	7.6	30	Yes	2741
03/17/23	6:00 AM	1.26	63	79	6.9	7.7	30	Yes	2369
03/18/23	6:00 AM	1.43	55	79	7.2	7.9	33	Yes	2782
03/19/23	6:00 AM	1.33	99	132	7.9	7.9	31	Yes	1527
03/20/23	6:00 AM	1.43	55	79	7.5	7.8	31	Yes	2727
03/21/23	6:00 AM	1.53	45	68	7.7	7.8	31	Yes	3436
03/22/23	6:00 AM	1.65	45	74	7.7	7.8	31	Yes	3380
03/23/23	6:00 AM	1.49	52	78	8.5	7.6	27	Yes	2886
03/24/23	6:00 AM	1.66	52	87	7.2	7.7	31	Yes	2859
03/25/23	6:00 AM	1.73	55	95	6.8	7.6	31	Yes	2748
03/26/23	6:00 AM	1.53	57	88	8.1	8.2	35	Yes	2638
03/27/23	6:00 AM	1.44	96	138	7.1	7.6	29	Yes	1581
03/28/23	6:00 AM	1.47	66	97	7.5	7.7	30	Yes	2300
03/29/23	6:00 AM	1.49	56	83	7.7	7.7	29	Yes	2719
03/30/23	6:00 AM	1.58	49	77	7.2	7.6	30	Yes	3096
03/31/23	6:00 AM	1.52	99	150	7.5	7.5	28	Yes	1528

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day