


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: April 2023

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.07	N/A	N/A	N/A	0.07
2	N/A	N/A	0.06	N/A	N/A	N/A	0.06
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08
4	N/A	N/A	0.06	N/A	N/A	N/A	0.06
5	N/A	N/A	0.09	N/A	N/A	N/A	0.09
6	N/A	N/A	0.08	N/A	N/A	N/A	0.08
7	N/A	N/A	0.09	N/A	N/A	N/A	0.09
8	N/A	N/A	0.07	N/A	N/A	N/A	0.07
9	N/A	N/A	0.06	N/A	N/A	N/A	0.06
10	N/A	N/A	0.07	N/A	N/A	N/A	0.07
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	0.07	N/A	N/A	N/A	0.07
15	N/A	N/A	0.07	N/A	N/A	N/A	0.07
16	N/A	N/A	0.07	N/A	N/A	N/A	0.07
17	N/A	N/A	0.06	N/A	N/A	N/A	0.06
18	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.07	N/A	N/A	N/A	0.07
23	N/A	N/A	0.08	N/A	N/A	N/A	0.08
24	N/A	N/A	0.07	N/A	N/A	N/A	0.07
25	N/A	N/A	0.09	N/A	N/A	N/A	0.09
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
28	N/A	N/A	0.08	N/A	N/A	N/A	0.08
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07
30	N/A	N/A	0.07	N/A	N/A	N/A	0.07

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
Notes:		PRINTED NAME: Joe Rogers	
		SIGNATURE 	DATE 5/01/23
		PHONE #: (503) 723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B2 Month/Year: April 2023

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
04/01/23	6:00 AM	1.46	52	75	7.4	7.6	29	Yes	2890
04/02/23	6:00 AM	1.49	41	61	7.0	7.6	29	Yes	3668
04/03/23	6:00 AM	1.44	40	58	7.0	7.5	28	Yes	3786
04/04/23	6:00 AM	1.45	106	154	7.2	8.1	35	Yes	1427
04/05/23	6:00 AM	1.52	53	80	7.2	7.7	31	Yes	2861
04/06/23	6:00 AM	1.46	39	57	7.2	8.2	37	Yes	3844
04/07/23	6:00 AM	1.44	94	135	8.4	7.6	27	Yes	1575
04/08/23	6:00 AM	1.47	55	80	9.0	7.6	26	Yes	2737
04/09/23	6:00 AM	1.43	52	74	8.2	7.6	27	Yes	2940
04/10/23	6:00 AM	1.40	34	47	8.7	7.7	27	Yes	4461
04/11/23	6:00 AM	1.35	46	63	8.4	7.7	28	Yes	3184
04/12/23	6:00 AM	1.45	37	53	8.2	7.7	28	Yes	4108
04/13/23	6:00 AM	1.47	45	66	8.4	7.7	28	Yes	3354
04/14/23	6:00 AM	1.33	51	68	8.0	8.0	32	Yes	2894
04/15/23	6:00 AM	1.45	49	71	8.1	7.7	29	Yes	3077
04/16/23	6:00 AM	1.58	102	161	8.4	7.8	30	Yes	1485
04/17/23	6:00 AM	1.50	102	152	9.0	8.1	32	Yes	1508
04/18/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/19/23	6:00 AM	1.43	91	130	8.4	7.8	29	Yes	1691
04/20/23	6:00 AM	1.45	54	78	8.2	7.8	30	Yes	2933
04/21/23	6:00 AM	1.44	47	68	8.5	8.1	33	Yes	3226
04/22/23	6:00 AM	1.38	53	73	9.0	7.8	28	Yes	2874
04/23/23	6:00 AM	1.48	47	69	9.3	7.6	26	Yes	3326
04/24/23	6:00 AM	1.42	53	75	9.1	7.8	28	Yes	2850
04/25/23	6:00 AM	1.53	99	151	9.6	7.8	27	Yes	1531
04/26/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/27/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/28/23	6:00 AM	1.46	45	66	10.4	7.9	27	Yes	3203
04/29/23	6:00 AM	1.46	46	67	11.7	7.9	24	Yes	3175
04/30/23	6:00 AM	1.42	54	77	10.5	7.8	25	Yes	2759