


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B2 Month/Year: May 2023								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
2	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
5	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
6	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
7	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
8	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
10	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
13	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
14	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
15	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
16	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
17	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
18	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
19	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
21	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
22	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
23	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
24	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
25	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
26	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
27	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
28	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
30	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
31	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
Slow Sand/Membrane/DE Filtration/ Unfiltered				<b>Monthly Summary</b>				
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>		
All daily readings ≤ 5 NTU? <b>YES</b>								
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 6/01/23	
				PHONE #: (503) 723-3505			CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B2 Month/Year: May 2023**

**Membrane Filters**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
05/01/23	6:00 AM	1.47	68	100	10.1	7.7	25	Yes	2227
05/02/23	6:00 AM	1.57	53	83	9.9	7.6	25	Yes	2791
05/03/23	6:00 AM	1.48	59	87	11.0	7.7	24	Yes	2648
05/04/23	6:00 AM	1.80	53	95	10.4	7.5	24	Yes	2757
05/05/23	6:00 AM	1.40	97	136	11.3	7.8	24	Yes	1578
05/06/23	6:00 AM	1.46	51	74	10.3	7.7	25	Yes	2861
05/07/23	6:00 AM	1.42	70	99	10.4	8.1	29	Yes	2186
05/08/23	6:00 AM	1.46	72	105	9.8	7.7	26	Yes	2133
05/09/23	6:00 AM	1.46	45	65	10.2	7.7	25	Yes	3354
05/10/23	6:00 AM	1.40	97	136	11.1	7.7	23	Yes	1573
05/11/23	6:00 AM	1.39	99	138	10.7	7.9	26	Yes	1541
05/12/23	6:00 AM	1.63	91	148	11.1	7.7	24	Yes	1605
05/13/23	6:00 AM	1.76	48	85	12.0	7.6	22	Yes	3028
05/14/23	6:00 AM	1.59	34	53	12.1	7.6	21	Yes	4440
05/15/23	6:00 AM	1.49	32	47	12.6	7.6	20	Yes	4625
05/16/23	6:00 AM	1.43	49	71	12.8	7.7	21	Yes	2940
05/17/23	6:00 AM	1.40	33	46	13.0	7.8	21	Yes	4492
05/18/23	6:00 AM	1.48	45	66	13.1	7.6	20	Yes	3352
05/19/23	6:00 AM	1.35	49	66	13.5	7.9	21	Yes	3041
05/20/23	6:00 AM	1.35	38	51	14.3	8.3	23	Yes	4041
05/21/23	6:00 AM	1.35	33	44	14.2	7.8	19	Yes	4546
05/22/23	6:00 AM	1.29	34	43	13.2	7.7	20	Yes	4399
05/23/23	6:00 AM	1.29	33	42	12.9	7.8	21	Yes	4475
05/24/23	6:00 AM	1.31	30	40	12.7	7.7	21	Yes	4921
05/25/23	6:00 AM	1.52	33	51	12.8	7.7	21	Yes	4551
05/26/23	6:00 AM	1.35	29	39	13.5	7.7	19	Yes	5049
05/27/23	6:00 AM	1.43	32	45	13.9	7.6	18	Yes	4840
05/28/23	6:00 AM	1.38	55	76	14.4	8.2	22	Yes	2676
05/29/23	6:00 AM	1.39	67	93	14.1	7.8	19	Yes	2269
05/30/23	6:00 AM	1.37	33	45	14.1	7.8	19	Yes	4696
05/31/23	6:00AM	1.34	23	30	13.9	7.8	20	Yes	6754

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day