


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: June 2023							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08
2	N/A	N/A	0.08	N/A	N/A	N/A	0.08
3	N/A	N/A	0.06	N/A	N/A	N/A	0.06
4	N/A	N/A	0.06	N/A	N/A	N/A	0.06
5	N/A	N/A	0.06	N/A	N/A	N/A	0.06
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06
7	N/A	N/A	0.07	N/A	N/A	N/A	0.07
8	N/A	N/A	0.07	N/A	N/A	N/A	0.07
9	N/A	N/A	0.08	N/A	N/A	N/A	0.08
10	N/A	N/A	0.07	N/A	N/A	N/A	0.07
11	N/A	N/A	0.06	N/A	N/A	N/A	0.06
12	N/A	N/A	0.07	N/A	N/A	N/A	0.07
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	0.07	N/A	N/A	N/A	0.07
15	N/A	N/A	0.07	N/A	N/A	N/A	0.07
16	N/A	N/A	0.09	N/A	N/A	N/A	0.09
17	N/A	N/A	0.07	N/A	N/A	N/A	0.07
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.07	N/A	N/A	N/A	0.07
23	N/A	N/A	0.05	N/A	N/A	N/A	0.05
24	N/A	N/A	0.04	N/A	N/A	N/A	0.04
25	N/A	N/A	0.04	N/A	N/A	N/A	0.04
26	N/A	N/A	0.04	N/A	N/A	N/A	0.04
27	N/A	N/A	0.06	N/A	N/A	N/A	0.06
28	N/A	N/A	0.09	N/A	N/A	N/A	0.09
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08
30	N/A	N/A	0.06	N/A	N/A	N/A	0.06
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back)		All CL2 residual at entry point \geq 0.2 mg/l?	
All daily readings \leq 5 NTU? YES				YES		YES	
Notes:				PRINTED NAME: Joe Rogers			
				SIGNATURE 		DATE 7/01/23	
				PHONE #: (503) -723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: June 2023

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
06/01/23	6:00 AM	1.41	104	146	14.4	8.1	21	Yes	1442
06/02/23	6:00 AM	1.45	34	49	15.1	8.2	21	Yes	4374
06/03/23	6:00 AM	1.70	45	77	15.5	7.9	18	Yes	3378
06/04/23	6:00 AM	1.46	33	48	15.2	7.7	17	Yes	4402
06/05/23	6:00 AM	1.46	32	47	15.1	7.8	18	Yes	4775
06/06/23	6:00 AM	1.48	30	45	15.8	7.7	17	Yes	5096
06/07/23	6:00 AM	1.52	24	37	16.9	7.6	15	Yes	6274
06/08/23	6:00 AM	1.37	24	33	17.0	7.7	15	Yes	6216
06/09/23	6:00 AM	1.38	29	41	16.8	7.8	16	Yes	5022
06/10/23	6:00 AM	1.41	25	35	16.1	8.2	19	Yes	6006
06/11/23	6:00 AM	1.38	52	71	18.2	8.2	17	Yes	2930
06/12/23	6:00 AM	1.39	30	42	17.3	7.8	16	Yes	4846
06/13/23	6:00 AM	1.41	31	43	17.9	7.7	15	Yes	4789
06/14/23	6:00 AM	1.36	5	7	17.5	8.2	18	No	4956
06/15/23	6:00 AM	1.35	29	39	16.3	7.7	16	Yes	5248
06/16/23	6:00 AM	1.31	37	48	17.8	7.8	15	Yes	4091
06/17/23	6:00 AM	1.45	24	35	18.4	7.8	15	Yes	6048
06/18/23	6:00 AM	1.41	91	129	17.1	8.0	17	Yes	1680
06/19/23	6:00 AM	1.32	33	44	16.7	7.6	15	Yes	4522
06/20/23	6:00 AM	1.34	103	139	16.4	7.6	15	Yes	1406
06/21/23	6:00 AM	1.38	36	49	16.4	7.6	15	Yes	4300
06/22/23	6:00 AM	1.34	51	68	16.3	7.7	16	Yes	3002
06/23/23	6:00 AM	1.42	24	34	18.5	7.7	14	Yes	6147
06/24/23	6:00 AM	1.41	33	47	18.5	8.0	16	Yes	4451
06/25/23	6:00 AM	1.44	31	44	18.2	7.9	15	Yes	4747
06/26/23	6:00 AM	1.47	30	44	18.8	7.7	14	Yes	5037
06/27/23	6:00 AM	1.38	30	42	19.4	7.5	12	Yes	5024
06/28/23	6:00 AM	1.41	30	42	19.2	7.6	13	Yes	4905
06/29/23	6:00 AM	1.37	35	48	19.9	7.7	13	Yes	4299
06/30/23	6:00 AM	1.44	28	40	20.4	7.8	13	Yes	5411

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day