


OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP: WTP-B2 Month/Year: July 2023							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.04	N/A	N/A	N/A	0.04
2	N/A	N/A	0.04	N/A	N/A	N/A	0.04
3	N/A	N/A	0.04	N/A	N/A	N/A	0.04
4	N/A	N/A	0.03	N/A	N/A	N/A	0.03
5	N/A	N/A	0.05	N/A	N/A	N/A	0.05
6	N/A	N/A	0.04	N/A	N/A	N/A	0.04
7	N/A	N/A	0.04	N/A	N/A	N/A	0.04
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07
10	N/A	N/A	0.05	N/A	N/A	N/A	0.05
11	N/A	N/A	0.08	N/A	N/A	N/A	0.08
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	0.06	N/A	N/A	N/A	0.06
15	N/A	N/A	0.03	N/A	N/A	N/A	0.03
16	N/A	N/A	0.03	N/A	N/A	N/A	0.03
17	N/A	N/A	0.03	N/A	N/A	N/A	0.03
18	N/A	N/A	0.07	N/A	N/A	N/A	0.07
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.07	N/A	N/A	N/A	0.07
22	N/A	N/A	0.03	N/A	N/A	N/A	0.03
23	N/A	N/A	0.03	N/A	N/A	N/A	0.03
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08
25	N/A	N/A	0.04	N/A	N/A	N/A	0.04
26	N/A	N/A	0.05	N/A	N/A	N/A	0.05
27	N/A	N/A	0.03	N/A	N/A	N/A	0.03
28	N/A	N/A	0.03	N/A	N/A	N/A	0.03
29	N/A	N/A	0.03	N/A	N/A	N/A	0.03
30	N/A	N/A	0.04	N/A	N/A	N/A	0.04
31	N/A	N/A	0.03	N/A	N/A	N/A	0.03
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES	
All daily readings ≤ 5 NTU? YES				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE 8/01/23	
				PHONE #: (503) -723-3565		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B2 Month/Year: July 2023

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
07/01/23	6:00 AM	1.37	34	46	20.4	7.9	13	Yes	4382
07/02/23	6:00 AM	1.34	32	42	20.4	8.2	15	Yes	4651
07/03/23	6:00 AM	1.43	21	30	20.5	7.9	13	Yes	6954
07/04/23	6:00 AM	1.34	26	35	20.3	7.7	13	Yes	5584
07/05/23	6:00 AM	1.29	21	27	21.1	7.8	12	Yes	6993
07/06/23	6:00 AM	1.36	24	33	21.3	7.7	12	Yes	6137
07/07/23	6:00 AM	1.33	22	29	21.5	7.7	12	Yes	6705
07/08/23	6:00 AM	1.31	27	35	22.0	8.1	13	Yes	5608
07/09/23	6:00 AM	1.30	30	40	20.5	7.9	13	Yes	4845
07/10/23	6:00 AM	1.30	31	40	21.5	7.8	12	Yes	4744
07/11/23	6:00 AM	1.39	33	46	19.2	7.8	14	Yes	4473
07/12/23	6:00 AM	1.44	23	34	22.1	8.3	14	Yes	6314
07/13/23	6:00 AM	1.41	30	43	21.7	7.9	12	Yes	4812
07/14/23	6:00 AM	1.38	32	44	22.1	7.8	11	Yes	4581
07/15/23	6:00 AM	1.35	31	42	22.2	7.7	11	Yes	4706
07/16/23	6:00 AM	1.34	30	40	22.5	7.9	11	Yes	4894
07/17/23	6:00 AM	1.32	32	42	22.6	7.9	11	Yes	4632
07/18/23	6:00 AM	1.28	25	32	21.5	7.7	12	Yes	5855
07/19/23	6:00 AM	1.30	21	28	22.2	7.8	11	Yes	6907
07/20/23	6:00 AM	1.36	22	30	22.5	7.8	11	Yes	6542
07/21/23	6:00 AM	1.39	24	34	22.6	7.7	11	Yes	6072
07/22/23	6:00 AM	1.35	26	35	22.2	7.7	11	Yes	5686
07/23/23	6:00 AM	1.39	18	25	23.0	7.7	10	Yes	8063
07/24/23	6:00 AM	1.31	34	45	23.2	7.7	10	Yes	4365
07/25/23	6:00 AM	1.29	31	40	21.8	7.9	12	Yes	4755
07/26/23	6:00 AM	1.28	22	28	21.2	7.8	12	Yes	6765
07/27/23	6:00 AM	1.32	24	32	21.9	7.9	12	Yes	6058
07/28/23	6:00 AM	1.41	30	43	22.0	8.0	12	Yes	4849
07/29/23	6:00 AM	1.29	33	42	21.8	8.0	12	Yes	4512
07/30/23	6:00 AM	1.29	31	41	22.1	7.8	11	Yes	4685
07/31/23	6:00AM	1.31	23	30	21.9	7.9	12	Yes	6449

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day