

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B2 Month/Year: August 2023

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08
2	N/A	N/A	0.06	N/A	N/A	N/A	0.06
3	N/A	N/A	0.04	N/A	N/A	N/A	0.04
4	N/A	N/A	0.04	N/A	N/A	N/A	0.04
5	N/A	N/A	0.04	N/A	N/A	N/A	0.04
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06
7	N/A	N/A	0.05	N/A	N/A	N/A	0.05
8	N/A	N/A	0.07	N/A	N/A	N/A	0.07
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07
10	N/A	N/A	0.03	N/A	N/A	N/A	0.03
11	N/A	N/A	0.04	N/A	N/A	N/A	0.04
12	N/A	N/A	0.03	N/A	N/A	N/A	0.03
13	N/A	N/A	0.04	N/A	N/A	N/A	0.04
14	N/A	N/A	0.04	N/A	N/A	N/A	0.04
15	N/A	N/A	0.04	N/A	N/A	N/A	0.04
16	N/A	N/A	0.05	N/A	N/A	N/A	0.05
17	N/A	N/A	0.06	N/A	N/A	N/A	0.06
18	N/A	N/A	0.04	N/A	N/A	N/A	0.04
19	N/A	N/A	0.04	N/A	N/A	N/A	0.04
20	N/A	N/A	0.06	N/A	N/A	N/A	0.06
21	N/A	N/A	0.03	N/A	N/A	N/A	0.03
22	N/A	N/A	0.03	N/A	N/A	N/A	0.03
23	N/A	N/A	0.04	N/A	N/A	N/A	0.04
24	N/A	N/A	0.04	N/A	N/A	N/A	0.04
25	N/A	N/A	0.04	N/A	N/A	N/A	0.04
26	N/A	N/A	0.04	N/A	N/A	N/A	0.04
27	N/A	N/A	0.06	N/A	N/A	N/A	0.06
28	N/A	N/A	0.06	N/A	N/A	N/A	0.06
29	N/A	N/A	0.03	N/A	N/A	N/A	0.03
30	N/A	N/A	0.04	N/A	N/A	N/A	0.04
31	N/A	N/A	0.06	N/A	N/A	N/A	0.06

Slow Sand/Membrane/DE Filtration/ Unfiltered	Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES	CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
Notes:	PRINTED NAME: Joe Rogers	
	SIGNATURE	DATE 9/01/23
	PHONE #: (503) -723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B2 Month/Year: August 2023

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
		(mg/L)	(minutes)					Yes / No	
08/01/23	6:00 AM	1.33	25	33	22.2	7.7	11	Yes	5955
08/02/23	6:00 AM	1.32	22	29	21.8	7.7	11	Yes	6629
08/03/23	6:00 AM	1.26	23	29	22.0	7.8	11	Yes	6394
08/04/23	6:00 AM	1.26	23	29	22.7	7.7	10	Yes	6383
08/05/23	6:00 AM	1.25	23	28	22.1	8.0	12	Yes	6596
08/06/23	6:00 AM	1.47	24	35	20.9	7.7	12	Yes	6241
08/07/23	6:00 AM	1.55	32	50	22.0	8.1	13	Yes	4562
08/08/23	6:00 AM	1.32	25	34	21.8	7.8	12	Yes	5794
08/09/23	6:00 AM	1.37	24	33	22.4	7.9	12	Yes	6064
08/10/23	6:00 AM	1.34	30	40	22.0	7.8	12	Yes	4954
08/11/23	6:00 AM	1.34	28	38	22.0	7.7	11	Yes	5195
08/12/23	6:00 AM	1.32	30	40	22.2	7.7	11	Yes	4884
08/13/23	6:00 AM	1.29	31	40	22.4	7.6	10	Yes	4905
08/14/23	6:00 AM	1.48	22	33	22.9	7.7	11	Yes	6579
08/15/23	6:00 AM	1.28	23	29	23.4	7.8	10	Yes	6542
08/16/23	6:00 AM	1.30	21	28	23.5	7.8	10	Yes	7012
08/17/23	6:00 AM	1.30	25	32	23.7	7.6	9	Yes	6002
08/18/23	6:00 AM	1.26	21	27	21.7	7.7	11	Yes	6951
08/19/23	6:00 AM	1.27	24	30	21.4	7.9	12	Yes	6254
08/20/23	6:00 AM	1.24	25	31	21.8	7.8	12	Yes	5968
08/21/23	6:00 AM	1.25	23	28	21.2	7.9	12	Yes	6422
08/22/23	6:00 AM	1.23	23	28	20.8	7.7	12	Yes	6391
08/23/23	6:00 AM	1.27	25	32	21.0	7.7	12	Yes	5914
08/24/23	6:00 AM	1.25	71	88	21.4	8.3	14	Yes	2114
08/25/23	6:00 AM	1.31	53	70	21.8	8.0	12	Yes	2921
08/26/23	6:00 AM	1.26	28	35	22.4	7.9	11	Yes	5322
08/27/23	6:00 AM	1.35	24	32	22.1	7.6	11	Yes	6226
08/28/23	6:00 AM	1.26	23	29	22.4	7.7	11	Yes	6338
08/29/23	6:00 AM	1.30	48	62	20.5	8.0	14	Yes	3108
08/30/23	6:00 AM	1.40	34	47	19.1	8.0	15	Yes	4478
08/31/23	6:00AM	1.20	38	46	20.3	8.3	15	Yes	4120

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day