


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: September 2023									
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]		
1	N/A	N/A	0.04	N/A	N/A	N/A	0.04		
2	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
3	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
4	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
5	N/A	N/A	0.08	N/A	N/A	N/A	0.08		
6	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
7	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
8	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
9	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
10	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
11	N/A	N/A	0.06	N/A	N/A	N/A	0.06		
12	N/A	N/A	0.06	N/A	N/A	N/A	0.06		
13	N/A	N/A	0.04	N/A	N/A	N/A	0.04		
14	N/A	N/A	0.03	N/A	N/A	N/A	0.03		
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09		
16	N/A	N/A	0.06	N/A	N/A	N/A	0.06		
17	N/A	N/A	0.04	N/A	N/A	N/A	0.04		
18	N/A	N/A	0.04	N/A	N/A	N/A	0.04		
19	N/A	N/A	0.06	N/A	N/A	N/A	0.06		
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07		
21	N/A	N/A	0.03	N/A	N/A	N/A	0.03		
22	N/A	N/A	0.04	N/A	N/A	N/A	0.04		
23	N/A	N/A	0.05	N/A	N/A	N/A	0.05		
24	N/A	N/A	0.04	N/A	N/A	N/A	0.04		
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08		
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN		
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary					
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back)		All CL2 residual at entry point ≥ 0.2 mg/l?			
All daily readings ≤ 5 NTU? YES				YES		YES			
Notes:				PRINTED NAME: Joe Rogers					
				SIGNATURE 			DATE 10/01/23		
				PHONE #: (503) 723-3505			CERT #: T-09162		

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B2 Month/Year: September 2023

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
09/01/23	6:00 AM	1.33	51	68	19.5	7.8	14	Yes	2965
09/02/23	6:00 AM	1.30	37	48	20.4	8.3	15	Yes	4082
09/03/23	6:00 AM	1.27	23	29	20.5	8.0	14	Yes	6417
09/04/23	6:00 AM	1.10	36	40	19.4	8.0	15	Yes	4053
09/05/23	6:00 AM	1.35	27	37	18.8	7.9	15	Yes	5591
09/06/23	6:00 AM	1.21	34	41	18.3	8.2	17	Yes	4529
09/07/23	6:00 AM	1.30	23	29	19.9	7.9	14	Yes	6530
09/08/23	6:00 AM	1.33	53	70	19.0	8.3	17	Yes	2911
09/09/23	6:00 AM	1.34	47	63	19.4	8.3	16	Yes	3194
09/10/23	6:00 AM	1.43	54	77	19.5	8.2	16	Yes	2769
09/11/23	6:00 AM	1.44	31	44	19.4	7.8	14	Yes	4899
09/12/23	6:00 AM	1.39	28	39	18.9	8.2	16	Yes	5368
09/13/23	6:00 AM	1.36	25	34	19.2	7.7	13	Yes	5952
09/14/23	6:00 AM	1.44	23	33	19.2	7.9	15	Yes	6555
09/15/23	6:00 AM	1.22	33	40	19.2	7.8	14	Yes	4632
09/16/23	6:00 AM	1.30	31	40	19.4	7.9	14	Yes	4803
09/17/23	6:00 AM	1.23	35	43	19.0	7.9	15	Yes	4318
09/18/23	6:00 AM	1.31	49	65	18.6	8.0	15	Yes	3069
09/19/23	6:00 AM	1.36	30	41	18.1	8.0	16	Yes	4890
09/20/23	6:00 AM	1.31	48	63	18.1	7.9	15	Yes	3126
09/21/23	6:00 AM	1.26	45	57	17.5	8.3	18	Yes	3201
09/22/23	6:00 AM	1.35	54	73	17.7	7.9	16	Yes	2794
09/23/23	6:00 AM	1.30	101	131	17.1	7.8	16	Yes	1466
09/24/23	6:00 AM	1.25	104	130	16.9	8.2	18	Yes	1415
09/25/23	6:00 AM	1.29	49	64	15.0	7.9	18	Yes	2948
09/26/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
09/27/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
09/28/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
09/29/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
09/30/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

*If Cl₂ at entry point <0.2 mg/L OR CT not met. notify DWP by end of next business day