

Membrane Filter Monthly Operating Report

County: **Clackamas**

System Name: **NCCWC**

Month/Year: **February 2026**

PWS ID#: 41 - **00580**

Minimum test pressure applied: **13.69** psi

Plant ID: WTP - **B2**

Minimum test pressure req'd: **11.4** psi

(e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

PDR_{Max} [^{psi}/_{min}]

LRC [log removal]

LRC = Log Removal Credit


0.484

4.00


DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU]	Highest PDR of day [^{psi} / _{min}]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.050	0.050	0.050	0.36	4.18	Y
2	0.020	0.020	0.070	0.36	4.18	Y
3	0.020	0.020	0.040	0.35	4.20	Y
4						off
5	0.020	0.020	0.050	0.39	4.16	Y
6						off
7	0.030	0.030	0.060	0.37	4.18	Y
8	0.020	0.020	0.060	0.38	4.18	Y
9	0.020	0.020	0.060	0.38	4.15	Y
10	0.020	0.020	0.060	0.37	4.14	Y
11	0.060	0.060	0.030	0.36	4.16	Y
12	0.030	0.030	0.030	0.37	4.16	Y
13	0.030	0.030	0.030	0.37	4.17	Y
14	0.060	0.060	0.060	0.38	4.15	Y
15	0.030	0.030	0.060	0.39	4.16	Y
16	0.040	0.040	0.060	0.39	4.15	Y
17	0.040	0.040	0.060	0.39	4.16	Y
18	0.030	0.030	0.060	0.38	4.16	Y
19	0.020	0.020	0.050	0.38	4.16	Y
20	0.030	0.030	0.030	0.37	4.15	Y
21	0.020	0.020	0.050	0.38	4.14	Y
22	0.040	0.040	0.060	0.38	4.14	Y
23	0.030	0.030	0.060	0.38	4.13	Y
24	0.030	0.030	0.060	0.40	4.11	Y
25	0.040	0.040	0.060	0.41	4.10	Y
26	0.040	0.040	0.060	0.41	4.11	Y
27	0.040	0.040	0.060	0.42	4.11	Y
28	0.040	0.040	0.060	0.42	4.10	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
		Yes	Yes	
PRINTED NAME:	Brent Carrar	DATE:	3/3/2026	
SIGNATURE:		WT CERT #:	T-355512	
Notes:		PHONE #:	(503) 723-3505	

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: February 2026							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.05	N/A	N/A	N/A	0.05
2	N/A	N/A	0.03	N/A	N/A	N/A	0.03
3	N/A	N/A	0.04	N/A	N/A	N/A	0.04
4	N/A	N/A	N/A	N/A	N/A	N/A	DOWN
5	N/A	N/A	0.05	N/A	N/A	N/A	0.05
6	N/A	N/A	N/A	N/A	N/A	N/A	DOWN
7	N/A	N/A	0.06	N/A	N/A	N/A	0.06
8	N/A	N/A	0.06	N/A	N/A	N/A	0.06
9	N/A	N/A	0.02	N/A	N/A	N/A	0.02
10	N/A	N/A	0.03	N/A	N/A	N/A	0.03
11	N/A	N/A	0.04	N/A	N/A	N/A	0.04
12	N/A	N/A	0.05	N/A	N/A	N/A	0.05
13	N/A	N/A	0.03	N/A	N/A	N/A	0.03
14	N/A	N/A	0.03	N/A	N/A	N/A	0.03
15	N/A	N/A	0.03	N/A	N/A	N/A	0.03
16	N/A	N/A	0.05	N/A	N/A	N/A	0.05
17	N/A	N/A	0.04	N/A	N/A	N/A	0.04
18	N/A	N/A	0.02	N/A	N/A	N/A	0.02
19	N/A	N/A	0.03	N/A	N/A	N/A	0.03
20	N/A	N/A	0.06	N/A	N/A	N/A	0.06
21	N/A	N/A	0.04	N/A	N/A	N/A	0.04
22	N/A	N/A	0.04	N/A	N/A	N/A	0.04
23	N/A	N/A	0.04	N/A	N/A	N/A	0.04
24	N/A	N/A	0.04	N/A	N/A	N/A	0.04
25	N/A	N/A	0.04	N/A	N/A	N/A	0.04
26	N/A	N/A	0.04	N/A	N/A	N/A	0.04
27	N/A	N/A	0.03	N/A	N/A	N/A	0.03
28	N/A	N/A	0.03	N/A	N/A	N/A	0.03
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES				PRINTED NAME: Brent Carrar			
Notes:				SIGNATURE 		DATE 3/3/2025	
				PHONE #: (503) 723-3505		CERT #: T-355512	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: February 2026

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
02/01/26	6:00 AM	1.53	107	163	6.5	8.4	42	Yes	1579
02/02/26	6:00 AM	1.51	110	167	7.2	8.7	44	Yes	1456
02/03/26	6:00 AM	1.40	70	98	6.8	8.6	43	Yes	2224
02/04/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/05/26	6:00 AM	1.30	46	60	7.3	8.1	34	Yes	3426
02/06/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/07/26	6:00 AM	1.63	98	160	6.9	8.5	43	Yes	1653
02/08/26	6:00 AM	1.57	38	60	8.1	8.3	37	Yes	4622
02/09/26	6:00 AM	1.53	35	53	7.6	8.2	36	Yes	4827
02/10/26	6:00 AM	1.39	38	52	7.1	8.1	36	Yes	4524
02/11/26	6:00 AM	1.23	105	129	7.1	8.3	37	Yes	1665
02/12/26	6:00 AM	1.02	123	125	7.2	8.5	39	Yes	1418
02/13/26	6:00 AM	1.24	121	150	6.5	8.6	43	Yes	1452
02/14/26	6:00 AM	1.38	110	152	7.1	8.5	41	Yes	1585
02/15/26	6:00 AM	1.32	124	163	7.3	8.4	39	Yes	1379
02/16/26	6:00 AM	1.31	126	165	7.5	8.5	39	Yes	1387
02/17/26	6:00 AM	1.27	75	95	7.3	8.5	39	Yes	2326
02/18/26	6:00 AM	1.20	75	91	7.1	8.5	40	Yes	2310
02/19/26	6:00 AM	1.26	108	136	7.2	8.5	40	Yes	1610
02/20/26	6:00 AM	1.17	109	128	6.8	8.3	38	Yes	1509
02/21/26	6:00 AM	1.25	131	163	7.2	8.4	39	Yes	1332
02/22/26	6:00 AM	1.19	47	56	7.8	8.6	40	Yes	3448
02/23/26	6:00 AM	1.39	37	51	7.6	7.8	31	Yes	4700
02/24/26	6:00 AM	1.38	29	40	7.2	7.9	32	Yes	5760
02/25/26	6:00 AM	1.52	36	55	7.5	7.9	32	Yes	4685
02/26/26	6:00 AM	1.25	43	54	7.2	8.3	37	Yes	3919
02/27/26	6:00 AM	1.23	37	45	6.8	8.2	36	Yes	4540
02/28/26	6:00 AM	1.28	50	64	6.6	8.5	41	Yes	3300

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day