

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional

Month/Year: Apr-21

System Name: Oakland, City of ID#: 41-00581 WTP: TP - 41-00581

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02
19	0.02	0.02	0.02	0.02	OFF	OFF	0.02
20	OFF	OFF	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.02	0.02	0.02	0.02	0.02
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02
24	OFF	OFF	OFF	0.02	0.02	0.02	0.02
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	OFF	OFF	0.02
30	OFF	OFF	0.02	0.02	0.02	0.02	0.02
31							

Conventional	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE2 triggers <input checked="" type="radio"/> Yes / No		

NOTES: Fire and Ash issues caused cleaning on daily schedule and for UV system and the turbidity meter systems.

PRINTED NAME: JAMES M. HART
 SIGNATURE: *James M. Hart* 5/1/2021
 PHONE #: (541) 580-6617 C#: T08699-FE

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individual Filter Eff. (335-061-0046(1))(e)(B&C)

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	DOUGLAS
System Name:	Oakland, City of		41-00581		Month/Year:	Apr-21	Disinfection Giardia Log Inactive:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			formula	Yes / No	[GPM]
1	1.00	163	163	10.0	6.86	36.8	yes	300
2	1.00	163	163	12.0	6.86	32.4	yes	300
3	1.00	163	163	12.0	6.86	32.4	yes	300
4	1.00	163	163	12.0	6.86	32.4	yes	300
5	1.00	163	163	12.0	6.86	32.4	yes	300
6	1.00	163	163	10.0	6.86	36.8	yes	300
7	1.00	163	163	12.0	6.86	32.4	yes	300
8	1.00	163	163	11.0	6.86	34.5	yes	300
9	1.00	163	163	11.0	6.86	34.5	yes	300
10	1.00	163	163	11.0	6.86	34.5	yes	300
11	1.00	163	163	13.0	6.86	29.6	yes	300
12	1.00	163	163	10.0	6.86	36.8	yes	300
13	1.00	163	163	11.0	6.86	34.5	yes	300
14	1.00	163	163	12.0	6.86	32.4	yes	300
15	1.00	163	163	12.0	6.86	32.4	yes	300
16	1.00	163	163	13.0	6.86	29.6	yes	300
17	1.00	163	163	13.0	6.86	29.6	yes	300
18	1.00	163	163	13.0	6.86	29.6	yes	300
19	1.00	163	163	15.0	6.86	25.9	yes	300
20	1.00	163	163	16.0	6.86	24.2	yes	300
21	1.00	163	163	12.0	6.86	32.4	yes	300
22	1.00	163	163	13.0	6.86	29.6	yes	300
23	1.00	163	163	12.0	6.86	32.4	yes	300
24	1.00	163	163	12.0	6.86	32.4	yes	300
25	1.00	163	163	13.0	6.86	29.6	yes	300
26	1.00	163	163	11.0	6.86	34.5	yes	300
27	1.00	163	163	13.0	6.86	29.6	yes	300
28	1.00	163	163	11.0	6.86	34.5	yes	300
29	1.00	163	163	13.0	6.86	29.6	yes	300
30	1.00	163	163	17.0	6.86	22.6	yes	300
31								

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

