

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional

Month/Year: Jan-23

System Name: Oakland, City of ID#: 41-00581 WTP : TP - 41-00581

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.02	0.02	0.02	0.02	0.02	0.02	0.03
2	0.02	0.02	0.02	0.02	0.02	0.02	0.03
3	0.02	0.02	0.02	0.02	0.02	0.02	0.03
4	0.02	0.02	0.02	0.02	0.02	0.02	0.03
5	0.02	0.02	0.02	0.02	0.02	0.02	0.03
6	0.02	0.02	0.02	0.02	0.02	0.02	0.03
7	OFF	OFF	OFF	OFF	OFF	STORM	0.03
8	0.02	0.02	0.02	0.02	0.02	0.02	0.03
9	0.02	0.02	0.02	0.02	0.02	0.02	0.03
10	0.02	0.02	0.02	0.02	0.02	0.02	0.03
11	0.02	0.02	0.02	0.02	0.02	0.02	0.03
12	0.02	0.02	0.02	0.02	0.02	0.02	0.03
13	OFF	OFF	OFF	OFF	OFF	STORM	0.03
14	OFF	OFF	OFF	OFF	OFF	STORM	0.03
15	OFF	OFF	OFF	OFF	OFF	STORM	0.03
16	OFF	OFF	OFF	OFF	OFF	OFF	0.03
17	OFF	OFF	OFF	OFF	OFF	OFF	0.03
18	OFF	OFF	OFF	OFF	OFF	STORM	0.03
19	0.02	0.02	0.02	0.02	0.02	0.02	0.03
20	0.02	0.02	0.02	0.02	0.02	0.02	0.03
21	OFF	OFF	OFF	OFF	OFF	OFF	0.03
22	OFF	OFF	OFF	OFF	OFF	OFF	0.03
23	OFF	OFF	OFF	OFF	OFF	STORM	0.03
24	OFF	OFF	OFF	OFF	OFF	STORM	0.03
25	OFF	OFF	OFF	0.02	0.02	0.02	0.03
26	0.02	0.02	0.02	0.02	0.02	0.02	0.03
27	0.02	0.02	0.02	0.02	0.02	0.02	0.03
28	0.02	0.02	0.02	0.02	0.02	0.02	0.03
29	0.02	0.02	0.02	0.02	0.02	0.02	0.03
30	0.02	0.02	0.02	0.02	0.02	0.02	0.03
31	0.02	0.02	0.02	0.02	0.02	0.02	0.03

Conventional

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU?

Yes / No

All 4-hour turbidity readings ≤ 1 NTU?

Yes / No

All turbidity readings < IFE2 triggers

Yes / No

CT's met everyday?
(see back)

Yes / No

All Cl2 residual at entry point
≥ 0.2 mg/l?

Yes / No

NOTES: NTU remained between 0.01-0.1 NTU but now chlorine has dropped down to 0.20 mg/l levels at furthest point, Cl2 has been increase by 200 % and still 0.2 lingers at furthest point, more and more cfz is required and customers complain of taste, odor and mold. Engineers suspect bacteria passed into distribution system that eats iron but is not detected by ecoli test. FEMA has funded project to correct. Sensors still grow slime, optics coated and cleaned to take readings, extreme sludge from organics.

PRINTED NAME: JAMES M. HART

PRINTED NAME: JAMES M. HART

2/7/2024

PHONE #: (541) 580-6617

C#: T08699-FE

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	DOUGLAS
System Name:	Oakland, City of		41-00581		Month/Year:	Jan-24	Disinfection Giardia Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			formula		[GPM]
1	1.39	163	227	10.00	6.90	38.9	yes	300
2	1.39	163	227	10.00	6.90	38.9	yes	300
3	1.39	163	227	10.00	6.90	38.9	yes	300
4	1.39	163	227	9.50	6.90	40.2	yes	300
5	1.39	163	227	9.10	6.90	41.3	yes	300
6	1.39	163	227	9.00	6.90	41.6	yes	300
7	1.39	163	227	10.00	6.90	38.9	yes	300
8	1.39	163	227	8.90	6.90	41.8	yes	300
9	1.39	163	227	9.80	6.90	39.4	yes	300
10	1.39	163	227	9.30	6.90	40.8	yes	300
11	1.39	163	227	9.20	6.90	41.0	yes	300
12	1.39	163	227	9.10	6.90	41.3	yes	300
13	1.39	163	227	8.90	6.90	41.8	yes	300
14	1.39	163	227	8.90	6.90	41.8	yes	300
15	1.39	163	227	8.90	6.90	41.8	yes	300
16	1.39	163	227	8.90	6.90	41.8	yes	300
17	1.39	163	227	9.40	6.90	40.5	yes	300
18	1.39	163	227	10.00	6.90	38.9	yes	300
19	1.39	163	227	10.00	6.90	38.9	yes	300
20	1.39	163	253	10.00	6.90	38.9	yes	300
21	1.39	163	227	10.00	6.90	38.9	yes	300
22	1.39	163	227	11.00	6.90	36.5	yes	300
23	1.39	163	227	13.00	6.90	31.4	yes	300
24	1.39	163	227	12.00	6.90	34.2	yes	300
25	1.39	163	227	12.00	6.90	34.2	yes	300
26	1.39	163	227	12.00	6.90	34.2	yes	300
27	1.39	163	227	12.00	6.90	34.2	yes	300
28	1.39	163	227	13.00	6.90	31.4	yes	300
29	1.39	163	227	12.00	6.90	34.2	yes	300
30	1.39	163	227	13.00	6.90	31.4	yes	300
31	1.39	163	227	13.00	6.90	31.4	yes	300

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

(JH)

