

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional

Month/Year: Aug-24

System Name: Oakland, City of ID#: 41-00581

WTP : TP - 41-00581

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.06	0.04	0.03	0.03	0.06
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	OFF	OFF	OFF	OFF	OFF	OFF	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Conventional		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE2 triggers	Yes / No		

NOTES: NTU remained between 0.01-0.1 NTU. Stain on optics present. 33 F temperatures affect filter profiles and filter run times, very high water demand 300 gpm, two broken flow control valves ordered new from unit process and now broken distribution pump, ordered parts system still off line. High distribution chlorine demand.

PRINTED NAME: JAMES M. HART
 PRINTED NAME: JAMES M. HART
 PHONE #: (541) 580-6617
 9/2/2024
 C#: T08699-FE



OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	DOUGLAS
System Name:	Oakland, City of		41-00581		Month/Year:	Aug-24	Disinfection Giardia Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			formula		[GPM]
1	1.34	141	189	30.00	6.90	9.8	yes	300
2	1.33	141	188	30.00	6.90	9.8	yes	300
3	1.34	141	189	31.00	6.90	9.1	yes	300
4	1.33	141	188	30.00	6.90	9.8	yes	300
5	1.31	141	185	30.00	6.90	9.7	yes	300
6	1.34	141	189	30.00	6.90	9.8	yes	300
7	1.34	141	189	28.00	6.90	11.3	yes	300
8	1.33	141	188	28.00	6.90	11.2	yes	300
9	1.33	141	188	28.00	6.90	11.2	yes	300
10	1.30	141	184	26.00	6.90	12.9	yes	300
11	1.31	141	185	26.00	6.90	12.9	yes	300
12	1.32	141	187	26.00	6.90	12.9	yes	300
13	1.32	141	187	26.00	6.90	12.9	yes	300
14	1.33	141	188	26.00	6.90	12.9	yes	300
15	1.63	141	230	26.00	6.90	13.4	yes	300
16	1.61	141	228	26.00	6.90	13.3	yes	300
17	1.36	141	192	26.00	6.90	13.0	yes	300
18	1.33	141	188	23.00	6.90	15.9	yes	300
19	1.34	141	22	22.00	6.90	17.0	yes	300
20	1.31	141	253	25.00	6.90	14.2	yes	300
21	1.58	141	223	21.00	6.90	18.7	yes	300
22	1.58	141	223	22.00	6.90	17.5	yes	300
23	1.45	141	205	19.00	6.90	21.1	yes	300
24	1.43	141	202	19.00	6.90	21.1	yes	300
25	1.41	141	199	19.00	6.90	21.0	yes	300
26	1.40	141	198	18.00	6.90	22.5	yes	300
27	1.39	141	197	17.00	6.90	24.0	yes	300
28	1.38	141	195	23.00	6.90	16.0	yes	300
29	1.39	141	197	24.00	6.90	14.9	yes	300
30	1.39	141	197	24.00	6.90	14.9	yes	300
31	1.38	141	195	24.00	6.90	14.9	yes	300

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

(JH)