

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County: Douglas		
Conventional							Month/Year: May-25		
System Name:		Oakland, City of		ID#: 41-00581		WTP : TP - 41-00581			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]		
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03		
Conventional					Monthly Summary (Answer Yes or No)				
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?				Yes / No		CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All 4-hour turbidity readings $\leq$ 1 NTU?				Yes / No		Yes / No		Yes / No	
All turbidity readings < IFE2 triggers				Yes / No					
NOTES: NTU remained between 0.01-0.1 NTU Stain on optics present.PPL power fails, treatment plant construction shut downs					PRINTED NAME: JAMES M. HART				
					PRINTED NAME: JAMES M. HART			6/10/2025	
					PHONE #: (541) 580-6617			C#: T08699-FE	

OHA - Drinking Water Program - Surface Water Quality Data Form						WTP - :	DOUGLAS	
System Name:	Oakland, City of		41-00581		Month/Year:	May-25	Disinfection Giardia Log Inactive:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			formula		[GPM]
1	1.44	167	240	11	7.00	38.0	yes	254
2	1.40	167	234	11	7.00	37.8	yes	254
3	1.43	167	239	11	7.00	37.9	yes	254
4	1.43	167	239	11	7.00	37.9	yes	254
5	1.43	167	239	11	7.00	37.9	yes	254
6	1.41	167	235	11	7.00	37.9	yes	254
7	1.39	167	232	11	7.00	37.8	yes	254
8	1.40	167	234	11	7.00	37.8	yes	254
9	1.41	167	235	12	7.00	35.5	yes	254
10	1.42	167	237	13	7.00	32.7	yes	254
11	1.41	167	235	13	7.00	32.6	yes	254
12	1.39	167	232	12	7.00	35.4	yes	254
13	1.40	167	234	11	7.00	37.8	yes	254
14	1.41	167	235	11	7.00	37.9	yes	254
15	1.38	167	230	11	7.00	37.7	yes	254
16	1.38	167	230	12	7.00	35.4	yes	254
17	1.39	167	232	12	7.00	35.4	yes	254
18	1.40	167	234	12	7.00	35.4	yes	254
19	1.41	167	22	12	7.00	35.5	yes	254
20	1.42	167	253	13	7.00	#REF!	yes	254
21	1.44	167	240	13	7.00	32.7	yes	254
22	1.44	167	240	13	7.00	32.7	yes	254
23	1.43	167	239	11	7.00	37.9	yes	254
24	1.42	167	237	11	7.00	37.9	yes	254
25	1.43	167	239	13	7.00	32.7	yes	254
26	1.42	167	237	14	7.00	30.6	yes	254
27	1.42	167	237	13	7.00	32.7	yes	254
28	1.41	167	235	14	7.00	30.5	yes	254
29	1.41	167	235	14	7.00	30.5	yes	254
30	1.40	167	234	15	7.00	28.5	yes	254
31	1.43	167	239	15	7.00	28.6	yes	254

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

Page 2 of 2