

OHA - Drinking Water Program -Turbidity Monitoring Report Form

County: Douglas

Conventional

Month/Year: Oct-25

System Name: Oakland, City of ID#: 41-00581 WTP : TP - 41-00581

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Conventional

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?☒ Yes / ☐ NoAll 4-hour turbidity readings $\leq$ 1 NTU?☒ Yes / ☐ No

All turbidity readings < IFE2 triggers

☒ Yes / ☐ NoCT's met everyday?
(see back)☒ Yes / ☐ NoAll Cl2 residual at entry point
 $\geq$ 0.2 mg/l?☒ Yes / ☐ No

NOTES: NTU remained between 0.01-0.1 NTU. Stain on optics present. Water temperatures in stream are back to normal, little changes other than temperature

PRINTED NAME: JAMES M. HART

PRINTED NAME: JAMES M. HART

11/4/2025

PHONE #: (541) 580-6617

C#: T08699-FE



OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	DOUGLAS
System Name:	Oakland, City of	41-00581		Month/Year:	Oct-25		Disinfection Giardia Log Inactive:	1
Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			formula		[GPM]
1	1.31	167	219	18	6.80	21.4	yes	300
2	1.31	167	219	18	6.80	21.4	yes	300
3	1.31	167	219	18	6.80	21.4	yes	300
4	1.31	167	219	17	6.80	22.9	yes	300
5	1.30	167	217	18	6.80	21.4	yes	300
6	1.30	167	217	18	6.80	21.4	yes	300
7	1.31	167	219	17	6.80	22.9	yes	300
8	1.31	167	219	16	6.80	24.5	yes	300
9	1.31	167	219	16	6.80	24.5	yes	300
10	1.30	167	217	15	6.80	26.2	yes	300
11	1.31	167	219	16	6.80	24.5	yes	300
12	1.30	167	217	17	6.80	22.9	yes	300
13	1.30	167	217	17	6.80	22.9	yes	300
14	1.31	167	219	16	6.80	24.5	yes	300
15	1.32	167	220	16	6.80	24.5	yes	300
16	1.32	167	220	16	6.80	24.5	yes	300
17	1.31	167	219	15	6.80	26.2	yes	300
18	1.31	167	219	16	6.80	24.5	yes	300
19	1.30	167	217	15	6.80	26.2	yes	300
20	1.30	167	217	14	6.80	28.0	yes	300
21	1.30	167	217	14	6.80	28.0	yes	300
22	1.30	167	217	14	6.80	28.0	yes	300
23	1.30	167	217	14	6.80	28.0	yes	300
24	1.31	167	219	13	6.80	29.9	yes	300
25	1.32	167	220	13	6.80	30.0	yes	300
26	1.31	167	219	12	6.80	32.8	yes	300
27	1.31	167	219	13	6.80	29.9	yes	300
28	1.30	167	217	13	6.80	29.9	yes	300
29	1.30	167	217	12	6.80	32.8	yes	300
30	1.31	167	219	12	6.80	32.8	yes	300
31	1.30	167	217	12	6.80	32.8	yes	300

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012