

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Douglas
Conventional							Month/Year:	Nov-25
System Name:	Oakland, City of			ID#: 41-00581			WTP : TP -	41-00581
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
21	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02	
31								

Conventional		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE2 triggers	☒ Yes / ☐ No		

NOTES: NTU remained between 0.01-0.1 NTU. Stain on optics present. Water temperatures in stream are back to normal, little changes other than temperature. Online pH probes show a 1 unit difference from daily calibrated BOD meter. Contacted Hach and they will not provide answer. Ordering a different online pH probe to get more accurate results.

PRINTED NAME: JAMES M. HART	
PRINTED NAME: JAMES M. HART	12/2/2025
PHONE #: (541) 580-6617	C#: T08699-FE

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	DOUGLAS
System Name:	Oakland, City of		41-00581		Month/Year:	Nov-25	Disinfection Giardia Log Inactive:	1
Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			formula		[GPM]
1	1.65	147	243	12	7.91	50.1	yes	288
2	1.63	147	240	12	7.91	50.0	yes	288
3	1.63	147	240	12	7.91	50.0	yes	288
4	1.65	147	243	13	7.91	46.9	yes	288
5	1.68	147	247	13	7.91	47.0	yes	288
6	1.68	147	247	12	7.91	50.3	yes	288
7	1.68	147	247	12	7.91	50.3	yes	288
8	1.65	147	243	12	7.91	50.1	yes	288
9	1.65	147	243	12	7.91	50.1	yes	288
10	1.65	147	243	12	7.91	50.1	yes	288
11	1.65	147	243	12	7.91	50.1	yes	288
12	1.64	147	241	12	7.91	50.1	yes	288
13	1.64	147	241	11	7.91	53.5	yes	288
14	1.65	147	243	11	7.91	53.6	yes	288
15	1.61	147	237	10	7.91	57.1	yes	288
16	1.60	147	235	10	7.91	57.0	yes	288
17	1.65	147	243	10	7.91	57.3	yes	288
18	1.65	147	243	10	7.91	57.3	yes	288
19	1.68	147	247	10	7.91	57.5	yes	288
20	1.68	147	247	10	7.91	57.3	yes	288
21	1.65	147	243	10	7.91	57.3	yes	288
22	1.67	147	245	10	7.91	57.5	yes	288
23	1.67	147	245	9	7.91	61.5	yes	288
24	1.68	147	247	9	7.91	61.6	yes	288
25	1.68	147	247	9	7.91	61.6	yes	288
26	1.65	147	243	9	7.91	61.3	yes	288
27	1.75	147	257	9	7.91	62.1	yes	288
28	1.78	147	262	8	7.91	66.7	yes	288
29	1.79	147	263	9	7.91	62.4	yes	288
30	1.80	147	265	9	7.91	62.4	yes	288
3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.							Revised February 2012	
							Page 2 of 2	
							jh	