

OHA - Drinking Water Program - Turbidity Monitoring Report Form

County: Douglas

Month/Year: Feb 23

Conventional

WTP : TP - 41-00581

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]	
1	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
2	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	Snow
4	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
5	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
6	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
7	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
8	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
9	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
10	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
11	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	Snow
13	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
14	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF	Snow
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	Snow
17	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
18	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
19	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
20	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
21	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
22	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
23	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
24	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
25	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
26	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
27	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
28	0.01	0.01	0.01	0.01	0.01	0.01	0.02	
29								
30								
31								

Conventional	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU? <span style="float: right;">(Yes/No)</span>	CT's met everyday? (see back) <span style="float: right;">(Yes/No)</span>	All Cl2 residual at entry point $\geq$ 0.2 mg/l? <span style="float: right;">(Yes/No)</span>
All 4-hour turbidity readings $\leq$ 1 NTU? <span style="float: right;">(Yes/No)</span>		
All turbidity readings < IFE2 triggers <span style="float: right;">(Yes/No)</span>		

NOTES: NTU remained between 0.01-0.1 NTU for all effluent water and fire ash stains continues to make sensor cleaning difficult, super cold weather causes frozen pipes and high organics.

COLD WEATHER FROZEN PIPES

PRINTED NAME: JAMES M. HART	3/1/2023
PRINTED NAME: JAMES M. HART	
PHONE #: (541) 580-6617	C#: T08699-FE

