

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Jun-21


Membrane

System Name: Oceanside, City of

ID#: 41 00585

WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.021	0.021	0.021	0.021	0.021	OFF	0.023
2	OFF	OFF	0.021	0.022	0.021	0.021	0.024
3	0.022	OFF	OFF	0.023	OFF	0.020	0.024
4	0.021	0.021	0.022	OFF	0.021	0.022	0.023
5	OFF	OFF	OFF	0.022	0.020	0.021	0.024
6	0.020	0.020	0.021	OFF	0.021	OFF	0.023
7	0.021	0.021	0.022	0.022	0.021	OFF	0.023
8	OFF	OFF	OFF	OFF	0.021	0.022	0.025
9	0.021	0.022	0.022	0.022	OFF	OFF	0.023
10	OFF	OFF	0.021	0.021	0.022	0.021	0.023
11	0.022	OFF	OFF	OFF	OFF	OFF	0.024
12	OFF	OFF	0.022	0.022	OFF	0.021	0.024
13	0.022	0.022	0.021	0.021	0.021	0.021	0.022
14	0.021	0.021	0.021	OFF	OFF	OFF	0.023
15	OFF	OFF	OFF	0.022	OFF	OFF	0.059
16	OFF	OFF	OFF	OFF	0.022	0.021	0.025
17	0.022	0.022	0.022	0.022	0.022	0.021	0.023
18	0.021	0.021	0.021	0.021	0.021	0.021	0.023
19	0.021	0.021	0.021	0.021	0.021	OFF	0.024
20	0.021	OFF	0.021	0.022	0.022	0.021	0.024
21	0.021	0.021	0.021	0.022	0.022	0.022	0.024
22	0.022	0.022	0.022	0.022	0.022	0.022	0.024
23	0.022	0.022	OFF	0.022	0.022	0.021	0.026
24	OFF	OFF	OFF	0.020	0.020	0.020	0.022
25	OFF	0.020	0.020	0.020	0.021	0.020	0.025
26	0.020	0.020	0.020	0.021	0.021	0.021	0.026
27	0.020	0.020	0.020	0.020	0.021	0.021	0.021
28	0.020	0.020	0.020	OFF	0.019	0.019	0.020
29	0.019	0.019	0.019	0.020	0.019	0.019	0.023
30	0.019	0.019	0.019	0.019	0.019	0.019	0.023

Membrane		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All daily turbidity readings < 5 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
Notes:		PRINTED NAME: David L. Nordman	
		SIGNATURE: 	DATE: 7/7/2021
		PHONE #: (503) 842-6462	T-08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: **Oceanside, City of** ID#: **41 00585** Month/Year: **Jun-21** Disinfection Giardia Log Inactiv: **1.000**

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.790	142.00	112.2	13.2	7.68	38.6	YES	300
2	0.890	142.00	126.4	18.9	7.84	28.3	YES	300
3	1.110	142.00	157.6	14.7	7.81	38.0	YES	300
4	1.140	142.00	161.9	14.2	7.62	36.7	YES	300
5	1.130	142.00	160.5	13.9	7.80	40.0	YES	300
6	1.150	142.00	163.3	14.0	7.82	40.1	YES	300
7	1.200	142.00	170.4	13.9	7.80	40.3	YES	300
8	1.080	142.00	153.4	14.1	7.71	38.0	YES	300
9	0.720	142.00	102.2	13.2	7.76	39.4	YES	300
10	0.860	142.00	122.1	12.6	7.68	40.5	YES	300
11	0.610	142.00	86.6	14.3	7.60	34.1	YES	300
12	0.680	142.00	96.6	14.6	7.61	33.8	YES	300
13	0.700	142.00	99.4	14.7	7.62	33.8	YES	300
14	0.680	142.00	96.6	14.8	7.65	33.9	YES	300
15	0.740	142.00	105.1	14.9	7.70	34.5	YES	300
16	0.590	142.00	83.8	14.3	7.67	34.9	YES	300
17	0.850	142.00	120.7	15.2	7.54	32.3	YES	300
18	0.870	142.00	123.5	15.1	7.45	31.5	YES	300
19	0.890	142.00	126.4	14.5	7.64	35.3	YES	300
20	0.910	142.00	129.2	14.6	7.62	34.8	YES	300
21	0.960	142.00	136.3	14.7	7.65	35.2	YES	300
22	0.940	142.00	133.5	14.9	7.60	34.0	YES	300
23	0.800	142.00	113.6	15.6	7.34	29.0	YES	300
24	0.800	142.00	113.6	15.9	7.24	27.4	YES	300
25	0.730	142.00	103.7	16.5	7.54	29.2	YES	300
26	0.740	142.00	105.1	16.3	7.44	28.5	YES	300
27	0.780	142.00	110.8	16.4	7.46	28.7	YES	300
28	0.800	142.00	113.6	16.6	7.50	28.8	YES	300
29	0.810	142.00	115.0	16.4	7.46	28.8	YES	300
30	0.610	142.00	86.6	16.6	7.65	29.8	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013