

OHA - Drinking Water Services - Turbidity Monitoring Report Form


County:	Tillamook
Month/Year:	Jan-22

Membrane

System Name: Oceanside, City of	ID#: 41 00585	WTP : A
---------------------------------	---------------	---------

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.013	0.013	0.013	0.013	0.013	0.013	0.013
2	OFF	OFF	OFF	OFF	0.014	0.017	0.017
3	0.017	0.019	0.021	0.013	0.013	0.013	0.021
4	0.013	0.013	0.013	0.013	0.013	OFF	0.014
5	OFF	OFF	OFF	OFF	OFF	0.013	0.015
6	OFF	OFF	OFF	OFF	OFF	OFF	0.016
7	OFF	OFF	OFF	0.013	0.013	0.013	0.015
8	0.013	OFF	OFF	OFF	OFF	OFF	0.014
9	OFF	OFF	OFF	OFF	OFF	0.013	0.014
10	OFF	OFF	OFF	OFF	OFF	OFF	0.014
11	OFF	OFF	OFF	0.013	OFF	0.013	0.017
12	0.013	OFF	OFF	OFF	0.013	0.013	0.015
13	0.013	OFF	OFF	0.025	0.013	OFF	0.028
14	OFF	OFF	OFF	OFF	OFF	OFF	0.014
15	OFF	OFF	0.013	0.013	0.013	0.013	0.014
16	OFF	OFF	OFF	OFF	OFF	0.013	0.014
17	OFF	OFF	OFF	OFF	OFF	0.013	0.013
18	0.013	OFF	OFF	0.013	OFF	0.013	0.013
19	OFF	OFF	OFF	0.013	0.013	OFF	0.014
20	OFF	OFF	OFF	0.013	0.013	0.013	0.014
21	OFF	OFF	OFF	OFF	0.013	0.013	0.014
22	OFF	OFF	OFF	OFF	0.013	0.013	0.014
23	0.013	OFF	OFF	OFF	0.013	0.013	0.013
24	OFF	OFF	OFF	0.013	0.013	OFF	0.014
25	OFF	OFF	OFF	0.013	0.013	OFF	0.014
26	OFF	OFF	OFF	0.013	0.013	OFF	0.014
27	OFF	OFF	OFF	0.013	0.013	OFF	0.014
28	OFF	OFF	OFF	OFF	OFF	OFF	0.014
29	OFF	0.013	OFF	0.013	0.013	0.013	0.014
30	0.013	0.013	0.013	OFF	OFF	OFF	0.014
31	OFF	OFF	OFF	0.013	0.013	OFF	0.015

Membrane		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: 	DATE: 2/8/2022
	PHONE #: (503) 842-6462	CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Jan-22 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.140	142.00	161.9	8.3	7.72	56.6	YES	300
2	1.130	142.00	160.5	8.2	7.68	56.1	YES	300
3	1.070	142.00	151.9	8.6	7.52	51.2	YES	300
4	1.200	142.00	170.4	8.4	7.59	54.0	YES	300
5	1.000	142.00	142.0	8.1	7.66	55.3	YES	300
6	0.960	142.00	136.3	8.7	7.43	48.7	YES	300
7	0.850	142.00	120.7	8.7	7.40	47.6	YES	300
8	0.840	142.00	119.3	8.7	7.44	48.2	YES	300
9	0.610	142.00	86.6	10.1	7.38	41.9	YES	300
10	0.730	142.00	103.7	10.0	7.41	43.2	YES	300
11	0.810	142.00	115.0	10.4	7.46	43.2	YES	300
12	0.830	142.00	117.9	9.9	7.38	43.5	YES	300
13	1.030	142.00	146.3	10.0	7.76	50.6	YES	300
14	0.760	142.00	107.9	10.1	7.74	48.4	YES	300
15	0.770	142.00	109.3	9.6	7.96	54.2	YES	300
16	0.790	142.00	112.2	9.3	7.91	54.4	YES	300
17	0.740	142.00	105.1	11.1	7.34	39.3	YES	300
18	0.890	142.00	126.4	10.2	7.39	43.1	YES	300
19	1.080	142.00	153.4	10.7	7.63	46.4	YES	300
20	0.850	142.00	120.7	11.2	7.47	41.3	YES	300
21	0.850	142.00	120.7	9.9	7.74	49.5	YES	300
22	0.960	142.00	136.3	10.7	7.46	43.1	YES	300
23	0.880	142.00	125.0	10.8	7.62	44.9	YES	300
24	0.930	142.00	132.1	10.2	7.35	42.7	YES	300
25	0.860	142.00	122.1	9.9	7.85	51.6	YES	300
26	0.910	142.00	129.2	9.6	7.35	44.3	YES	300
27	0.990	142.00	140.6	9.5	7.65	50.1	YES	300
28	0.830	142.00	117.9	10.1	7.76	49.1	YES	300
29	0.820	142.00	116.4	9.5	7.85	52.7	YES	300
30	0.840	142.00	119.3	9.7	7.67	48.9	YES	300
31	0.910	142.00	129.2	9.5	7.60	48.7	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013