

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Mar-22

Membrane

System Name: Oceanside, City of

ID#: 41 00585

WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	0.015	0.013	0.016
2	0.014	0.014		0.014	0.014	0.014	0.015
3	0.014	0.014	OFF	OFF	OFF	OFF	0.015
4	OFF	OFF	OFF	OFF	0.014	0.013	0.016
5	OFF	OFF	OFF	OFF	OFF	OFF	0.014
6	0.014	OFF	OFF	OFF	0.014	0.013	0.015
7	0.013	0.013	OFF	OFF	OFF	OFF	0.015
8	OFF	OFF	OFF	OFF	0.015	0.013	0.019
9	0.013	OFF	OFF	OFF	OFF	OFF	0.018
10	0.013	OFF	OFF	0.013	OFF	OFF	0.017
11	0.013	OFF	0.013	OFF	OFF	OFF	0.014
12	OFF	OFF	0.013	OFF	OFF	OFF	0.017
13	OFF	OFF	OFF	OFF	OFF	OFF	0.016
14	OFF	OFF	OFF	OFF	0.014	0.013	0.018
15	0.013	0.013	0.014	OFF	OFF	OFF	0.015
16	OFF	OFF	OFF	OFF	OFF	0.014	0.018
17	OFF	OFF	OFF	OFF	OFF	OFF	0.015
18	0.014	OFF	0.014	OFF	OFF	OFF	0.015
19	OFF	OFF	OFF	OFF	0.014	OFF	0.023
20	OFF	OFF	OFF	OFF	0.014	OFF	0.015
21	OFF	0.013	0.013	0.014	OFF	OFF	0.016
22	OFF	OFF	0.015	0.014	0.014	OFF	0.025
23	OFF	OFF	OFF	0.014	0.014	OFF	0.014
24	OFF	OFF	OFF	0.014	0.014	0.014	0.016
25	0.013	OFF	OFF	OFF	OFF	OFF	0.014
26	0.013	OFF	OFF	OFF	OFF	OFF	0.015
27	OFF	0.013	OFF	0.014	0.013	0.013	0.014
28	0.013	OFF	OFF	OFF	OFF	OFF	0.014
29	OFF	OFF	OFF	0.014	0.013	OFF	0.015
30	OFF	OFF	OFF	OFF	OFF	OFF	0.014
31	0.013	0.013	OFF	0.014	OFF	OFF	0.016

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All daily turbidity readings < 5 NTU? Yes / No		

Notes:	PRINTED NAME: David Nordman	
	SIGNATURE: 	DATE: 4-3-2022
	PHONE #: (503) 842-6462	CERT #: T-08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Mar-22 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.970	142.00	137.7	9.0	7.51	49.1	YES	300
2	0.900	142.00	127.8	9.6	7.46	46.0	YES	300
3	0.830	142.00	117.9	8.9	7.73	52.6	YES	300
4	0.890	142.00	126.4	9.7	7.60	48.0	YES	300
5	0.910	142.00	129.2	9.6	7.39	44.9	YES	300
6	0.830	142.00	117.9	9.2	7.65	50.1	YES	300
7	0.860	142.00	122.1	9.1	7.83	54.0	YES	300
8	0.820	142.00	116.4	9.3	7.81	52.7	YES	300
9	0.920	142.00	130.6	9.6	7.38	44.8	YES	300
10	1.030	142.00	146.3	9.2	7.31	45.5	YES	300
11	0.940	142.00	133.5	10.4	7.66	47.0	YES	300
12	0.920	142.00	130.6	9.9	7.44	44.9	YES	300
13	0.870	142.00	123.5	9.0	7.59	50.0	YES	300
14	0.700	142.00	99.4	9.4	7.65	48.8	YES	300
15	0.870	142.00	123.5	9.7	7.63	48.4	YES	300
16	0.940	142.00	133.5	9.9	7.67	48.8	YES	300
17	0.830	142.00	117.9	9.4	7.68	50.0	YES	300
18	0.950	142.00	134.9	9.8	7.61	48.2	YES	300
19	0.970	142.00	137.7	9.5	7.47	46.9	YES	300
20	0.970	142.00	137.7	9.4	7.63	49.9	YES	300
21	1.150	142.00	163.3	9.3	7.61	50.9	YES	300
22	1.040	142.00	147.7	10.0	7.70	49.6	YES	300
23	0.970	142.00	137.7	10.0	7.49	45.7	YES	300
24	1.100	142.00	156.2	11.4	7.47	41.9	YES	300
25	0.930	142.00	132.1	11.5	7.80	45.9	YES	300
26	1.000	142.00	142.0	11.0	7.41	41.7	YES	300
27	1.010	142.00	143.4	10.6	7.49	44.1	YES	300
28	1.010	142.00	143.4	10.7	7.45	43.2	YES	300
29	0.970	142.00	137.7	12.0	7.62	41.9	YES	300
30	0.890	142.00	126.4	10.5	7.42	42.7	YES	300
31	0.830	142.00	117.9	10.7	7.56	44.0	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013