

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Nov-22

Membrane

System Name: Oceanside, City of ID#: 41 00585 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day 1 [NTU]
1	OFF	0.014	0.014	OFF	OFF	0.014	0.019
2	0.014	0.014	OFF	OFF	OFF	OFF	0.015
3	OFF	0.014	OFF	OFF	OFF	0.014	0.016
4	0.014	OFF	0.015	0.015	0.014	0.014	0.016
5	OFF	0.014	OFF	OFF	OFF	OFF	0.015
6	0.014	0.014	OFF	0.014	OFF	OFF	0.016
7	0.014	OFF	OFF	0.015	0.014	OFF	0.016
8	0.014	0.014	OFF	OFF	OFF	OFF	0.015
9	OFF	OFF	OFF	0.014	OFF	OFF	0.016
10	OFF	OFF	OFF	0.016	0.015	0.014	0.029
11	0.014	0.014	0.014	0.014	0.014	0.014	0.015
12	0.014	0.014	0.014	0.014	OFF	0.014	0.015
13	OFF	OFF	0.014	0.015	0.014	OFF	0.015
14	0.014	0.014	OFF	OFF	0.015	0.014	0.016
15	0.014	0.014	0.014	OFF	0.014	0.014	0.017
16	0.014	0.014	OFF	OFF	OFF	OFF	0.016
17	OFF	0.014	0.014	OFF	OFF	OFF	0.016
18	OFF	0.014	OFF	0.014	OFF	0.014	0.016
19	0.014	0.014	0.014	0.014	0.014	0.014	0.015
20	OFF	0.014	OFF	OFF	0.014	OFF	0.015
21	0.014	OFF	OFF	OFF	OFF	OFF	0.016
22	OFF	OFF	OFF	0.014	OFF	OFF	0.018
23	OFF	OFF	0.014	0.014	0.014	0.015	0.015
24	OFF	OFF	0.015	OFF	OFF	OFF	0.015
25	0.014	0.015	0.014	0.014	OFF	0.014	0.016
26	0.014	OFF	OFF	0.014	OFF	0.015	0.021
27	0.014	0.014	0.015	OFF	0.014	0.014	0.016
28	0.014	OFF	0.014	0.015	0.015	0.014	0.016
29	0.014	0.014	OFF	0.015	0.015	OFF	0.015
30	OFF	0.015	0.015	OFF	OFF	OFF	0.016

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?
		<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes:	PRINTED NAME : David L. Nordman	
	SIGNATURE: <i>[Signature]</i>	DATE: 12/9/2022
	PHONE #: (503) 842-6462	CERT #: 08918

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of      ID#: 41 00585      Month/Year: Nov-22      Disinfection Giardia Log Inactiv:      1.000

Date / Time	Minimum Cl2 Residual at 1st User	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.620	142.00	88.0	12.3	7.66	40.0	YES	300
2	0.620	142.00	88.0	11.5	7.54	40.5	YES	300
3	0.580	142.00	82.4	11.5	7.50	39.7	YES	300
4	0.620	142.00	88.0	11.6	7.39	38.2	YES	300
5	0.620	142.00	88.0	11.9	7.34	36.8	YES	300
6	0.540	142.00	76.7	11.6	7.37	37.6	YES	300
7	0.620	142.00	88.0	10.0	7.39	42.4	YES	300
8	0.650	142.00	92.3	10.9	7.35	39.5	YES	300
9	0.670	142.00	95.1	10.4	7.31	40.4	YES	300
10	0.710	142.00	100.8	11.1	7.26	38.1	YES	300
11	0.670	142.00	95.1	10.3	7.41	42.1	YES	300
12	0.720	142.00	102.2	10.5	7.39	41.5	YES	300
13	0.640	142.00	90.9	10.2	7.60	45.1	YES	300
14	0.770	142.00	109.3	9.9	7.57	46.2	YES	300
15	0.720	142.00	102.2	10.3	7.63	45.7	YES	300
16	0.720	142.00	102.2	10.1	7.41	42.9	YES	300
17	0.620	142.00	88.0	11.2	7.55	41.4	YES	300
18	0.670	142.00	95.1	9.8	7.63	47.0	YES	300
19	0.750	142.00	106.5	10.4	7.57	44.6	YES	300
20	0.770	142.00	109.3	9.6	7.52	46.3	YES	300
21	0.790	142.00	112.2	9.9	7.55	46.0	YES	300
22	0.710	142.00	100.8	11.0	7.52	41.9	YES	300
23	0.760	142.00	107.9	10.1	7.50	44.4	YES	300
24	0.740	142.00	105.1	9.8	7.49	45.1	YES	300
25	0.850	142.00	120.7	10.4	7.77	48.4	YES	300
26	0.860	142.00	122.1	10.7	7.49	43.0	YES	300
27	0.790	142.00	112.2	10.3	7.53	44.5	YES	300
28	0.820	142.00	116.4	9.8	7.55	46.5	YES	300
29	0.740	142.00	105.1	9.7	7.54	46.2	YES	300
30	0.710	142.00	100.8	9.5	7.57	47.1	YES	300

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013