

OHA - Drinking Water Services - Turbidity Monitoring Report Form


County:	Tillamook
Month/Year:	Feb-23

Membrane

System Name: Oceanside, City of ID#: 41 00585 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	0.014	0.029
2	0.014	0.014	0.014	OFF	OFF	OFF	0.015
3	OFF	OFF	OFF	OFF	OFF	OFF	0.015
4	OFF	OFF	0.015	0.014	0.014	0.014	0.016
5	OFF	OFF	OFF	OFF	0.014	0.014	0.016
6	0.014	0.014	OFF	0.015	OFF	OFF	0.016
7	OFF	OFF	OFF	OFF	OFF	0.014	0.017
8	0.014	OFF	0.014	OFF	OFF	OFF	0.017
9	OFF	OFF	OFF	0.015	OFF	OFF	0.019
10	OFF	0.014	0.014	0.014	0.014	OFF	0.015
11	OFF	OFF	OFF	OFF	0.014	OFF	0.017
12	OFF	OFF	OFF	0.015	OFF	0.014	0.016
13	0.014	0.014	0.014	0.015	0.015	0.015	0.015
14	OFF	OFF	OFF	OFF	OFF	OFF	0.016
15	0.014	0.014	OFF	OFF	OFF	OFF	0.016
16	0.014	0.014	0.015	OFF	0.015	0.015	0.016
17	OFF	OFF	OFF	OFF	OFF	OFF	0.016
18	0.014	0.014	OFF	OFF	OFF	OFF	0.016
19	0.015	0.015	0.015	OFF	0.015	0.015	0.016
20	0.014	OFF	OFF	OFF	OFF	0.014	0.016
21	0.015	0.015	0.015	OFF	0.015	OFF	0.016
22	OFF	OFF	0.016	0.016	OFF	0.015	0.016
23	OFF	OFF	OFF	OFF	OFF	OFF	0.016
24	0.014	0.014	OFF	0.015	0.014	0.014	0.015
25	0.014	OFF	0.014	0.015	OFF	0.014	0.015
26	0.014	0.014	0.014	OFF	OFF	0.015	0.015
27	0.014	0.014	0.015	0.015	0.015	0.014	0.015
28	0.014	OFF	OFF	OFF	OFF	OFF	0.016

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All daily turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: 	DATE: 3/8/2023
	PHONE #: (503) 842-6462	CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Feb-23 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.830	142.00	117.9	9.9	7.44	44.4	YES	300
32	1.000	142.00	142.0	11.1	7.33	40.3	YES	300
3	0.920	142.00	130.6	11.3	7.40	40.4	YES	300
4	0.940	142.00	133.5	9.9	7.68	49.0	YES	300
5	0.920	142.00	130.6	9.9	7.43	44.7	YES	300
6	0.840	142.00	119.3	11.1	7.56	42.9	YES	300
7	0.860	142.00	122.1	11.0	7.30	39.5	YES	300
8	0.830	142.00	117.9	9.3	7.35	44.8	YES	300
9	0.760	142.00	107.9	10.0	7.56	45.7	YES	300
10	0.970	142.00	137.7	10.7	7.56	44.7	YES	300
11	0.830	142.00	117.9	11.5	7.37	39.0	YES	300
12	0.790	142.00	112.2	16.7	7.40	27.5	YES	300
13	0.850	142.00	120.7	11.5	7.53	41.4	YES	300
14	0.870	142.00	123.5	9.7	7.64	48.6	YES	300
15	0.820	142.00	116.4	9.5	7.55	47.4	YES	300
16	0.950	142.00	134.9	9.5	7.70	50.7	YES	300
17	0.860	142.00	122.1	9.3	7.86	53.9	YES	300
18	0.860	142.00	122.1	9.3	7.78	52.4	YES	300
19	0.830	142.00	117.9	9.7	7.39	44.2	YES	300
20	0.810	142.00	115.0	9.2	7.46	46.8	YES	300
21	0.750	142.00	106.5	9.0	7.64	50.2	YES	300
22	0.810	142.00	115.0	8.5	7.47	49.2	YES	300
23	0.790	142.00	112.2	8.7	7.54	49.6	YES	300
24	0.820	142.00	116.4	8.8	7.50	48.8	YES	300
25	0.870	142.00	123.5	8.9	7.44	47.7	YES	300
26	0.870	142.00	123.5	9.1	7.51	48.3	YES	300
27	0.820	142.00	116.4	8.4	7.72	54.2	YES	300
28	0.830	142.00	117.9	8.2	7.70	54.6	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013