

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Mar-23

Membrane

System Name: Oceanside, City of ID#: 41 00585 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	0.015	0.015	OFF	OFF	0.017
2	0.014	0.014	0.014	OFF	0.015	0.014	0.016
3	0.014	OFF	OFF	OFF	OFF	0.015	0.030
4	0.015	0.015	OFF	OFF	OFF	OFF	0.017
5	OFF	0.014	0.015	0.015	0.015	0.015	0.015
6	OFF	OFF	OFF	OFF	OFF	OFF	0.016
7	OFF	0.014	OFF	OFF	OFF	0.015	0.017
8	0.014	0.014	0.014	0.015	0.015	OFF	0.016
9	OFF	OFF	OFF	OFF	0.014	OFF	0.017
10	OFF	OFF	OFF	OFF	0.014	0.014	0.026
11	0.014	0.014	0.014	OFF	OFF	OFF	0.016
12	OFF	0.014	OFF	OFF	OFF	OFF	0.016
13	OFF	0.014	0.015	0.015	0.015	0.014	0.015
14	0.014	OFF	OFF	OFF	OFF	OFF	0.017
15	0.014	OFF	OFF	OFF	0.015	0.014	0.016
16	0.014	0.014	0.014	0.015	OFF	OFF	0.017
17	OFF	OFF	OFF	OFF	OFF	OFF	0.018
18	OFF	OFF	OFF	0.015	0.014	0.014	0.016
19	OFF	0.014	0.014	0.015	0.015	0.014	0.015
20	OFF	OFF	OFF	OFF	OFF	0.014	0.018
21	OFF	OFF	OFF	OFF	0.015	0.015	0.018
22	OFF	0.014	0.014	OFF	OFF	OFF	0.017
23	OFF	OFF	OFF	0.015	0.015	OFF	0.027
24	OFF	OFF	OFF	OFF	OFF	0.014	0.016
25	0.014	OFF	OFF	0.015	0.014	0.014	0.015
26	OFF	0.015	0.014	OFF	OFF	0.015	0.016
27	0.014	OFF	OFF	OFF	OFF	0.016	0.017
28	0.015	0.014	OFF	0.015	0.015	0.014	0.015
29	OFF	0.014	OFF	OFF	OFF	0.014	0.018
30	0.014	OFF	OFF	0.015	0.014	OFF	0.017
31	0.014	0.014	0.014	0.015	OFF	OFF	0.020

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All daily turbidity readings < 5 NTU? Yes / No		

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: <i>[Signature]</i>	DATE: 4/2/2023
	PHONE #: (503) 842-6462	CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Mar-23 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.890	142.00	126.4	7.8	7.84	59.4	YES	300
2	0.910	142.00	129.2	8.7	7.57	50.9	YES	300
3	0.830	142.00	117.9	8.9	7.67	51.5	YES	300
4	0.830	142.00	117.9	8.0	7.73	55.9	YES	300
5	0.800	142.00	113.6	8.3	7.40	48.6	YES	300
6	0.820	142.00	116.4	8.3	7.44	49.4	YES	300
7	0.830	142.00	117.9	10.5	7.39	42.0	YES	300
8	0.760	142.00	107.9	8.2	7.43	49.2	YES	300
9	0.810	142.00	115.0	8.4	7.53	50.6	YES	300
10	0.830	142.00	117.9	8.5	7.37	47.6	YES	300
11	0.990	142.00	140.6	9.2	7.69	51.8	YES	300
12	0.860	142.00	122.1	8.2	7.81	57.0	YES	300
13	0.800	142.00	113.6	9.5	7.62	48.5	YES	300
14	0.880	142.00	125.0	8.6	7.50	49.8	YES	300
15	0.850	142.00	120.7	8.5	7.58	51.4	YES	300
16	0.840	142.00	119.3	9.3	7.70	50.8	YES	300
17	0.890	142.00	126.4	9.6	7.65	49.2	YES	300
18	0.890	142.00	126.4	9.2	7.77	52.7	YES	300
19	0.880	142.00	125.0	10.0	7.96	53.4	YES	300
20	0.860	142.00	122.1	10.8	7.61	44.6	YES	300
21	0.850	142.00	120.7	11.1	7.58	43.2	YES	300
22	0.860	142.00	122.1	13.7	7.81	39.4	YES	300
23	0.880	142.00	125.0	12.2	7.78	43.3	YES	300
24	0.860	142.00	122.1	10.5	7.99	52.1	YES	300
25	0.870	142.00	123.5	8.8	7.46	48.4	YES	300
26	0.830	142.00	117.9	9.1	7.65	50.5	YES	300
27	0.810	142.00	115.0	8.7	7.67	52.1	YES	300
28	0.960	142.00	136.3	9.8	7.68	49.4	YES	300
29	0.880	142.00	125.0	9.7	7.47	45.8	YES	300
30	0.830	142.00	117.9	8.7	7.50	49.2	YES	300
31	0.860	142.00	122.1	9.0	7.65	51.0	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013