

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Aug-23

Membrane

System Name: Oceanside, City of	ID#: 41 00585	WTP : A
---------------------------------	---------------	---------

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.011	0.011	OFF	0.019	0.013	0.011	0.021
2	0.014	0.013	0.011	0.012	OFF	0.012	0.019
3	0.011	0.011	OFF	0.011	OFF	0.012	0.017
4	0.011	0.011	0.012	0.012	OFF	OFF	0.015
5	0.011	0.011	0.011	0.011	0.011	OFF	0.012
6	0.011	0.011	OFF	0.012	OFF	0.011	0.012
7	0.011	0.011	0.011	0.012	0.012	0.012	0.012
8	0.011	OFF	0.011	0.011	0.011	0.011	0.012
9	0.011	0.011	0.011	0.012	0.012	0.011	0.012
10	0.011	0.011	OFF	OFF	OFF	0.011	0.018
11	0.011	0.011	0.011	0.012	0.012	0.011	0.013
12	0.012	OFF	0.011	0.011	OFF	0.011	0.012
13	0.011	OFF	OFF	0.012	0.011	0.011	0.018
14	OFF	0.011	0.011	0.012	0.012	0.011	0.012
15	OFF	0.011	0.011	OFF	0.011	0.011	0.012
16	0.011	OFF	0.011	OFF	0.011	0.011	0.011
17	0.011	0.011	0.011	OFF	OFF	OFF	0.012
18	OFF	0.011	0.011	0.012	0.011	0.011	0.013
19	0.011	0.011	OFF	0.012	OFF	0.011	0.012
20	0.011	0.011	0.011	0.012	OFF	OFF	0.012
21	OFF	OFF	OFF	0.012	0.011	0.011	0.012
22	OFF	OFF	OFF	0.012	0.011	0.011	0.013
23	0.011	0.011	0.011	0.011	0.011	OFF	0.012
24	OFF	OFF	OFF	0.011	0.011	0.011	0.013
25	0.011	0.011	0.011	0.011	0.011	0.011	0.012
26	0.011	0.011	0.011	OFF	0.012	0.011	0.015
27	0.011	0.011	OFF	0.011	0.011	0.011	0.013
28	0.011	0.011	OFF	0.012	0.012	OFF	0.012
29	OFF	0.011	OFF	0.012	0.011	0.011	0.012
30	0.011	0.011	0.011	OFF	OFF	0.011	0.012
31	0.011	0.011	0.011	OFF	OFF	0.011	0.012

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All daily turbidity readings < 5 NTU? Yes / No		

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: 	DATE: 9/7/2023
	PHONE #: (503) 842-6462	CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Aug-23 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.790	142.00	112.2	17.6	8.03	32.8	YES	300
2	0.680	142.00	96.6	17.4	7.51	27.0	YES	300
3	0.770	142.00	109.3	16.7	7.50	28.5	YES	300
4	0.710	142.00	100.8	17.0	7.58	28.6	YES	300
5	0.820	142.00	116.4	19.3	7.65	25.5	YES	300
6	0.810	142.00	115.0	18.1	7.59	27.0	YES	300
7	0.630	142.00	89.5	19.3	7.59	24.4	YES	300
8	0.700	142.00	99.4	18.5	7.64	26.4	YES	300
9	0.640	142.00	90.9	17.9	7.66	27.5	YES	300
10	0.600	142.00	85.2	17.6	7.70	28.4	YES	300
11	0.650	142.00	92.3	17.8	7.42	25.4	YES	300
12	0.650	142.00	92.3	18.0	7.48	25.6	YES	300
13	0.610	142.00	86.6	25.2	7.75	17.3	YES	300
14	0.580	142.00	82.4	23.4	7.87	20.4	YES	300
15	0.650	142.00	92.3	19.0	8.02	29.3	YES	300
16	0.500	142.00	71.0	18.0	7.51	25.4	YES	300
17	0.530	142.00	75.3	18.4	7.58	25.5	YES	300
18	0.550	142.00	78.1	18.8	7.77	26.7	YES	300
19	0.560	142.00	79.5	18.0	7.81	28.6	YES	300
20	0.570	142.00	80.9	17.0	7.82	30.8	YES	300
21	0.590	142.00	83.8	16.7	7.85	31.8	YES	300
22	0.590	142.00	83.8	16.7	7.81	31.3	YES	300
23	0.600	142.00	85.2	16.8	7.87	31.9	YES	300
24	0.590	142.00	83.8	16.4	7.93	33.4	YES	300
25	0.660	142.00	93.7	16.7	7.69	30.2	YES	300
26	0.720	142.00	102.2	15.8	7.69	32.3	YES	300
27	0.620	142.00	88.0	16.5	7.64	29.9	YES	300
28	0.610	142.00	86.6	16.7	7.72	30.4	YES	300
29	0.600	142.00	85.2	16.6	7.74	30.8	YES	300
30	0.620	142.00	88.0	16.6	7.73	30.7	YES	300
31	0.640	142.00	90.9	16.6	7.64	29.8	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013