

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Dec-23

Membrane

System Name: Oceanside, City of ID#: 41 00585 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.012	0.012	0.012	0.012	0.012	0.012	0.012
2	0.012	0.012	OFF	OFF	OFF	OFF	0.014
3	OFF	OFF	0.012	OFF	OFF	OFF	0.015
4	OFF	OFF	0.011	0.012	0.012	OFF	0.016
5	OFF	OFF	OFF	0.012	0.012	0.011	0.015
6	0.012	0.011	0.011	OFF	OFF	OFF	0.015
7	OFF	OFF	OFF	0.012	OFF	0.012	0.013
8	OFF	OFF	OFF	OFF	OFF	OFF	0.020
9	0.012	0.012	OFF	OFF	OFF	0.012	0.013
10	0.012	OFF	0.012	OFF	0.012	0.012	0.012
11	0.011	OFF	OFF	OFF	OFF	OFF	0.018
12	0.011	0.012	OFF	OFF	OFF	OFF	0.014
13	OFF	OFF	0.012	OFF	OFF	0.012	0.018
14	OFF	OFF	0.012	0.012	0.012	0.011	0.013
15	0.011	0.012	0.012	OFF	OFF	0.014	0.012
16	OFF	OFF	OFF	0.017	0.014	OFF	0.017
17	OFF	OFF	OFF	OFF	0.015	0.014	0.015
18	OFF	OFF	OFF	OFF	0.014	0.014	0.014
19	0.014	0.014	0.014	OFF	OFF	OFF	0.014
20	OFF	OFF	OFF	OFF	0.015	OFF	0.015
21	0.014	OFF	OFF	OFF	OFF	OFF	0.014
22	OFF	0.014	OFF	OFF	OFF	OFF	0.014
23	0.014	OFF	0.015	OFF	0.014	0.014	0.015
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	0.015	0.014	OFF	OFF	OFF	OFF	0.015
26	0.014	0.015	OFF	OFF	OFF	OFF	0.015
27	OFF	0.014	0.014	0.015	OFF	OFF	0.015
28	OFF	OFF	OFF	OFF	0.015	0.015	0.015
29	0.014	0.014	OFF	OFF	OFF	OFF	0.014
30	0.014	0.015	0.014	0.015	0.014	0.014	0.015
31	0.014	0.014	OFF	OFF	OFF	OFF	0.014

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All daily turbidity readings < 5 NTU? Yes / No		

Notes: PRINTED NAME: David L. Nordman
 SIGNATURE: *[Signature]* DATE: 1/9/2024
 PHONE #: (503) 842-6462 CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of	ID#: 41 00585	Month/Year: Dec-23	Disinfection Giardia Log Inactiv:	1.000
---------------------------------	---------------	--------------------	-----------------------------------	-------

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.620	142.00	88.0	10.8	7.72	45.1	YES	300
2	0.530	142.00	75.3	10.7	7.55	42.4	YES	300
3	0.650	142.00	92.3	10.9	7.79	46.1	YES	300
4	0.610	142.00	86.6	11.6	7.66	41.9	YES	300
5	0.570	142.00	80.9	11.3	7.67	42.7	YES	300
6	0.550	142.00	78.1	11.6	7.57	40.3	YES	300
7	0.500	142.00	71.0	11.5	7.61	40.9	YES	300
8	0.520	142.00	73.8	11.6	7.73	42.5	YES	300
9	0.480	142.00	68.2	11.1	7.61	41.9	YES	300
10	0.650	142.00	92.3	11.4	7.63	42.2	YES	300
11	0.680	142.00	96.6	11.4	7.48	40.2	YES	300
12	0.670	142.00	95.1	11.7	7.53	40.0	YES	300
13	0.580	142.00	82.4	10.8	7.76	45.6	YES	300
14	0.650	142.00	92.3	12.6	7.47	36.6	YES	300
15	0.670	142.00	95.1	11.3	7.58	41.8	YES	300
16	0.740	142.00	105.1	11.4	7.60	42.2	YES	300
17	0.720	142.00	102.2	11.1	7.58	42.6	YES	300
18	0.700	142.00	99.4	11.7	7.59	41.0	YES	300
19	0.770	142.00	109.3	12.3	7.43	37.6	YES	300
20	0.680	142.00	96.6	11.6	7.66	42.2	YES	300
21	0.700	142.00	99.4	11.7	7.48	39.5	YES	300
22	0.680	142.00	96.6	11.9	7.57	40.1	YES	300
23	0.770	142.00	109.3	11.6	7.56	41.2	YES	300
24	0.740	142.00	105.1	10.9	7.62	43.9	YES	300
25	0.730	142.00	103.7	12.0	7.45	38.4	YES	300
26	0.770	142.00	109.3	10.9	7.71	45.4	YES	300
27	0.910	142.00	129.2	11.6	7.68	43.6	YES	300
28	0.630	142.00	89.5	11.6	7.47	39.3	YES	300
29	0.740	142.00	105.1	11.5	7.53	40.9	YES	300
30	0.670	142.00	95.1	12.2	7.58	39.4	YES	300
31	0.750	142.00	106.5	11.3	7.72	44.3	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013