

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Jan-24

Membrane

System Name: Oceanside, City of ID#: 41 00585 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.018	0.014	OFF	OFF	0.015	0.016	0.018
2	0.014	0.014	0.014	0.016	OFF	OFF	0.016
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	0.016	0.014	OFF	OFF	OFF	OFF	0.016
5	OFF	OFF	OFF	0.014	0.015	0.015	0.015
6	OFF	0.015	0.015	OFF	OFF	OFF	0.015
7	OFF	OFF	OFF	OFF	OFF	0.014	0.014
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	OFF	0.014	0.014	0.014
11	0.018	0.015	0.014	OFF	OFF	OFF	0.018
12	OFF	OFF	OFF	OFF	0.016	OFF	0.016
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	0.013	OFF	0.014	0.014
15	0.014	0.014	0.014	0.015	OFF	OFF	0.014
16	OFF	OFF	OFF	OFF	OFF	0.014	0.014
17	0.016	0.014	0.016	0.016	OFF	OFF	0.016
18	OFF	0.014	OFF	OFF	OFF	OFF	0.015
19	OFF	OFF	OFF	OFF	0.015	0.014	0.017
20	OFF	OFF	OFF	OFF	0.014	0.014	0.015
21	0.014	OFF	OFF	OFF	OFF	OFF	0.015
22	OFF	OFF	OFF	OFF	OFF	OFF	0.017
23	OFF	OFF	OFF	0.015	0.015	0.014	0.021
24	0.014	0.014	0.014	OFF	0.015	0.014	0.020
25	0.014	OFF	OFF	OFF	OFF	OFF	0.015
26	OFF	OFF	OFF	OFF	OFF	OFF	0.028
27	OFF	0.014	OFF	OFF	OFF	OFF	0.016
28	OFF	OFF	OFF	0.015	0.015	OFF	0.021
29	0.014	0.014	0.014	0.015	OFF	OFF	0.015
30	OFF	OFF	OFF	0.015	OFF	OFF	0.016
31	OFF	OFF	OFF	OFF	OFF	OFF	0.016

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All daily turbidity readings < 5 NTU? Yes / No		

Notes:	PRINTED NAME: David Nordman	
	SIGNATURE: <i>[Signature]</i>	DATE: 2/9/2024
	PHONE #: (503) 842-6462	CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Jan-24 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.700	142.00	99.4	11.1	7.64	43.4	YES	300
2	0.800	142.00	113.6	11.6	7.51	40.6	YES	300
3	0.690	142.00	98.0	10.8	7.61	43.8	YES	300
4	0.690	142.00	98.0	11.1	7.44	40.4	YES	300
5	0.720	142.00	102.2	11.4	7.55	41.3	YES	300
6	0.770	142.00	109.3	10.8	7.56	43.4	YES	300
7	0.750	142.00	106.5	10.8	7.42	41.2	YES	300
8	0.720	142.00	102.2	10.6	7.52	43.1	YES	300
9	0.700	142.00	99.4	12.0	7.63	40.8	YES	300
10	0.690	142.00	98.0	11.6	7.48	39.7	YES	300
11	0.740	142.00	105.1	10.4	7.52	43.8	YES	300
12	0.740	142.00	105.1	10.1	7.59	45.8	YES	300
13	0.750	142.00	106.5	10.5	7.73	46.9	YES	300
14	0.720	142.00	102.2	8.3	7.63	52.2	YES	300
15	0.640	142.00	90.9	8.0	7.59	52.0	YES	300
16	0.730	142.00	103.7	9.1	7.84	53.4	YES	300
17	0.750	142.00	106.5	9.2	7.57	48.3	YES	300
18	0.780	142.00	110.8	9.1	7.62	49.7	YES	300
19	0.770	142.00	109.3	9.7	7.61	47.5	YES	300
20	0.900	142.00	127.8	9.4	7.67	50.2	YES	300
21	0.780	142.00	110.8	9.7	7.68	48.7	YES	300
22	0.750	142.00	106.5	9.9	7.41	43.6	YES	300
23	0.780	142.00	110.8	10.1	7.39	42.9	YES	300
24	0.820	142.00	116.4	11.2	7.48	41.3	YES	300
25	0.880	142.00	125.0	10.4	7.46	43.5	YES	300
26	0.760	142.00	107.9	10.9	7.48	41.9	YES	300
27	0.880	142.00	125.0	10.5	7.62	45.8	YES	300
28	0.860	142.00	122.1	11.4	7.53	41.7	YES	300
29	1.100	142.00	156.2	12.1	7.74	44.0	YES	300
30	0.860	142.00	122.1	11.4	7.48	41.0	YES	300
31	0.770	142.00	109.3	12.1	7.62	40.7	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013