

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: **Oceanside Water District**

County: **Tillamook**

PWS ID#: 41 - **00585**

Month/Year: **May, 2025**

Plant ID: WTP - **A**

Minimum test pressure applied: **20** psi

Minimum test pressure req'd: **18** psi

(e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

**DIT
Daily**

PDR_{Max} [psi/min]

LRC [log removal]

0.900

4.00

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU]	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.014	0.178	0.178	0.033	4.467	Y
2	0.013	0.017	0.017	0.033	4.645	Y
3	0.013	0.018	0.018	0.025	4.811	Y
4	0.013	0.018	0.018	0.025	4.782	Y
5	0.013	0.015	0.015	0.027	4.674	Y
6	0.013	0.020	0.020	0.027	4.725	Y
7	0.013	0.015	0.015	0.027	4.731	Y
8	0.015	0.015	0.015	0.029	4.627	Y
9	0.013	0.019	0.019	0.029	4.642	Y
10	0.013	0.016	0.016	0.029	4.637	Y
11	0.013	0.016	0.016	0.031	4.570	Y
12	0.013	0.017	0.017	0.031	4.648	Y
13	0.014	0.015	0.015	0.025	4.671	Y
14	0.013	0.018	0.018	0.024	4.735	Y
15	0.013	0.015	0.015	0.035	4.385	Y
16	0.013	0.016	0.016	0.035	4.417	Y
17	0.013	0.016	0.016	0.034	4.414	Y
18	0.013	0.015	0.015	0.025	4.678	Y
19	0.014	0.016	0.016	0.035	4.486	Y
20	0.014	0.018	0.018	0.035	4.436	Y
21	0.013	0.019	0.019	0.031	4.498	Y
22	0.018	0.025	0.025	0.021	4.839	Y
23	0.014	0.024	0.024	0.016	5.413	Y
24	0.013	0.018	0.018	0.025	4.833	Y
25	0.013	0.016	0.016	0.028	4.625	Y
26	0.013	0.015	0.015	0.028	4.639	Y
27	0.013	0.016	0.016	0.028	4.666	Y
28	0.013	0.017	0.017	0.028	4.628	Y
29	0.014	0.016	0.016	0.022	4.852	Y
30	0.013	0.023	0.023	0.028	4.647	Y
31	0.013	0.016	0.016	0.029	4.591	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N] Yes	All turbidity readings ≤ 5 NTU? [Y/N] Yes	All IFE turbidity readings ≤ 0.15 NTU? [Y/N] Yes	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC) Yes	DIT Daily? Yes
CT's met daily? (p. 2) Yes	All Cl ₂ residual at EP ≥ 0.2 mg/L? Yes	PDR ≤ PDR _{Max} ? Yes	LRV _{ambient} ≥ LRC? Yes	

PRINTED NAME: **Christian Anderson**

DATE: **06/01/2025**

SIGNATURE: 

WT CERT #:

T-650708

Notes:

PHONE #:

503-842-6462

Disinfection Monthly Operating ReportSystem Name: **Oceanside Water District**PWS ID#: 41 - **00585**Plant ID : WTP - **A****0.5**Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.470	142	66.7	12.6	7.77	20.0	YES	300	
2	0.490	142	69.6	13.0	7.77	19.5	YES	300	
3	0.450	142	63.9	14.0	7.75	18.1	YES	300	
4	0.510	142	72.4	13.7	7.92	19.7	YES	300	
5	0.480	142	68.2	14.4	7.84	18.2	YES	300	
6	0.530	142	75.3	15.6	7.84	16.9	YES	300	
7	0.540	142	76.7	14.1	7.70	17.8	YES	300	
8	0.590	142	83.8	13.8	7.68	18.1	YES	300	
9	0.540	142	76.7	13.8	7.57	17.3	YES	300	
10	0.530	142	75.3	13.8	7.65	17.8	YES	300	
11	0.520	142	73.8	14.2	7.63	17.2	YES	300	
12	0.520	142	73.8	14.6	7.65	16.9	YES	300	
13	0.480	142	68.2	13.5	7.72	18.5	YES	300	
14	0.530	142	75.3	14.5	7.52	16.2	YES	300	
15	0.470	142	66.7	14.0	7.77	18.2	YES	300	
16	0.500	142	71.0	14.4	7.58	16.6	YES	300	
17	0.480	142	68.2	14.1	7.65	17.3	YES	300	
18	0.470	142	66.7	13.8	7.66	17.7	YES	300	
19	0.430	142	61.1	14.6	7.74	17.2	YES	300	
20	0.520	142	73.8	16.0	7.55	14.8	YES	300	
21	0.470	142	66.7	14.7	7.62	16.5	YES	300	
22	0.440	142	62.5	13.5	7.72	18.4	YES	300	
23	0.500	142	71.0	13.8	7.70	18.1	YES	300	
24	0.470	142	66.7	14.4	7.61	16.7	YES	300	
25	0.530	142	75.3	14.4	7.82	18.2	YES	300	
26	0.520	142	73.8	17.8	7.66	13.7	YES	300	
27	0.500	142	71.0	16.4	7.81	15.8	YES	300	
28	0.510	142	72.4	15.6	7.35	14.1	YES	300	
29	0.500	142	71.0	16.0	7.39	13.9	YES	300	
30	0.450	142	63.9	15.0	7.64	16.2	YES	300	
31	0.520	142	73.8	14.9	7.61	16.3	YES	300	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2