

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: **Oceanside Water District**

County: **Tillamook**

PWS ID#: 41 - **00585**

Month/Year: **August, 2025**

Plant ID: WTP - **A**
(e.g., "A")

Minimum test pressure applied: **20** psi

Minimum test pressure req'd: **18** psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇨

PDR = Pressure Decay Rate

LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU]	PDR _{Max} [psi/min]	LRC [log removal]	DIT Daily
				0.900	4.00	
				Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.015	0.025	0.025	0.039	4.301	Y
2	0.015	0.016	0.016	0.039	4.496	Y
3	0.015	0.023	0.023	0.026	4.751	Y
4	0.015	0.039	0.039	0.039	4.391	Y
5	0.016	0.023	0.023	0.039	4.433	Y
6	0.015	0.027	0.027	0.033	4.533	Y
7	0.015	0.023	0.023	0.034	4.346	Y
8	0.015	0.021	0.021	0.034	4.399	Y
9	0.015	0.017	0.017	0.045	4.131	Y
10	0.015	0.023	0.023	0.055	4.158	Y
11	0.015	0.016	0.016	0.055	4.167	Y
12	0.015	0.021	0.021	0.046	4.263	Y
13	0.015	0.025	0.025	0.029	4.529	Y
14	0.015	0.020	0.020	0.038	4.347	Y
15	0.015	0.033	0.033	0.047	4.047	Y
16	0.015	0.035	0.035	0.047	4.045	Y
17	0.015	0.017	0.017	0.047	4.199	Y
18	0.015	0.017	0.017	0.040	4.284	Y
19	0.015	0.025	0.025	0.048	4.172	Y
20	0.015	0.020	0.020	0.048	4.180	Y
21	0.014	0.029	0.029	0.046	4.192	Y
22	0.015	0.027	0.027	0.046	4.175	Y
23	0.015	0.023	0.023	0.048	4.144	Y
24	0.015	0.019	0.019	0.048	4.221	Y
25	0.015	0.020	0.020	0.047	4.115	Y
26	0.015	0.033	0.033	0.047	4.101	Y
27	0.015	0.022	0.022	0.040	4.180	Y
28	0.015	0.037	0.037	0.040	4.362	Y
29	0.015	0.016	0.016	0.040	4.389	Y
30	0.015	0.043	0.043	0.037	4.376	Y
31	0.015	0.027	0.027	0.036	4.360	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: **Christian Anderson**

SIGNATURE: 

Notes:

DATE: **9/3/2025**

WT CERT #: **T-650708**

PHONE #: **503-842-6462**

Disinfection Monthly Operating ReportSystem Name: **Oceanside Water District**PWS ID#: 41 - **00585****0.5**Log
Inactivation
Required via
DisinfectionPlant ID : WTP - **A**

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.560	142	79.5	15.6	7.61	15.6	YES	300	
2	0.550	142	78.1	16.9	7.55	14.0	YES	300	
3	0.500	142	71.0	16.4	7.56	14.4	YES	300	
4	0.480	142	68.2	15.9	7.57	14.9	YES	300	
5	0.540	142	76.7	16.0	7.57	14.9	YES	300	
6	0.490	142	69.6	16.1	7.59	14.9	YES	300	
7	0.440	142	62.5	17.0	7.53	13.6	YES	300	
8	0.460	142	65.3	15.7	7.66	15.6	YES	300	
9	0.470	142	66.7	16.6	7.57	14.2	YES	300	
10	0.480	142	68.2	16.2	7.55	14.5	YES	300	
11	0.490	142	69.6	16.4	7.46	13.9	YES	300	
12	0.420	142	59.6	16.9	7.54	13.7	YES	300	
13	0.420	142	59.6	16.9	7.54	13.7	YES	300	
14	0.430	142	61.1	17.5	7.50	13.0	YES	300	
15	0.460	142	65.3	17.1	7.46	13.2	YES	300	
16	0.390	142	55.4	16.9	7.63	14.1	YES	300	
17	0.360	142	51.1	16.4	7.49	13.8	YES	300	
18	0.390	142	55.4	16.8	7.60	14.1	YES	300	
19	0.360	142	51.1	17.0	7.64	14.0	YES	300	
20	0.420	142	59.6	16.8	7.53	13.8	YES	300	
21	0.490	142	69.6	16.3	7.54	14.4	YES	300	
22	0.580	142	82.4	16.6	7.59	14.5	YES	300	
23	0.580	142	82.4	16.6	7.59	14.5	YES	300	
24	0.560	142	79.5	17.2	7.58	13.9	YES	300	
25	0.500	142	71.0	17.2	7.64	14.1	YES	300	
26	0.470	142	66.7	16.6	7.65	14.7	YES	300	
27	0.440	142	62.5	17.3	7.65	13.9	YES	300	
28	0.460	142	65.3	16.2	7.62	14.9	YES	300	
29	0.500	142	71.0	15.7	7.62	15.5	YES	300	
30	0.670	142	95.1	16.2	7.52	14.7	YES	300	
31	0.410	142	58.2	15.9	7.55	14.7	YES	300	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458