


OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Apr-21

Membrane

System Name: Oceanside, City of ID#: 41 00585 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.057	0.057	OFF	0.057	OFF	OFF	0.076
2	OFF	OFF	OFF	0.057	OFF	0.057	0.075
3	0.058	OFF	OFF	0.059	0.059	OFF	0.076
4	OFF	OFF	0.057	0.058	OFF	OFF	0.076
5	0.057	0.058	OFF	0.059	0.061	0.060	0.076
6	OFF	OFF	OFF	OFF	0.059	0.060	0.074
7	OFF	OFF	OFF	0.054	0.059	0.059	0.077
8	0.059	OFF	OFF	OFF	OFF	OFF	0.076
9	OFF	0.060	OFF	OFF	0.060	0.061	0.078
10	0.060	0.061	OFF	OFF	OFF	0.061	0.079
11	0.061	OFF	OFF	OFF	0.062	0.062	0.080
12	0.060	OFF	OFF	OFF	OFF	OFF	0.079
13	0.060	OFF	OFF	OFF	OFF	0.062	0.081
14	0.062	0.061	OFF	OFF	OFF	OFF	0.079
15	0.060	OFF	OFF	OFF	0.063	OFF	0.078
16	0.060	0.061	OFF	OFF	OFF	0.059	0.079
17	0.060	0.059	0.058	OFF	OFF	OFF	0.080
18	0.061	OFF	0.061	0.062	0.063	0.063	0.078
19	OFF	OFF	OFF	OFF	0.061	0.061	0.061
20	0.061	0.061	OFF	OFF	OFF	OFF	0.077
21	OFF	OFF	0.058	0.060	0.061	0.060	0.073
22	0.061	OFF	OFF	OFF	OFF	OFF	0.077
23	0.053	OFF	OFF	0.055	0.054	0.055	0.069
24	0.055	OFF	OFF	OFF	OFF	OFF	0.070
25	0.054	0.056	OFF	0.055	OFF	0.057	0.071
26	OFF	OFF	OFF	OFF	OFF	OFF	0.054
27	0.054	0.055	0.053	0.057	0.056	0.057	0.070
28	OFF	OFF	OFF	OFF	0.057	OFF	0.072
29	OFF	0.056	0.058	OFF	OFF	OFF	0.075
30	OFF	OFF	OFF	0.056	0.057	0.057	0.067

<b>Membrane</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
<b>Notes:</b>		<b>PRINTED NAME: David Nordman</b>	
		<b>SIGNATURE:</b> 	<b>DATE:</b> 5/4/2021
		<b>PHONE #:</b> (503) 842-6462	<b>CERT #:</b> T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of

ID#: 41 00585

Month/Year: Apr-21

Disinfection Giardia  
Log Inactiv:

1.000

Date / Time	Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.180	142.00	167.6	10.0	7.70	50.4	YES	300
2	1.090	142.00	154.8	10.0	7.93	54.1	YES	300
3	1.220	142.00	173.2	10.6	7.61	47.1	YES	300
4	1.200	142.00	170.4	10.7	7.58	46.2	YES	300
5	1.160	142.00	164.7	10.5	7.60	46.9	YES	300
6	1.140	142.00	161.9	10.0	7.64	49.1	YES	300
7	1.080	142.00	153.4	10.6	7.89	51.2	YES	300
8	1.010	142.00	143.4	11.1	7.89	49.1	YES	300
9	1.170	142.00	166.1	10.4	7.87	52.0	YES	300
10	1.010	142.00	143.4	11.5	7.84	47.0	YES	300
11	1.000	142.00	142.0	11.3	7.81	47.1	YES	300
12	1.010	142.00	143.4	10.8	7.84	49.2	YES	300
13	1.060	142.00	150.5	10.6	7.80	49.5	YES	300
14	1.090	142.00	154.8	10.1	7.88	52.8	YES	300
15	1.110	142.00	157.6	12.3	7.67	42.5	YES	300
16	1.100	142.00	156.2	12.0	7.67	43.2	YES	300
17	1.200	142.00	170.4	12.3	7.76	44.3	YES	300
18	1.180	142.00	167.6	12.2	7.77	44.6	YES	300
19	1.110	142.00	157.6	12.3	7.70	42.9	YES	300
20	1.060	142.00	150.5	12.4	7.68	42.1	YES	300
21	1.120	142.00	159.0	12.5	7.63	41.2	YES	300
22	1.190	142.00	169.0	13.1	7.86	43.4	YES	300
23	1.090	142.00	154.8	12.6	7.47	38.4	YES	300
24	1.080	142.00	153.4	12.5	7.73	42.5	YES	300
25	1.060	142.00	150.5	12.4	7.70	42.4	YES	300
26	1.100	142.00	156.2	12.3	7.65	42.1	YES	300
27	1.010	142.00	143.4	12.2	7.59	41.1	YES	300
28	0.960	142.00	136.3	12.2	7.54	40.2	YES	300
29	1.000	142.00	142.0	12.6	7.46	37.9	YES	300
30	0.980	142.00	139.2	12.2	7.27	36.7	YES	300

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013