

OHA - Drinking Water Services - Turbidity Monitoring Report Form


County:	Tillamook
Month/Year:	Nov-21

Membrane

System Name: Oceanside, City of ID#: 41 00585 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.013	OFF	0.013	0.013	0.013	OFF	0.013
2	OFF	OFF	OFF	0.013	OFF	0.013	0.014
3	OFF	OFF	OFF	OFF	OFF	0.013	0.015
4	0.013	0.013	OFF	0.013	0.013	0.013	0.014
5	OFF	OFF	OFF	OFF	OFF	0.013	0.092
6	0.013	0.013	0.016	OFF	0.013	0.013	0.274
7	0.013	OFF	OFF	0.013	OFF	0.013	0.014
8	0.013	0.013	OFF	OFF	OFF	0.013	0.014
9	0.013	OFF	0.013	0.014	OFF	OFF	0.014
10	OFF	OFF	0.014	0.013	0.013	0.013	0.014
11	0.013	OFF	0.013	0.013	OFF	OFF	0.014
12	OFF	OFF	OFF	0.014	0.013	0.013	0.022
13	0.013	0.013	0.013	0.013	0.013	0.013	0.254
14	OFF	OFF	OFF	0.013	0.013	0.012	0.014
15	OFF	0.013	0.013	OFF	OFF	OFF	0.014
16	OFF	OFF	OFF	OFF	0.013	0.013	0.032
17	0.013	0.013	OFF	OFF	0.013	OFF	0.059
18	OFF	OFF	OFF	OFF	OFF	OFF	0.015
19	OFF	OFF	OFF	OFF	0.013	0.013	0.014
20	0.013	0.013	OFF	OFF	OFF	OFF	0.016
21	OFF	0.013	OFF	OFF	OFF	0.013	0.014
22	0.013	OFF	OFF	OFF	0.013	0.013	0.015
23	0.013	0.013	0.013	0.013	0.014	OFF	0.014
24	OFF	OFF	0.015	0.013	0.013	OFF	0.015
25	OFF	OFF	OFF	0.013	0.013	0.013	0.015
26	0.013	0.013	0.013	0.013	0.013	OFF	0.014
27	OFF	OFF	OFF	OFF	OFF	OFF	0.015
28	OFF	OFF	OFF	0.013	0.013	0.013	0.015
29	0.013	0.013	0.013	0.013	0.013	0.013	0.013
30	0.013	0.013	OFF	OFF	OFF	OFF	0.015

Membrane		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: 	DATE: 12/6/2021
	PHONE #: (503) 842-6462	CERT #: T-08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Nov-21 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.640	142.00	90.9	12.2	7.42	37.2	YES	300
2	0.260	142.00	36.9	12.2	7.39	35.3	YES	300
3	0.290	142.00	41.2	12.5	7.39	34.3	YES	300
4	0.350	142.00	49.7	12.4	7.33	34.5	YES	300
5	0.270	142.00	38.3	12.2	7.43	35.8	YES	300
6	0.360	142.00	51.1	12.1	7.42	36.3	YES	300
7	0.490	142.00	69.6	12.0	7.46	37.5	YES	300
8	0.500	142.00	71.0	11.8	7.40	37.3	YES	300
9	0.860	142.00	122.1	11.9	7.36	38.0	YES	300
10	1.100	142.00	156.2	11.6	7.49	41.7	YES	300
11	1.030	142.00	146.3	12.0	7.47	40.0	YES	300
12	0.880	142.00	125.0	12.4	7.31	36.3	YES	300
13	1.060	142.00	150.5	11.7	7.43	40.4	YES	300
14	1.100	142.00	156.2	11.9	7.30	38.3	YES	300
15	1.150	142.00	163.3	12.1	7.44	39.9	YES	300
16	0.980	142.00	139.2	11.8	7.51	40.9	YES	300
17	0.830	142.00	117.9	11.2	7.35	39.5	YES	300
18	0.900	142.00	127.8	11.7	7.34	38.4	YES	300
19	0.830	142.00	117.9	11.9	7.60	41.2	YES	300
20	1.000	142.00	142.0	11.8	7.46	40.3	YES	300
21	1.010	142.00	143.4	11.4	7.51	42.1	YES	300
22	1.060	142.00	150.5	11.1	7.30	40.1	YES	300
23	1.100	142.00	156.2	11.3	7.36	40.6	YES	300
24	1.070	142.00	151.9	10.8	7.56	44.9	YES	300
25	0.950	142.00	134.9	10.8	7.32	40.7	YES	300
26	0.950	142.00	134.9	10.8	7.47	42.9	YES	300
27	0.980	142.00	139.2	11.0	7.65	45.3	YES	300
28	0.960	142.00	136.3	11.1	7.64	44.7	YES	300
29	1.040	142.00	147.7	11.3	7.66	44.8	YES	300
30	1.090	142.00	154.8	11.4	7.55	43.1	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013