

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Dec-21

Membrane

System Name: Oceanside, City of ID#: 41 00585 WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	0.013	OFF	0.024
2	0.013	OFF	0.013	0.013	OFF	OFF	0.014
3	OFF	OFF	OFF	OFF	OFF	0.013	0.015
4	OFF	OFF	OFF	OFF	OFF	OFF	0.015
5	0.013	OFF	OFF	OFF	OFF	0.014	0.016
6	0.013	0.013	0.013	OFF	OFF	OFF	0.014
7	OFF	OFF	OFF	0.014	0.013	OFF	0.016
8	OFF	OFF	OFF	OFF	OFF	OFF	0.015
9	OFF	OFF	0.013	0.014	0.013	0.013	0.017
10	OFF	OFF	OFF	0.014	0.013	0.013	0.015
11	0.013	OFF	OFF	OFF	OFF	OFF	0.015
12	OFF	OFF	0.013	OFF	OFF	OFF	0.023
13	OFF	OFF	OFF	OFF	0.013	OFF	0.019
14	0.013	OFF	OFF	0.014	0.013	0.013	0.014
15	0.013	OFF	OFF	OFF	OFF	OFF	0.014
16	OFF	OFF	OFF	OFF	0.013	OFF	0.015
17	OFF	OFF	OFF	OFF	OFF	OFF	0.772
18	OFF	0.013	OFF	0.013	0.014	0.013	0.017
19	0.013	OFF	0.013	0.013	0.013	OFF	0.015
20	OFF	OFF	OFF	0.014	0.013	OFF	0.015
21	OFF	OFF	OFF	0.014	0.013	OFF	0.032
22	OFF	0.013	0.013	OFF	OFF	OFF	0.014
23	OFF	OFF	OFF	OFF	0.013	0.013	0.014
24	OFF	OFF	OFF	OFF	OFF	OFF	0.014
25	OFF	0.013	OFF	0.013	OFF	0.013	0.014
26	0.014	0.013	OFF	0.013	0.013	0.013	0.014
27	OFF	OFF	OFF	OFF	OFF	OFF	0.014
28	0.013	OFF	OFF	OFF	OFF	OFF	0.014
29	OFF	0.013	0.013	0.013	0.013	0.013	0.014
30	0.013	OFF	OFF	0.014	OFF	0.013	0.015
31	OFF	OFF	OFF	OFF	OFF	0.014	0.014

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes	<input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes	<input type="radio"/> No
All daily turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes	<input type="radio"/> No
	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
	<input checked="" type="radio"/> Yes	<input checked="" type="radio"/> Yes
	<input type="radio"/> No	<input type="radio"/> No

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: <i>David L. Nordman</i>	DATE: 1/6/2022
	PHONE #: (503) 842-6462	CERT #: T-08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Dec-21 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.950	142.00	134.9	11.7	7.62	42.6	YES	300
2	1.070	142.00	151.9	12.1	7.61	41.9	YES	300
3	0.960	142.00	136.3	10.9	7.61	44.8	YES	300
4	0.940	142.00	133.5	11.3	7.44	41.0	YES	300
5	0.920	142.00	130.6	10.8	7.49	43.1	YES	300
6	0.990	142.00	140.6	10.6	7.56	45.1	YES	300
7	1.000	142.00	142.0	10.4	7.52	45.1	YES	300
8	0.830	142.00	117.9	11.0	7.31	39.5	YES	300
9	0.920	142.00	130.6	10.3	7.46	44.0	YES	300
10	0.850	142.00	120.7	10.5	7.65	46.1	YES	300
11	0.840	142.00	119.3	10.4	7.63	46.0	YES	300
12	0.790	142.00	112.2	10.2	7.58	45.6	YES	300
13	0.810	142.00	115.0	10.0	7.50	45.0	YES	300
14	0.940	142.00	133.5	9.8	7.40	44.7	YES	300
15	0.990	142.00	140.6	9.7	7.42	45.5	YES	300
16	0.880	142.00	125.0	9.0	7.79	53.7	YES	300
17	0.890	142.00	126.4	8.6	7.61	51.8	YES	300
18	0.830	142.00	117.9	9.0	7.59	49.7	YES	300
19	0.810	142.00	115.0	9.8	7.64	47.9	YES	300
20	0.910	142.00	129.2	9.0	7.64	51.1	YES	300
21	0.950	142.00	134.9	8.8	7.69	53.0	YES	300
22	0.970	142.00	137.7	9.3	7.35	45.5	YES	300
23	0.990	142.00	140.6	9.7	7.66	49.6	YES	300
24	1.030	142.00	146.3	8.8	7.74	54.4	YES	300
25	1.110	142.00	157.6	8.6	7.78	56.5	YES	300
26	1.270	142.00	180.3	10.6	7.53	46.0	YES	300
27	1.130	142.00	160.5	8.3	7.59	54.0	YES	300
28	1.030	142.00	146.3	7.0	7.64	59.3	YES	300
29	1.080	142.00	153.4	7.7	7.61	56.3	YES	300
30	0.960	142.00	136.3	8.4	7.85	57.7	YES	300
31	1.050	142.00	149.1	7.7	7.43	52.6	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013