

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Feb-22

Membrane


System Name: Oceanside, City of

ID#: 41 00585

WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	0.014
2	OFF	OFF	OFF	0.014	0.013	0.013	0.015
3	0.013	0.013	OFF	OFF	OFF	OFF	0.014
4	OFF	OFF	OFF	OFF	0.013	0.013	0.015
5	OFF	OFF	OFF	OFF	OFF	OFF	0.017
6	0.013	OFF	OFF	0.014	0.013	0.013	0.014
7	0.013	OFF	OFF	OFF	OFF	OFF	0.016
8	OFF	OFF	OFF	OFF	0.013	OFF	0.015
9	OFF	OFF	OFF	OFF	OFF	OFF	0.019
10	OFF	OFF	OFF	0.014	OFF	0.013	0.022
11	0.013	0.013	0.013	OFF	OFF	OFF	0.016
12	OFF	OFF	OFF	0.013	0.013	OFF	0.019
13	OFF	OFF	OFF	0.014	0.013	OFF	0.015
14	OFF	OFF	OFF	OFF	0.013	0.013	0.014
15	OFF	0.013	OFF	OFF	OFF	OFF	0.014
16	OFF	OFF	OFF	0.014	0.014	OFF	0.015
17	OFF	OFF	OFF	OFF	0.013	OFF	0.017
18	0.013	0.013	OFF	OFF	OFF	OFF	0.014
19	OFF	0.013	0.013	0.013	0.013	OFF	0.013
20	OFF	OFF	OFF	OFF	0.013	0.013	0.014
21	OFF	OFF	OFF	OFF	OFF	OFF	0.014
22	0.013	OFF	0.014	OFF	OFF	OFF	0.016
23	OFF	OFF	OFF	OFF	OFF	OFF	0.017
24	OFF	OFF	OFF	OFF	OFF	0.013	0.023
25	0.013	0.013	OFF	0.013	0.013	0.013	0.014
26	0.013	0.013	OFF	OFF	OFF	OFF	0.014
27	OFF	OFF	0.014	0.014	OFF	OFF	0.015
28	OFF	OFF	OFF	OFF	OFF	OFF	0.015
29							
30							
31							

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes:	PRINTED NAME: David Nordman	
	SIGNATURE: 	DATE: 3/2/2022
	PHONE #: (503) 842-6462	CERT #: T-08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))



# OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A  
Disinfection Giardia Log Inactiv: 1.000

System Name: Oceanside, City of      ID#: 41 00585      Month/Year: Feb-22

Date / Time	Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.880	80.00	70.4	9.5	7.91	54.2	YES	300
2	0.880	80.00	70.4	9.5	7.59	48.4	YES	300
3	0.880	80.00	70.4	9.8	7.60	47.6	YES	300
4	0.840	80.00	67.2	9.3	7.48	47.0	YES	300
5	0.800	80.00	64.0	9.5	7.35	44.1	YES	300
6	0.740	80.00	59.2	9.6	7.42	44.6	YES	300
7	0.940	80.00	75.2	10.9	7.43	42.0	YES	300
8	0.710	80.00	56.8	9.9	7.47	44.3	YES	300
9	0.650	80.00	52.0	11.7	7.65	41.6	YES	300
10	0.590	80.00	47.2	10.9	7.52	41.7	YES	300
11	0.820	80.00	65.6	9.7	7.41	44.5	YES	300
12	0.910	80.00	72.8	9.4	7.33	44.6	YES	300
13	0.790	80.00	63.2	11.5	7.52	41.0	YES	300
14	0.680	80.00	54.4	10.6	7.61	44.3	YES	300
15	0.970	80.00	77.6	10.0	7.41	44.4	YES	300
16	0.920	80.00	73.6	10.4	7.41	43.0	YES	300
17	0.910	80.00	72.8	10.1	7.45	44.4	YES	300
18	0.920	80.00	73.6	9.7	7.53	47.0	YES	300
19	1.050	80.00	84.0	10.2	7.40	44.0	YES	300
20	0.960	80.00	76.8	9.9	7.47	45.6	YES	300
21	0.910	80.00	72.8	9.4	7.69	50.7	YES	300
22	0.770	80.00	61.6	8.6	7.61	51.1	YES	300
23	0.970	80.00	77.6	9.9	7.42	44.8	YES	300
24	0.920	80.00	73.6	8.3	7.74	55.6	YES	300
25	1.190	80.00	95.2	5.9	7.66	65.6	YES	300
26	1.020	80.00	81.6	8.6	7.47	50.0	YES	300
27	1.130	80.00	90.4	7.9	7.36	51.1	YES	300
28	0.900	80.00	72.0	10.1	7.40	43.6	YES	300

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013