

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	May-22

Membrane


System Name: Oceanside, City of

ID#: 41 00585

WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.013	0.012	OFF	OFF	OFF	0.012	0.013
2	OFF	OFF	OFF	OFF	OFF	OFF	0.013
3	OFF	OFF	0.013	OFF	OFF	OFF	0.065
4	OFF	OFF	OFF	0.013	0.013	0.013	0.014
5	OFF	OFF	OFF	OFF	OFF	OFF	0.013
6	OFF	OFF	OFF	0.013	0.013	OFF	0.021
7	OFF	OFF	OFF	OFF	0.012	0.012	0.015
8	OFF	OFF	OFF	OFF	0.012	0.012	0.014
9	0.012	0.012	OFF	OFF	OFF	OFF	0.013
10	OFF	OFF	OFF	0.013	OFF	0.012	0.014
11	OFF	OFF	OFF	OFF	0.022	OFF	0.083
12	0.013	0.015	OFF	OFF	OFF	OFF	0.030
13	OFF	OFF	OFF	0.013	OFF	OFF	0.026
14	OFF	OFF	OFF	OFF	0.014	0.013	0.018
15	OFF	OFF	0.014	OFF	0.012	0.012	0.014
16	0.012	OFF	OFF	OFF	OFF	OFF	0.018
17	OFF	0.012	OFF	OFF	OFF	OFF	0.020
18	OFF	OFF	0.012	0.013	0.012	0.012	0.017
19	OFF	OFF	OFF	OFF	OFF	OFF	0.016
20	0.017	0.012	OFF	OFF	OFF	OFF	0.017
21	OFF	OFF	OFF	0.012	0.013	OFF	0.015
22	0.012	0.012	0.012	OFF	OFF	OFF	0.014
23	OFF	0.012	OFF	OFF	OFF	OFF	0.015
24	0.012	OFF	OFF	OFF	OFF	OFF	0.014
25	OFF	OFF	OFF	0.012	0.012	0.012	0.015
26	0.012	OFF	OFF	OFF	OFF	OFF	0.014
27	OFF	OFF	OFF	OFF	OFF	OFF	0.014
28	OFF	OFF	OFF	0.013	0.012	0.012	0.014
29	OFF	0.012	OFF	OFF	OFF	OFF	0.014
30	0.012	OFF	OFF	OFF	OFF	0.012	0.015
31	0.012	0.012	OFF	OFF	OFF	0.012	0.014

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: 	DATE: 6/5/2022
	PHONE #: (503) 842-6462	CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of

ID#: 41 00585

Month/Year: May-22

Disinfection Giardia
Log Inactiv:

1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.710	80.00	56.8	12.8	7.57	37.7	YES	300
2	0.780	80.00	62.4	10.9	7.61	43.9	YES	300
3	0.720	80.00	57.6	10.8	7.61	43.9	YES	300
4	0.670	80.00	53.6	10.8	7.53	42.5	YES	300
5	0.710	80.00	56.8	10.8	7.46	41.6	YES	300
6	0.710	80.00	56.8	10.9	7.54	42.5	YES	300
7	0.670	80.00	53.6	10.8	7.51	42.2	YES	300
8	0.640	80.00	51.2	10.6	7.54	43.0	YES	300
9	0.670	80.00	53.6	10.7	7.54	42.9	YES	300
10	0.680	80.00	54.4	10.4	7.54	43.8	YES	300
11	0.610	80.00	48.8	10.7	7.56	42.9	YES	300
12	0.730	80.00	58.4	11.0	7.60	43.2	YES	300
13	0.690	80.00	55.2	10.7	7.49	42.2	YES	300
14	0.690	80.00	55.2	11.7	7.48	39.4	YES	300
15	0.590	80.00	47.2	11.7	7.47	38.8	YES	300
16	0.530	80.00	42.4	11.5	7.35	37.5	YES	300
17	0.610	80.00	48.8	11.7	7.44	38.5	YES	300
18	0.590	80.00	47.2	11.5	7.47	39.4	YES	300
19	0.620	80.00	49.6	11.4	7.38	38.5	YES	300
20	0.690	80.00	55.2	12.0	7.56	39.7	YES	300
21	0.640	80.00	51.2	11.6	7.64	41.7	YES	300
22	0.680	80.00	54.4	11.8	7.68	41.9	YES	300
23	0.790	80.00	63.2	11.9	7.68	42.2	YES	300
24	0.680	80.00	54.4	12.0	7.75	42.4	YES	300
25	0.710	80.00	56.8	12.6	7.62	38.9	YES	300
26	0.810	80.00	64.8	12.8	7.69	39.8	YES	300
27	0.800	80.00	64.0	12.2	7.64	40.8	YES	300
28	0.750	80.00	60.0	12.7	7.49	37.0	YES	300
29	0.550	80.00	44.0	12.8	7.63	37.8	YES	300
30	0.600	80.00	48.0	12.0	7.47	38.1	YES	300
31	0.630	80.00	50.4	12.2	7.38	36.6	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013