

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Jun-22

Membrane


System Name: Oceanside, City of

ID#: 41 00585

WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	0.018
2	OFF	OFF	OFF	0.012	0.013	OFF	0.016
3	OFF	OFF	OFF	OFF	OFF	OFF	0.036
4	OFF	OFF	OFF	0.019	OFF	OFF	0.381
5	OFF	OFF	OFF	0.013	0.013	OFF	0.015
6	OFF	0.013	0.013	0.013	OFF	OFF	0.014
7	OFF	0.012	0.012	0.012	OFF	OFF	0.015
8	OFF	OFF	OFF	0.013	0.012	0.012	0.014
9	OFF	OFF	OFF	OFF	OFF	0.012	0.020
10	OFF	OFF	OFF	OFF	OFF	0.022	0.023
11	0.012	0.014	0.012	OFF	OFF	OFF	0.020
12	0.017	OFF	OFF	OFF	0.012	OFF	0.143
13	OFF	OFF	OFF	OFF	OFF	OFF	0.016
14	OFF	0.013	OFF	OFF	OFF	OFF	0.017
15	OFF	OFF	OFF	OFF	0.013	OFF	0.016
16	OFF	OFF	OFF	0.012	OFF	0.012	0.017
17	0.012	0.012	OFF	OFF	OFF	0.012	0.020
18	OFF	OFF	OFF	OFF	0.012	OFF	0.017
19	OFF	OFF	0.012	OFF	0.012	0.012	0.019
20	0.012	OFF	OFF	OFF	0.012	OFF	0.019
21	OFF	OFF	OFF	0.012	OFF	OFF	0.015
22	OFF	0.013	0.013	0.012	0.012	OFF	0.020
23	OFF	OFF	OFF	OFF	0.012	OFF	0.018
24	OFF	OFF	OFF	0.012	0.012	0.012	0.018
25	0.012	OFF	OFF	OFF	OFF	OFF	0.016
26	0.012	0.012	0.012	0.012	0.015	OFF	0.020
27	OFF	0.012	OFF	0.012	0.014	0.013	0.020
28	OFF	OFF	OFF	OFF	OFF	0.012	0.017
29	0.012	OFF	OFF	OFF	0.015	0.012	0.017
30	0.015	0.013	0.012	OFF	OFF	0.012	0.019

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <b>Yes</b> / No	CT's met everyday? (see back) <b>Yes</b> / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b> / No
All 4-hour turbidity readings ≤ 1 NTU? <b>Yes</b> / No		
All daily turbidity readings < 5 NTU? <b>Yes</b> / No		

Notes:	PRINTED NAME: David J. Nordman	
	SIGNATURE: 	DATE: 7/5/2022
	PHONE #: (503) 842-6462	CERT #: T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of      ID#: 41 00585      Month/Year: Jun-22      Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.550	142.00	78.1	12.4	7.52	37.6	YES	300
2	0.520	142.00	73.8	13.0	7.64	37.3	YES	300
3	0.460	142.00	65.3	12.8	7.52	36.0	YES	300
4	0.520	142.00	73.8	13.0	7.59	36.7	YES	300
5	0.440	142.00	62.5	12.3	7.66	39.2	YES	300
6	0.520	142.00	73.8	12.5	7.59	37.9	YES	300
7	0.490	142.00	69.6	13.0	7.58	36.4	YES	300
8	0.420	142.00	59.6	13.6	7.62	35.2	YES	300
9	0.460	142.00	65.3	13.4	7.62	35.9	YES	300
10	0.440	142.00	62.5	13.2	7.38	33.2	YES	300
11	0.380	142.00	54.0	13.2	7.38	33.0	YES	300
12	0.400	142.00	56.8	14.9	7.33	28.9	YES	300
13	0.490	142.00	69.6	13.4	7.38	32.9	YES	300
14	0.440	142.00	62.5	13.3	7.38	33.0	YES	300
15	0.470	142.00	66.7	13.0	7.40	34.0	YES	300
16	0.470	142.00	66.7	13.0	7.42	34.2	YES	300
17	0.590	142.00	83.8	13.0	7.50	35.7	YES	300
18	0.440	142.00	62.5	13.0	7.53	35.5	YES	300
19	0.550	142.00	78.1	13.4	7.53	35.0	YES	300
20	0.690	142.00	98.0	13.3	7.45	34.8	YES	300
21	0.620	142.00	88.0	13.4	7.50	34.9	YES	300
22	0.620	142.00	88.0	13.4	7.53	35.3	YES	300
23	0.700	142.00	99.4	13.5	7.51	35.1	YES	300
24	0.770	142.00	109.3	14.4	7.46	32.8	YES	300
25	0.830	142.00	117.9	15.0	7.64	33.9	YES	300
26	0.770	142.00	109.3	14.7	7.68	34.8	YES	300
27	0.820	142.00	116.4	14.6	7.66	35.0	YES	300
28	0.870	142.00	123.5	15.0	7.70	34.8	YES	300
29	0.850	142.00	120.7	14.9	7.55	33.1	YES	300
30	0.900	142.00	127.8	14.5	7.57	34.4	YES	300

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013