

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Sep-22

Membrane

System Name: Oceanside, City of

ID#: 41 00585

WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	OFF	0.012	0.013	0.022
2	0.012	0.012	0.012	OFF	0.012	OFF	0.022
3	OFF	OFF	OFF	0.014	0.013	0.013	0.025
4	0.012	0.012	OFF	OFF	0.012	OFF	0.022
5	OFF	0.013	0.012	0.012	0.015	OFF	0.020
6	OFF	OFF	OFF	0.012	0.012	0.012	0.019
7	0.012	0.012	OFF	OFF	0.012	OFF	0.019
8	OFF	OFF	OFF	0.013	0.012	0.012	0.021
9	0.013	0.012	OFF	0.015	0.013	0.012	0.020
10	0.012	0.012	OFF	0.014	OFF	0.012	0.024
11	0.012	OFF	0.013	0.012	0.012	0.013	0.024
12	0.012	OFF	OFF	OFF	OFF	0.012	0.017
13	OFF	OFF	0.012	OFF	0.012	OFF	0.018
14	OFF	OFF	OFF	0.012	0.012	OFF	0.016
15	OFF	OFF	OFF	0.012	0.012	0.012	0.018
16	0.012	0.012	OFF	OFF	OFF	0.012	0.015
17	OFF	OFF	OFF	0.012	0.012	OFF	0.014
18	0.012	0.012	OFF	OFF	0.013	0.012	0.013
19	OFF	OFF	0.012	OFF	0.012	0.012	0.014
20	0.012	OFF	OFF	0.012	0.012	OFF	0.014
21	OFF	0.012	OFF	0.012	0.012	OFF	0.013
22	OFF	OFF	OFF	OFF	0.012	OFF	0.019
23	OFF	0.012	0.012	0.012	0.012	0.012	0.013
24	0.012	OFF	OFF	OFF	OFF	0.012	0.015
25	0.012	0.012	0.012	0.012	0.012	0.012	0.012
26	OFF	OFF	OFF	OFF	0.012	0.012	0.018
27	0.012	OFF	0.012	0.012	OFF	OFF	0.014
28	OFF	OFF	OFF	OFF	0.012	OFF	0.018
29	OFF	OFF	OFF	0.012	0.012	0.012	0.014
30	0.012	OFF	OFF	OFF	OFF	OFF	0.013
31							

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings < 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: <i>[Signature]</i>	DATE: 10/4/2022
	PHONE #: (503) 842-6462	CERT #: T08918

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))



OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of

ID#: 41 00585

Month/Year: Sep-22

Disinfection Giardia  
Log Inactiv:

1.000

Date / Time	Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.580	142.00	82.4	16.7	7.58	28.7	YES	300
2	0.630	142.00	89.5	15.9	7.40	28.5	YES	300
3	0.640	142.00	90.9	15.6	7.43	29.5	YES	300
4	0.620	142.00	88.0	15.8	7.47	29.4	YES	300
5	0.630	142.00	89.5	15.5	7.44	29.7	YES	300
6	0.600	142.00	85.2	15.4	7.48	30.3	YES	300
7	0.630	142.00	89.5	15.4	7.54	31.1	YES	300
8	0.670	142.00	95.1	15.4	7.50	30.7	YES	300
9	0.520	142.00	73.8	16.8	7.54	27.9	YES	300
10	0.330	142.00	46.9	16.9	7.49	26.7	YES	300
11	0.300	142.00	42.6	16.4	7.49	27.5	YES	300
12	0.320	142.00	45.4	16.4	7.49	27.5	YES	300
13	0.430	142.00	61.1	16.4	7.46	27.6	YES	300
14	0.740	142.00	105.1	15.3	7.37	29.7	YES	300
15	0.320	142.00	45.4	16.2	7.47	27.7	YES	300
16	0.600	142.00	85.2	15.5	7.37	28.9	YES	300
17	0.550	142.00	78.1	15.5	7.42	29.2	YES	300
18	0.640	142.00	90.9	15.2	7.44	30.4	YES	300
19	0.560	142.00	79.5	15.8	7.45	29.0	YES	300
20	0.700	142.00	99.4	15.0	7.54	32.2	YES	300
21	0.710	142.00	100.8	15.1	7.51	31.6	YES	300
22	0.670	142.00	95.1	15.3	7.55	31.5	YES	300
23	0.910	142.00	129.2	18.7	7.50	25.3	YES	300
24	0.740	142.00	105.1	15.3	7.52	31.4	YES	300
25	0.650	142.00	92.3	15.0	7.57	32.3	YES	300
26	0.610	142.00	86.6	15.1	7.53	31.5	YES	300
27	0.700	142.00	99.4	15.3	7.45	30.5	YES	300
28	0.640	142.00	90.9	15.4	7.56	31.3	YES	300
29	0.450	142.00	63.9	15.2	7.56	31.1	YES	300
30	0.680	142.00	96.6	15.1	7.42	30.5	YES	300

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013