

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	May-23


Membrane

System Name: Oceanside, City of

ID#: 41 00585

WTP : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.014	0.014	OFF	0.015	0.014	0.014	0.015
2	OFF	OFF	OFF	OFF	0.015	0.014	0.017
3	OFF	OFF	OFF	OFF	OFF	0.015	0.066
4	0.014	OFF	OFF	OFF	OFF	OFF	0.017
5	0.014	0.014	OFF	0.014	0.014	0.014	0.015
6	OFF	0.014	OFF	OFF	OFF	OFF	0.015
7	0.014	OFF	OFF	OFF	OFF	0.014	0.017
8	0.014	OFF	0.014	0.015	0.014	0.014	0.015
9	OFF	OFF	OFF	OFF	OFF	OFF	0.017
10	0.014	OFF	OFF	OFF	OFF	OFF	0.016
11	0.014	OFF	0.014	0.015	0.014	OFF	0.016
12	OFF	OFF	OFF	OFF	0.014	0.014	0.018
13	0.014	OFF	OFF	0.015	0.014	OFF	0.016
14	OFF	OFF	OFF	0.014	0.013	0.013	0.016
15	0.014	0.014	OFF	0.014	0.014	0.014	0.015
16	0.014	0.014	OFF	0.014	0.014	0.014	0.015
17	0.014	0.014	OFF	0.014	0.014	OFF	0.015
18	OFF	OFF	OFF	0.014	0.014	OFF	0.017
19	OFF	OFF	0.014	0.015	0.014	0.014	0.015
20	OFF	0.014	OFF	OFF	OFF	0.014	0.016
21	0.014	OFF	OFF	OFF	OFF	0.014	0.015
22	0.014	0.014	0.014	0.014	OFF	OFF	0.015
23	OFF	OFF	OFF	0.015	0.014	OFF	0.016
24	OFF	OFF	OFF	OFF	0.014	0.014	0.015
25	0.014	OFF	OFF	OFF	OFF	OFF	0.217
26	OFF	OFF	OFF	0.013	0.012	0.012	0.018
27	0.012	OFF	0.012	OFF	OFF	OFF	0.013
28	0.012	OFF	OFF	OFF	OFF	0.012	0.013
29	0.012	0.012	OFF	0.013	OFF	OFF	0.013
30	OFF	OFF	OFF	0.013	OFF	0.012	0.013
31	0.012	0.012	0.012	OFF	OFF	OFF	0.013

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All daily turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: 	DATE:
	PHONE #: (503) 842-6462	CERT #: 08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: May-23 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.760	142.00	107.9	11.9	7.57	40.5	YES	300
2	0.760	142.00	107.9	11.9	7.56	40.3	YES	300
3	0.720	142.00	102.2	11.7	7.65	42.0	YES	300
4	0.700	142.00	99.4	11.8	7.61	41.0	YES	300
5	0.610	142.00	86.6	11.4	7.53	40.5	YES	300
6	0.630	142.00	89.5	11.4	7.53	40.6	YES	300
7	0.600	142.00	85.2	11.5	7.55	40.5	YES	300
8	0.540	142.00	76.7	12.3	7.50	37.5	YES	300
9	0.560	142.00	79.5	11.7	7.50	39.1	YES	300
10	0.590	142.00	83.8	12.5	7.42	35.9	YES	300
11	0.580	142.00	82.4	12.9	7.47	35.6	YES	300
12	0.700	142.00	99.4	17.5	7.51	26.9	YES	300
13	0.730	142.00	103.7	13.2	7.55	36.5	YES	300
14	0.670	142.00	95.1	14.6	7.50	32.4	YES	300
15	0.700	142.00	99.4	15.1	7.62	32.9	YES	300
16	0.840	142.00	119.3	14.5	7.45	32.7	YES	300
17	1.070	142.00	151.9	15.5	7.46	31.5	YES	300
18	0.950	142.00	134.9	13.2	7.45	36.1	YES	300
19	0.760	142.00	107.9	15.6	7.47	30.3	YES	300
20	0.710	142.00	100.8	14.6	7.30	30.3	YES	300
21	0.650	142.00	92.3	14.0	7.48	33.4	YES	300
22	0.700	142.00	99.4	14.2	7.53	33.8	YES	300
23	0.660	142.00	93.7	14.0	7.60	35.0	YES	300
24	0.660	142.00	93.7	13.5	7.54	35.4	YES	300
25	0.660	142.00	93.7	13.5	7.67	37.1	YES	300
26	0.800	142.00	113.6	13.0	7.62	38.3	YES	300
27	0.740	142.00	105.1	13.9	7.69	36.7	YES	300
28	0.720	142.00	102.2	15.4	7.73	33.7	YES	300
29	0.740	142.00	105.1	13.7	7.65	36.7	YES	300
30	0.680	142.00	96.6	14.2	7.67	35.5	YES	300
31	0.770	142.00	109.3	13.3	7.69	38.4	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013