

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County:	Tillamook
Month/Year:	Nov-23

Membrane

System Name: Oceanside, City of	ID#: 41 00585	WTP : A
---------------------------------	---------------	---------

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	0.012	0.012	0.012	0.012	0.012	0.012	0.012
2	OFF	0.012	OFF	OFF	OFF	0.012	0.017
3	0.012	OFF	OFF	0.012	OFF	0.012	0.013
4	0.012	0.013	0.013	0.013	0.012	0.012	0.021
5	0.012	0.012	0.012	0.012	0.012	0.012	0.014
6	OFF	OFF	0.014	OFF	0.013	0.012	0.026
7	0.012	0.012	OFF	OFF	0.012	0.012	0.020
8	0.013	0.012	0.012	0.012	0.013	0.012	0.013
9	0.012	OFF	OFF	0.012	OFF	OFF	0.014
10	0.014	0.012	0.012	0.012	OFF	0.011	0.014
11	0.011	0.011	0.011	OFF	0.012	0.011	0.012
12	OFF	0.011	0.012	0.012	OFF	0.011	0.014
13	0.012	0.012	0.012	OFF	0.012	0.012	0.012
14	OFF	0.012	0.012	OFF	OFF	0.011	0.012
15	0.012	0.011	OFF	OFF	OFF	0.013	0.118
16	0.012	0.012	0.012	0.012	OFF	OFF	0.016
17	OFF	OFF	OFF	0.026	OFF	0.012	0.027
18	OFF	OFF	OFF	0.012	0.012	0.012	0.018
19	0.012	0.012	0.012	0.012	0.012	OFF	0.013
20	OFF	OFF	OFF	OFF	0.012	0.012	0.020
21	OFF	OFF	OFF	OFF	OFF	OFF	0.017
22	0.012	0.012	0.012	0.012	0.012	0.011	0.013
23	0.012	0.012	OFF	OFF	0.012	0.012	0.013
24	0.012	OFF	OFF	OFF	OFF	0.012	0.014
25	0.012	0.012	OFF	0.012	0.012	0.012	0.012
26	0.012	0.012	OFF	0.012	OFF	OFF	0.012
27	0.012	0.012	0.012	0.012	0.012	0.012	0.012
28	OFF	OFF	0.012	OFF	OFF	OFF	0.012
29	0.012	0.012	OFF	OFF	OFF	OFF	0.013
30	OFF	OFF	OFF	0.012	0.012	OFF	0.016

Membrane	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All daily turbidity readings < 5 NTU? Yes / No		

Notes:	PRINTED NAME: David L. Nordman	
	SIGNATURE: 	DATE: 12/10/2023
	PHONE #: (503) 842-6462	CERT #: T08918

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: A

System Name: Oceanside, City of ID#: 41 00585 Month/Year: Nov-23 Disinfection Giardia Log Inactiv: 1.000

Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.610	142.00	86.6	12.6	7.46	36.3	YES	300
2	0.700	142.00	99.4	12.6	7.47	36.8	YES	300
3	0.550	142.00	78.1	13.3	7.48	34.6	YES	300
4	0.820	142.00	116.4	13.0	7.72	39.8	YES	300
5	0.470	142.00	66.7	13.4	7.74	37.5	YES	300
6	0.430	142.00	61.1	13.1	7.59	36.1	YES	300
7	0.400	142.00	56.8	13.5	7.76	37.3	YES	300
8	0.420	142.00	59.6	12.9	7.58	36.4	YES	300
9	0.460	142.00	65.3	12.1	7.65	39.7	YES	300
10	0.410	142.00	58.2	13.3	7.70	37.0	YES	300
111	0.820	142.00	116.4	13.8	7.66	36.9	YES	300
12	0.430	142.00	61.1	12.5	7.68	38.8	YES	300
13	0.460	142.00	65.3	12.4	7.54	37.5	YES	300
14	0.460	142.00	65.3	11.9	7.80	42.4	YES	300
15	0.560	142.00	79.5	12.1	7.69	40.7	YES	300
16	0.470	142.00	66.7	11.7	7.42	37.7	YES	300
17	0.480	142.00	68.2	11.6	7.57	40.0	YES	300
18	0.460	142.00	65.3	11.8	7.53	38.8	YES	300
19	0.580	142.00	82.4	11.4	7.55	40.7	YES	300
20	0.480	142.00	68.2	11.5	7.30	36.7	YES	300
21	0.450	142.00	63.9	12.1	7.45	37.0	YES	300
22	0.500	142.00	71.0	12.2	7.54	38.1	YES	300
23	0.540	142.00	76.7	11.9	7.51	38.7	YES	300
24	0.600	142.00	85.2	11.2	7.61	42.2	YES	300
25	0.630	142.00	89.5	11.1	7.62	42.8	YES	300
26	0.680	142.00	96.6	10.2	7.67	46.5	YES	300
27	0.690	142.00	98.0	11.0	7.56	42.4	YES	300
28	0.730	142.00	103.7	11.1	7.70	44.5	YES	300
29	0.680	142.00	96.6	11.2	7.67	43.5	YES	300
30	0.660	142.00	93.7	10.8	7.69	44.9	YES	300

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013