


OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Malheur**
 Month/Year: **May 22**

System Name:		City of Ontario			ID#: 4100587			WTP : TP -	Old Plant
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]		
1	0.09	0.09	0.09	0.14	0.21	0.10	0.21		
2	0.10	0.10	0.10	0.09	0.13	0.12	0.13		
3	plant off	plant off	0.16	0.08	0.11	0.10	0.16		
4	0.10	0.10	0.10	0.11	0.11	0.10	0.11		
5	0.10	0.09	0.09	0.09	0.10	0.09	0.10		
6	0.09	0.09	0.09	0.09	0.09	0.09	0.09		
7	0.09	0.10	0.10	0.11	0.11	0.10	0.11		
8	0.09	0.09	0.08	0.08	0.08	0.08	0.09		
9	0.08	0.08	0.08	0.11	0.10	0.09	0.11		
10	0.09	0.09	0.10	0.12	0.12	0.13	0.13		
11	0.12	0.11	0.12	0.09	0.08	0.08	0.12		
12	0.08	0.08	0.08	0.07	0.07	0.07	0.08		
13	0.07	0.07	0.07	0.11	0.11	0.10	0.11		
14	0.10	0.10	0.10	0.10	0.09	0.09	0.10		
15	0.09	0.09	0.09	0.08	0.12	0.11	0.12		
16	0.10	0.10	0.10	0.10	0.11	0.10	0.11		
17	0.10	0.09	0.09	0.14	0.13	0.12	0.14		
18	0.12	0.12	0.12	0.12	0.12	0.13	0.13		
19	0.12	0.12	0.11	0.11	0.11	0.12	0.12		
20	0.12	0.11	0.12	0.13	0.13	0.13	0.13		
21	0.12	0.13	0.12	0.13	0.13	0.11	0.13		
22	0.11	0.11	0.10	0.10	0.10	0.10	0.11		
23	0.10	0.10	0.10	0.09	0.09	0.08	0.10		
24	0.08	0.08	0.12	0.13	0.17	0.12	0.17		
25	0.12	0.12	0.12	0.11	0.13	0.13	0.13		
26	0.13	0.13	0.13	0.13	0.14	0.12	0.14		
27	0.17	0.16	0.15	0.15	0.14	0.14	0.17		
28	0.15	0.15	0.14	0.15	0.15	0.14	0.15		
29	0.15	0.15	0.15	0.14	0.22	0.19	0.22		
30	0.18	0.18	0.17	0.17	0.16	0.15	0.18		
31	0.17	0.19	0.19	0.19	0.16	0.17	0.19		

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:

PRINTED NAME: Casey Mordhorst/Robert Crites
 SIGNATURE: 
 PHONE #: (541)889-8011

DATE: 6-6-22
 CERT #: 629575

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

System Name: City of Ontario Water System ID#: 4100587	Month/Year: May-22	Disinfection Giardia Log Inactiv:	0.5
--	--------------------	-----------------------------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1224	0.96	72.1	69.2	15.9	7.72	16.7	Yes	4201
2/0955	1.08	71.4	77.2	15.9	7.69	16.7	Yes	4220
2/0955	0.98	73.6	72.1	15.2	7.70	17.4	Yes	4156
4/1014	0.82	70.1	57.4	15.6	7.73	16.8	Yes	4262
5/0806	0.85	67.7	57.5	16.1	7.70	16.1	Yes	4333
6/0834	1.04	69.9	72.7	16.5	7.77	16.5	Yes	4266
7/1052	1.13	72.4	81.8	15.9	7.80	17.5	Yes	4191
8/1130	1.07	66.9	71.6	16.4	7.65	15.9	Yes	4356
9/0815	1.11	69.6	77.3	15.1	7.68	17.6	Yes	4275
10/0919	1.06	67.3	71.3	14.7	7.67	17.9	Yes	4346
11/1258	1	71.1	71.1	14.5	7.74	18.5	Yes	4230
12/0748	1.02	73.0	74.5	14.3	7.72	18.7	Yes	4173
13/0954	0.95	67.6	64.2	15.2	7.80	18.0	Yes	4336
14/1036	0.99	66.2	65.6	15.8	7.78	17.2	Yes	4377
15/1211	0.93	73.6	68.5	17.5	7.75	15.1	Yes	4154
16/1001	0.79	68.8	54.4	18.4	7.85	14.5	Yes	4299
17/0822	1	66.3	66.3	18.3	7.83	14.9	Yes	4374
18/0950	1.03	38.8	39.9	18.8	7.86	14.6	Yes	5204
19/1217	0.86	69.7	59.9	18.5	7.85	14.5	Yes	4274
20/0800	0.94	67.7	63.6	16.6	7.77	16.2	Yes	4333
21/1212	0.93	65.0	60.5	16.9	7.83	16.2	Yes	4414
22/1132	1.24	66.7	82.7	17.7	7.84	16.0	Yes	4364
23/0823	0.98	72.0	70.6	17.1	7.86	16.2	Yes	4202
24/1030	1.05	73.6	77.2	17.6	7.84	15.7	Yes	4156
25/0927	0.9	73.5	66.1	18.6	7.82	14.4	Yes	4159
26/0824	0.97	69.6	67.5	20.0	7.86	13.4	Yes	4275
27/0935	0.87	72.8	63.3	20.2	7.92	13.3	Yes	4179
28/1042	0.8	62.8	50.3	19.9	7.88	13.3	Yes	4480
29/1144	0.96	65.7	63.1	18.9	7.90	14.6	Yes	4393
30/1117	0.91	32.6	29.7	17.5	7.85	15.6	Yes	5389
31/0822	1.15	65.1	74.9	16.6	7.74	16.4	Yes	4411

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Here is the City of Ontario Water Treatment Plant MOR for May 2022.

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message