

**OHA - Drinking Water Services -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: Malheur  
 Month/Year: May 22  
 WTP : TP - Westech

System Nam	City of Ontario			ID#: 4100587			Highest Reading of the Day <sup>1</sup>
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	[NTU]
1	0.06	0.05	0.05	0.05	0.05	0.12	0.12
2	0.08	0.07	0.07	0.06	0.06	0.06	0.08
3	plant off	plant off	0.07	0.16	0.06	0.05	0.16
4	0.05	0.05	0.05	0.08	0.07	0.07	0.08
5	0.06	0.06	0.05	0.11	0.06	0.08	0.11
6	0.08	0.12	0.08	0.07	0.07	0.07	0.12
7	0.06	0.05	0.06	0.06	0.05	0.12	0.12
8	0.08	0.07	0.07	0.05	0.05	0.05	0.08
9	0.05	0.05	0.05	0.19	0.09	0.08	0.19
10	0.07	0.07	0.06	0.08	0.05	0.05	0.08
11	0.06	0.06	0.10	0.07	0.08	0.07	0.10
12	0.05	0.05	0.06	0.06	0.07	0.06	0.07
13	0.09	0.08	0.07	0.07	0.05	0.06	0.09
14	0.06	0.07	0.06	0.12	0.09	0.08	0.12
15	0.08	0.08	0.07	0.06	0.06	0.06	0.08
16	0.07	0.12	0.09	0.09	0.08	0.07	0.12
17	0.07	0.15	0.09	0.08	0.08	0.07	0.15
18	0.07	plant off	0.10	0.14	0.07	0.15	0.15
19	0.08	0.10	0.09	0.07	0.09	0.08	0.10
20	0.06	0.06	0.10	0.08	0.08	0.07	0.10
21	0.05	0.06	0.09	0.07	0.07	0.09	0.09
22	0.10	0.08	0.10	0.09	0.10	0.09	0.10
23	0.09	0.09	0.11	0.09	0.09	0.08	0.11
24	0.09	0.09	0.12	0.08	0.08	0.09	0.12
25	0.10	0.06	plant off	0.08	0.08	0.09	0.10
26	0.07	0.05	0.05	0.06	0.10	0.08	0.10
27	0.08	0.09	0.07	0.05	0.11	0.08	0.11
28	0.08	0.08	0.07	0.09	0.06	0.06	0.09
29	0.09	0.09	0.10	0.10	plant off	plant off	0.10
30	plant off	plant off	0.13	0.10	0.09	0.09	0.13
31	plant off	plant off	plant off	plant off	plant off	plant off	plant off

System Name: City of Ontario Water System ID#: 4100587	Month/Year: May-22	Disinfection <i>Giardia</i> Log Inactiv: 0.5
--	--------------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1224	0.96	72.1	69.2	15.9	7.72	16.7	Yes	4201
2/0955	1.08	71.4	77.2	15.9	7.69	16.7	Yes	4220
2/0955	0.98	73.6	72.1	15.2	7.70	17.4	Yes	4156
4/1014	0.82	70.1	57.4	15.6	7.73	16.8	Yes	4262
5/0806	0.85	67.7	57.5	16.1	7.70	16.1	Yes	4333
6/0834	1.04	69.9	72.7	16.5	7.77	16.5	Yes	4266
7/1052	1.13	72.4	81.8	15.9	7.80	17.5	Yes	4191
8/1130	1.07	66.9	71.6	16.4	7.65	15.9	Yes	4356
9/0815	1.11	69.6	77.3	15.1	7.68	17.6	Yes	4275
10/0919	1.06	67.3	71.3	14.7	7.67	17.9	Yes	4346
11/1258	1	71.1	71.1	14.5	7.74	18.5	Yes	4230
12/0748	1.02	73.0	74.5	14.3	7.72	18.7	Yes	4173
13/0954	0.95	67.6	64.2	15.2	7.80	18.0	Yes	4336
14/1036	0.99	66.2	65.6	15.8	7.78	17.2	Yes	4377
15/1211	0.93	73.6	68.5	17.5	7.75	15.1	Yes	4154
16/1001	0.79	68.8	54.4	18.4	7.85	14.5	Yes	4299
17/0822	1	66.3	66.3	18.3	7.83	14.9	Yes	4374
18/0950	1.03	38.8	39.9	18.8	7.86	14.6	Yes	5204
19/1217	0.86	69.7	59.9	18.5	7.85	14.5	Yes	4274
20/0800	0.94	67.7	63.6	16.6	7.77	16.2	Yes	4333
21/1212	0.93	65.0	60.5	16.9	7.83	16.2	Yes	4414
22/1132	1.24	66.7	82.7	17.7	7.84	16.0	Yes	4364
23/0823	0.98	72.0	70.6	17.1	7.86	16.2	Yes	4202
24/1030	1.05	73.6	77.2	17.6	7.84	15.7	Yes	4156
25/0927	0.9	73.5	66.1	18.6	7.82	14.4	Yes	4159
26/0824	0.97	69.6	67.5	20.0	7.86	13.4	Yes	4275
27/0935	0.87	72.8	63.3	20.2	7.92	13.3	Yes	4179
28/1042	0.8	62.8	50.3	19.9	7.88	13.3	Yes	4480
29/1144	0.96	65.7	63.1	18.9	7.90	14.6	Yes	4393
30/1117	0.91	32.6	29.7	17.5	7.85	15.6	Yes	5389
31/0822	1.15	65.1	74.9	16.6	7.74	16.4	Yes	4411

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

Here is the City of Ontario Water Treatment Plant MOR for May 2022.

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message