

**OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration**

County:
Month/Year:

Malheur
Jan / 23

System Name: City of Ontario			ID#: 4100587			WTP : TP -		West Tech
Day	NTU @ 12 am	NTU @ 4 am	NTU @ 8 am	NTU @ 12 pm	NTU @ 4 pm	NTU @ 8 pm	NTU Highest Reading of the Day (1)	
01	0.05	0.07	0.04	0.02	0.04	0.09	0.19	
02	0.06	0.05	0.04	0.12	0.08	0.08	0.26	
03	0.05	0.08	0.04	0.04	0.10	0.08	0.29	
04	0.08	0.07	0.07	0.04	0.12	Plant off	0.24	
05	0.05	0.12	0.27	0.15	0.05	0.04	0.23	
06	0.04	0.11	0.05	0.05	0.05	0.07	0.22	
07	0.05	0.04	0.08	0.07	0.06	0.07	0.12	
08	0.13	0.08	0.04	0.07	0.03	0.27	0.27	
09	0.06	0.05	0.05	0.04	0.04	0.06	0.29	
10	0.05	0.04	0.04	0.04	0.08	0.08	0.29	
11	0.07	0.06	0.07	Plant off	0.06	0.05	0.29	
12	0.04	0.04	0.04	0.06	0.03	0.03	0.29	
13	0.03	0.04	0.08	0.05	Plant off	Plant off	0.29	
14	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	
15	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	
16	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	
17	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	
18	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	
19	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	
20	plant off	plant off	plant off	plant off	plant off	plant off	plant off	
21	plant off	plant off	plant off	Plant Off	Plant Off	Plant Off	Plant Off	
22	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	
23	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	
24	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	
25	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	
26	ant OffPlant C	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	
27	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	
28	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	
29	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	
30	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	Plant off	
31								

System Name:	City of Ontario Water System			ID#: 4100587	Month/Year:	Jan / 23	Disinfection Giardia Log Inactiv:	0.5
Date / Time	Minimum Cl2 Residual at 1st User / (C) [ppm or mg/L]	Contact Time (T [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? Yes / No	Peak Hourly Demand Flow [GPM]
01 / 12:04 PM	1.21	136.9	165.6	10.8	7.91	25.8	Yes	2,249
02 / 10:10 AM	1.25	128.4	160.5	11.1	7.88	25.1	Yes	2,506
03 / 02:35 PM	1.24	134.7	167.0	9.3	7.98	29.4	Yes	2,315
04 / 01:45 PM	1.16	113.6	131.8	10.3	7.94	26.8	Yes	2,950
05 / 09:18 AM	1.03	60.4	62.2	8.8	7.87	28.5	Yes	4,552
06 / 11:30 AM	1.23	70.3	86.5	11.6	7.88	24.3	Yes	4,256
07 / 10:53 AM	1.20	73.1	87.7	10.8	7.90	25.7	Yes	4,169
08 / 11:45 AM	1.20	74.7	89.6	10.6	7.81	25.2	Yes	4,123
09 / 10:26 AM	1.30	43.2	56.2	11.1	7.79	24.5	Yes	5,072
10 / 10:45 AM	1.34	46.8	62.7	10.7	7.78	25.2	Yes	4,962
11 / 12:04 PM	1.22	62.9	76.7	11.6	7.73	23.0	Yes	4,478
12 / 12:02 PM	1.20	53.8	64.6	11.8	7.76	22.9	Yes	4,752
13 / 12:08 PM	1.12	65.3	73.1	12.2	7.61	20.9	Yes	4,405
14 / 01:41 PM	1.00	115.5	115.5	10.6	7.78	24.4	Yes	2,894
15 / 01:36 PM	1.01	49.5	50.0	9.2	7.78	26.8	Yes	4,882
16 / 01:48 PM	1.09	54.0	58.9	9.7	7.66	25.1	Yes	4,745
17 / 12:32 PM	1.16	114.4	132.7	11.2	7.85	24.5	Yes	2,926
18 / 10:05 AM	1.13	88.1	99.6	9.6	7.80	26.7	Yes	3,717
19 / 10:33 AM	1.02	107.2	109.3	8.9	7.72	26.8	Yes	3,143
20 / 10:25 AM	1.02	57.6	58.8	9.1	7.75	26.7	Yes	4,637
21 / 11:01 AM	1.11	123.5	137.1	11.3	7.72	23.1	Yes	2,653
22 / 12:04 PM	1.06	69.0	73.1	10.0	7.75	25.3	Yes	4,293
23 / 10:19 AM	1.09	61.1	66.6	9.0	7.66	26.3	Yes	4,532
24 / 11:30 AM	1.13	120.2	135.8	9.1	7.85	28.1	Yes	2,753
25 / 01:25 PM	1.00	87.7	87.7	8.7	7.86	28.5	Yes	3,730
26 / 10:31 AM	1.10	100.3	110.3	10.9	7.70	23.5	Yes	3,351
27 / 10:47 AM	1.22	89.6	109.3	11.4	7.93	25.0	Yes	3,672
28 / 10:48 AM	1.07	85.8	91.8	9.1	7.81	27.5	Yes	3,789
29 / 12:52 PM	1.07	83.6	89.5	9.4	7.90	27.8	Yes	3,855
30 / 10:52 AM	1.07	128.3	137.3	9.3	7.69	26.0	Yes	2,509
31 / 09:28 AM	1.05	119.7	125.7	8.8	7.57	25.7	Yes	2,768