

**OHA - Drinking Water Services -Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

**County:**  
**Month/Year:**

<b>Malheur</b>
<b>Apr / 24</b>

System Name: City of Ontario			ID#: 4100587			WTP : TP -	Westtech
Day	NTU @ 12 am	NTU @ 4 am	NTU @ 8 am	NTU @ 12 pm	NTU @ 4 pm	NTU @ 8 pm	NTU Highest Reading of the Day (1)
01	0.12	0.09	0.08	0.07	0.07	0.07	0.29
02	0.07	0.07	Plant Off	0.10	0.10	0.10	0.10
03	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off
04	Plant Off	Plant Off	0.08	0.05	Plant Off	0.03	0.29
05	0.04	0.05	0.05	0.04	0.06	0.07	0.07
06	0.07	0.07	0.07	Plant Off	Plant Off	Plant Off	Plant Off
07	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off
08	Plant Off	Plant Off	Plant Off	0.24	0.24	0.24	0.29
09	0.24	0.24	0.08	0.06	0.04	0.04	0.24
10	0.04	0.04	0.14	Plant Off	Plant Off	Plant Off	0.30
11	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off
12	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off
13	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off
14	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off
15	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off	Plant Off
16	Plant Off	Plant Off	Plant Off	0.08	0.07	0.04	0.29
17	0.05	0.05	0.05	0.03	0.03	0.03	0.14
18	Plant Off	Plant Off	0.06	0.29	0.06	0.04	0.29
19	0.04	0.04	0.04	0.03	0.09	0.05	0.19
20	0.04	0.04	0.03	0.04	0.03	0.06	0.25
21	0.05	0.04	0.04	0.03	0.03	0.20	0.30
22	0.05	0.04	0.04	0.03	0.03	0.03	0.30
23	0.08	0.05	0.04	0.03	0.03	0.03	0.30
24	0.10	0.07	0.05	0.04	0.03	0.03	0.21
25	0.03	0.11	0.06	0.04	0.04	0.03	0.21
26	0.03	0.02	0.07	0.04	0.04	0.03	0.20
27	0.03	0.03	0.06	0.05	0.04	0.04	0.04
28	0.04	0.03	0.03	0.07	0.05	0.04	0.20
29	0.04	0.03	0.03	0.12	0.06	0.04	0.19
30	0.04	0.04	0.04	0.03	0.05	0.04	0.16

System Name:	City of Ontario Water System			ID#: 4100587	Month/Year:	Apr / 24	Disinfection Giardia Log Inactiv:	0.5
Date / Time	Minimum Cl2 Residual at 1st Tap (C) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? Yes / No	Peak Hourly Demand Flow [GPM]
01 / 10:33 AM	1.27	85.4	108.5	13.0	7.55	19.7	Yes	3,800
02 / 11:26 AM	1.23	85.4	105.0	13.2	7.65	20.0	Yes	3,800
03 / 10:39 AM	1.34	85.4	114.4	15.9	7.76	17.7	Yes	3,800
04 / 12:09 PM	1.27	85.4	108.5	14.7	7.74	18.8	Yes	3,800
05 / 01:10 PM	1.31	85.4	111.9	14.3	8.30	23.9	Yes	3,800
06 / 02:42 PM	0.96	85.4	82.0	12.8	7.75	20.7	Yes	3,800
07 / 12:12 PM	1.03	103.7	106.8	12.4	7.76	21.6	Yes	3,250
08 / 08:46 AM	1.19	103.7	123.4	13.0	7.71	20.7	Yes	3,250
09 / 10:19 AM	1.17	85.4	99.9	13.2	7.65	19.9	Yes	3,800
10 / 11:59 AM	1.13	85.4	96.5	14.2	7.72	19.0	Yes	3,800
11 / 10:33 AM	1.10	85.4	93.9	13.9	7.66	18.9	Yes	3,800
12 / 09:44 AM	1.21	45.6	55.2	14.5	7.63	18.2	Yes	5,000
13 / 11:39 AM	1.57	45.6	71.6	14.1	7.54	18.8	Yes	5,000
14 / 11:39 AM	1.14	45.6	52.0	15.0	7.65	17.6	Yes	5,000
15 / 09:54 AM	0.94	85.4	80.3	15.7	7.85	17.7	Yes	3,800
16 / 09:53 AM	0.97	95.4	92.5	15.1	7.95	19.2	Yes	3,500
17 / 09:59 AM	1.23	95.4	117.3	14.6	7.67	18.4	Yes	3,500
18 / 09:47 AM	1.11	95.4	105.9	14.2	7.77	19.3	Yes	3,500
19 / 08:25 AM	1.17	95.4	111.6	14.7	7.71	18.4	Yes	3,500
20 / 12:06 PM	1.16	68.8	79.8	15.3	7.94	19.3	Yes	4,300
21 / 11:53 AM	0.84	68.8	57.8	15.1	7.87	18.3	Yes	4,300
22 / 09:30 AM	0.97	112.0	108.6	15.1	8.01	19.6	Yes	3,000
23 / 10:38 AM	1.24	95.4	118.3	15.1	7.69	18.0	Yes	3,500
24 / 10:34 AM	1.05	95.4	100.2	15.3	7.82	18.2	Yes	3,500
25 / 10:15 AM	1.05	95.4	100.2	16.0	7.81	17.3	Yes	3,500
26 / 10:20 AM	1.17	95.4	111.6	16.3	7.88	17.6	Yes	3,500
27 / 10:01 AM	1.20	95.4	114.5	16.3	7.97	18.3	Yes	3,500
28 / 11:10 AM	1.07	95.4	102.1	16.1	8.05	18.8	Yes	3,500
29 / 09:48 AM	1.27	59.5	75.6	15.2	7.97	19.8	Yes	4,580
30 / 10:12 AM	1.19	50.5	60.1	14.4	7.80	19.5	Yes	4,850
/								