


OHA- Drinking Water Program- Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A Month/Year: January 2021

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	OFF	OFF	OFF	0.03	0.03	OFF	0.03
2	OFF	OFF	OFF	0.03	0.03	0.03	0.04
3	0.03	OFF	OFF	0.03	0.03	0.03	0.03
4	0.03	OFF	OFF	OFF	0.04	0.04	0.04
5	0.04	OFF	OFF	OFF	OFF	0.04	0.04
6	0.04	OFF	OFF	OFF	0.03	0.04	0.04
7	0.04	OFF	OFF	OFF	0.04	0.03	0.04
8	0.03	OFF	OFF	OFF	0.03	OFF	0.03
9	OFF	OFF	OFF	0.03	0.03	0.03	0.04
10	0.03	OFF	OFF	0.03	0.03	0.04	0.04
11	0.03	OFF	OFF	OFF	0.03	0.03	0.03
12	0.03	OFF	OFF	OFF	OFF	0.03	0.04
13	0.04	0.04	OFF	OFF	0.05	0.06	0.06
14	0.05	OFF	OFF	OFF	0.04	0.05	0.05
15	0.05	OFF	OFF	0.05	0.04	0.04	0.05
16	0.04	OFF	OFF	OFF	0.03	0.03	0.04
17	0.04	OFF	OFF	OFF	0.03	0.03	0.04
18	0.03	OFF	OFF	OFF	0.03	0.03	0.03
19	0.03	OFF	OFF	OFF	0.03	0.04	0.04
20	0.03	OFF	OFF	OFF	0.03	0.03	0.03
21	0.03	OFF	OFF	OFF	0.03	0.03	0.03
22	0.03	OFF	OFF	OFF	0.03	0.03	0.03
23	OFF	OFF	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	0.03	0.03	0.03
25	0.03	OFF	OFF	OFF	0.03	0.03	0.04
26	OFF	0.03	OFF	OFF	OFF	0.04	0.04
27	0.03	OFF	OFF	OFF	0.03	0.03	0.03
28	0.03	OFF	OFF	OFF	0.03	0.03	0.03
29	0.03	OFF	OFF	0.03	0.03	0.03	0.04
30	0.04	OFF	OFF	OFF	0.03	0.03	0.04
31	0.04	OFF	OFF	OFF	0.03	0.03	0.04

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All CL <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE <sup>2</sup> triggers?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No <sup>2</sup>		
<b>Notes:</b>	Printed Name: John Collins		
	Signature: 		2/1/2021
	Phone: 503-657-5030		CERT #: 2053

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

**OHA-Drinking Water Program-Surface Water Quality Data Form**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Jan-21	Required Log Inactivation:	1.0
Date/Time	Minimum CL <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1415	1.06	299.10	317.04	8.0	7.5	30	Y	6,950
2)	1400	1.01	268.69	271.38	8.5	7.8	36	Y	7,298
3)	1330	1.24	247.83	307.31	9.0	7.6	37	Y	8,688
4)	1530	1.07	239.44	256.20	9.0	8.1	43	Y	8,271
5)	1245	1.12	304.65	341.20	9.0	7.7	36	Y	6,950
6)	1518	1.16	301.14	349.32	9.0	7.5	30	Y	7,089
7)	0912	1.09	309.93	337.82	8.5	7.9	36	Y	7,089
8)	0850	1.13	306.44	346.27	9.0	7.7	36	Y	7,020
9)	1215	1.00	280.89	280.89	8.0	7.6	36	Y	7,367
10)	1230	1.01	230.11	232.41	8.0	7.7	36	Y	9,452
11)	1900	1.22	239.50	292.19	8.0	7.8	37	Y	8,410
12)	1725	1.07	236.78	253.35	9.0	7.7	36	Y	8,688
13)	1439	1.04	253.08	263.21	9.5	7.1	30	Y	8,618
14)	1650	0.94	258.92	243.38	9.0	7.2	29	Y	6,603
15)	0900	1.10	238.28	262.11	8.5	8.1	43	Y	6,811
16)	1100	1.04	293.93	305.69	8.5	8.4	43	Y	7,437
17)	1145	1.00	286.75	286.75	8.5	7.8	36	Y	7,784
18)	1630	1.12	243.59	272.83	9.0	7.7	36	Y	8,549
19)	1808	1.01	295.03	297.98	8.0	7.5	30	Y	7,367
20)	1615	1.01	245.90	248.36	8.0	7.5	30	Y	8,271
21)	1000	1.19	289.21	344.16	8.0	7.7	36	Y	7,228
22)	1353	1.12	224.05	250.93	7.5	8.0	72	Y	9,522
23)	1500	1.16	224.90	260.88	6.5	7.7	36	Y	9,452
24)	1415	1.02	238.99	243.77	9.0	7.8	36	Y	6,672
25)	1900	1.16	235.99	273.75	7.0	7.5	30	Y	6,533
26)	1420	1.10	254.07	279.48	7.0	7.5	30	Y	8,062
27)	1421	1.11	246.55	273.67	7.0	7.7	36	Y	6,533
28)	1415	1.20	266.34	319.61	7.0	7.6	37	Y	7,993
29)	1245	1.12	248.77	278.62	7.0	7.7	36	Y	7,993
30)	1130	1.11	285.57	316.98	7.0	7.7	36	Y	7,367
31)	1145	1.16	291.51	338.16	7.0	7.8	36	Y	7,089