

OHA- Drinking Water Program- Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A Month/Year: March 2021

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	0.03	OFF	OFF	0.03	OFF	OFF	0.03
2	0.03	OFF	OFF	OFF	0.03	0.03	0.03
3	0.03	OFF	OFF	OFF	0.03	0.03	0.03
4	0.03	OFF	OFF	0.03	OFF	0.03	0.03
5	0.03	OFF	OFF	OFF	0.03	0.03	0.03
6	OFF	OFF	OFF	0.03	0.03	0.03	0.03
7	OFF	OFF	OFF	0.03	0.03	0.03	0.03
8	OFF	OFF	OFF	0.03	0.03	OFF	0.03
9	0.03	OFF	OFF	OFF	0.03	0.03	0.04
10	0.03	OFF	OFF	OFF	0.03	0.03	0.03
11	0.03	OFF	OFF	OFF	0.03	0.03	0.03
12	0.03	OFF	OFF	0.03	0.03	0.03	0.03
13	0.03	OFF	OFF	OFF	0.03	0.03	0.03
14	0.03	OFF	OFF	OFF	0.03	0.03	0.03
15	0.03	OFF	OFF	OFF	0.03	0.03	0.03
16	0.03	OFF	OFF	OFF	0.03	0.03	0.03
17	OFF	OFF	OFF	OFF	0.03	0.03	0.03
18	0.03	OFF	OFF	0.03	0.03	0.03	0.03
19	0.03	OFF	OFF	0.03	0.03	0.03	0.03
20	OFF	OFF	OFF	0.03	0.03	0.03	0.03
21	0.03	OFF	OFF	0.03	0.03	0.03	0.03
22	0.03	OFF	OFF	OFF	0.03	0.03	0.03
23	0.03	OFF	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	0.03	0.03	0.03
25	OFF	OFF	OFF	OFF	0.03	0.03	0.03
26	0.03	OFF	OFF	OFF	0.03	0.03	0.03
27	OFF	OFF	OFF	OFF	0.03	0.03	0.03
28	0.03	OFF	OFF	0.03	0.03	0.03	0.03
29	0.03	OFF	OFF	OFF	0.03	0.03	0.03
30	0.03	OFF	OFF	OFF	0.03	0.03	0.03
31	0.03	OFF	OFF	OFF	0.03	0.05	0.06

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All the 4-hour turbidity readings $\leq$ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All $Cl_2$ residual at entry point $\geq$ 0.2 mg/l?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE <sup>2</sup> triggers?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
<b>Notes:</b>	Printed Name: John Collins		
	Signature: <i>[Handwritten Signature]</i>		4/1/2021
	Phone: 503-657-5030		CERT #: 2053

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

**OHA-Drinking Water Program-Surface Water Quality Data Form**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Mar-21	Required Log Inactivation:	1.0
Date/Time	Minimum CL <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	0945	1.08	242.57	261.97	7.5	7.5	30	Y	6,603
2)	1440	1.00	237.37	237.37	8.0	7.6	36	Y	6,742
3)	1147	1.23	228.86	281.50	9.0	8.1	45	Y	6,603
4)	1007	1.10	295.90	325.50	8.0	7.5	30	Y	7,159
5)	1105	1.04	315.37	327.98	8.0	8.3	43	Y	7,089
6)	1330	1.06	240.39	254.82	8.5	8.0	36	Y	8,618
7)	1330	1.00	246.09	246.09	7.5	8.0	36	Y	8,271
8)	1115	1.01	253.67	256.21	8.0	7.6	36	Y	6,325
9)	1530	0.91	250.68	228.12	8.0	7.8	35	Y	7,715
10)	1625	1.09	279.34	304.49	8.0	7.9	36	Y	7,923
11)	1525	0.95	274.99	261.24	9.5	7.7	35	Y	7,923
12)	1045	0.99	271.96	269.24	9.0	7.6	35	Y	7,576
13)	1528	1.02	276.34	281.87	9.00	7.70	36	Y	7,923
14)	1200	1.10	251.97	277.16	8.00	7.80	36	Y	8,201
15)	1745	1.03	289.91	298.60	8.00	7.90	36	Y	7,645
16)	1105	1.13	230.28	260.21	9.00	7.70	36	Y	8,479
17)	1326	1.14	246.90	281.47	9.5	8.1	43	Y	7,923
18)	1230	1.21	239.49	289.79	8.0	7.6	37	Y	8,410
19)	1418	1.09	231.99	252.87	7.5	8.5	43	Y	8,271
20)	1345	0.99	255.86	253.30	8.5	7.5	29	Y	7,993
21)	1345	1.07	274.74	293.97	8.0	7.6	36	Y	7,367
22)	1030	1.11	272.39	302.36	9.0	7.9	36	Y	7,645
23)	1327	1.15	290.12	333.63	10.0	8.1	33	Y	7,506
24)	1529	1.17	235.41	275.43	8.0	7.6	36	Y	7,993
25)	1150	1.14	259.27	295.57	9.0	7.8	36	Y	8,132
26)	1250	1.15	264.40	304.06	8.5	8.0	36	Y	7,715
27)	1130	1.04	223.93	232.89	10.5	7.7	27	Y	8,827
28)	1515	1.05	276.40	290.22	9.0	7.7	36	Y	7,576
29)	1100	1.03	260.37	268.18	8.5	7.6	36	Y	7,854
30)	1500	1.10	248.66	273.53	10.5	9.0	39	Y	7,993
31)	1020	1.00	275.25	275.25	11.0	8.7	39	Y	7,784