


OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A

Month/Year: April 2021

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.04	OFF	OFF	0.03	OFF	OFF	0.04
2	0.03	OFF	OFF	0.03	0.03	0.03	0.03
3	0.03	OFF	OFF	0.03	0.03	0.03	0.03
4	0.03	OFF	OFF	OFF	0.03	0.03	0.03
5	0.03	OFF	OFF	0.03	0.03	0.03	0.04
6	0.04	OFF	OFF	OFF	0.03	0.04	0.04
7	0.03	OFF	OFF	OFF	0.03	0.03	0.03
8	0.03	OFF	OFF	OFF	0.03	0.03	0.03
9	0.03	OFF	OFF	OFF	0.03	0.03	0.03
10	0.03	OFF	OFF	OFF	0.03	0.03	0.03
11	0.03	OFF	OFF	0.03	0.03	0.03	0.03
12	0.03	OFF	OFF	0.03	0.03	0.04	0.04
13	0.04	0.03	0.03	0.03	0.03	0.04	0.04
14	0.03	0.03	0.03	0.03	0.03	0.04	0.04
15	0.03	OFF	OFF	0.03	0.03	0.03	0.03
16	0.03	OFF	OFF	0.03	0.03	0.03	0.03
17	0.03	OFF	OFF	0.03	0.03	0.03	0.03
18	0.03	OFF	OFF	0.03	0.03	0.03	0.03
19	0.03	OFF	0.03	0.03	0.04	0.03	0.04
20	0.03	0.04	OFF	0.04	0.03	0.03	0.05
21	0.03	0.03	0.03	0.03	0.04	0.04	0.07
22	0.04	0.04	0.04	0.05	OFF	0.04	0.06
23	0.03	OFF	OFF	0.03	0.03	0.03	0.04
24	0.03	OFF	0.03	0.03	0.03	0.03	0.03
25	0.03	OFF	OFF	OFF	0.03	0.03	0.03
26	0.03	OFF	0.03	0.03	0.03	0.03	0.04
27	OFF	OFF	0.04	0.03	0.04	0.05	0.05
28	OFF	OFF	0.04	0.03	0.04	0.04	0.04
29	OFF	OFF	0.03	0.03	0.03	0.03	0.04
30	0.03	OFF	0.03	0.03	0.04	0.04	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All CL ₂ residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No ²		
Notes:	Printed Name: John Collins		
	Signature: 		5/3/2021
	Phone: 503-657-5030		CERT #: 2053

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP.:WTP-A						Month/Year:	Apr-21	Required Log Inactivation:	1.0
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1104	1.12	267.54	299.65	10.0	8.4	33	Y	7,784
2)	1345	0.98	245.84	240.92	9.0	8.0	35	Y	8,132
3)	1345	1.00	239.99	239.99	10.5	8.3	33	Y	8,966
4)	1200	1.00	255.08	255.08	10.5	7.6	27	Y	8,062
5)	1030	1.06	258.02	273.51	10.0	7.5	22	Y	7,715
6)	1440	1.11	229.36	254.59	10.0	7.5	22	Y	8,966
7)	1430	1.05	266.49	279.81	9.5	7.5	30	Y	7,784
8)	1138	1.11	296.95	329.61	10.0	8.1	33	Y	7,089
9)	1048	1.10	269.75	296.72	9.0	7.7	36	Y	8,062
10)	1345	1.00	289.66	289.66	10.0	7.7	27	Y	7,228
11)	1300	1.10	265.08	291.59	10.5	7.6	27	Y	7,854
12)	1320	1.03	288.93	297.60	10.5	7.8	27	Y	7,298
13)	1415	1.13	226.86	256.35	11.0	7.8	27	Y	6,742
14)	1623	1.21	221.09	267.52	12.0	7.7	28	Y	9,105
15)	1314	1.17	163.90	191.76	13.0	8.1	65	Y	12,441
16)	1300	1.06	171.89	182.20	11.0	7.8	54	Y	11,120
17)	1345	1.14	179.51	204.65	12.5	7.5	45	Y	10,912
18)	1115	1.03	234.12	241.14	10.0	7.5	22	Y	9,244
19)	0800	1.00	198.35	198.35	13.5	7.8	54	Y	10,078
20)	1000	1.00	236.43	236.43	11.0	7.5	22	Y	8,271
21)	1345	1.05	246.97	259.31	11.5	7.5	22	Y	8,201
22)	1242	1.13	253.84	286.84	11.5	7.5	22	Y	8,757
23)	1325	1.01	264.09	266.73	11.0	7.6	27	Y	8,201
24)	0930	1.09	235.89	257.12	10.5	7.5	22	Y	9,174
25)	1100	1.04	243.98	253.74	12.5	7.8	27	Y	8,062
26)	1815	1.13	181.05	204.58	10.5	7.5	45	Y	10,634
27)	1015	1.08	240.92	260.19	10.0	7.8	27	Y	8,062
28)	1134	1.18	244.22	288.18	13.0	7.7	27	Y	8,479
29)	1433	1.16	235.18	272.81	12.0	7.8	27	Y	8,757
30)	1645	1.21	217.90	263.66	13.5	7.9	28	Y	9,174