


OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A

Month/Year: June 2021

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	0.03	0.03	0.03	0.03	0.03	0.04
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	OFF	0.03	0.03	0.03	0.03	0.03
7	0.03	OFF	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	OFF	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	OFF	OFF	0.03	0.03	0.03	0.03	0.03
12	OFF	OFF	0.03	0.03	0.03	0.03	0.03
13	0.03	OFF	OFF	0.03	0.03	0.03	0.03
14	OFF	OFF	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	OFF	0.03	0.03	0.03	0.03
16	OFF	0.03	OFF	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.04	0.04
29	OFF	OFF	0.05	0.04	0.04	0.04	0.05
30	0.03	0.03	0.03	0.04	0.03	0.03	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL ₂ residual at entry point ≥ 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	Printed Name: John Collins		
	Signature: 	7/1/2021	
	Phone: 503-657-5030	CERT #:	2053

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: Jun-21	Required Log Inactivation: 1.0	
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1040	1.12	156.66	175.45	20.5	7.9	27	Y	11,746
2)	1026	1.03	180.77	186.19	21.0	7.7	27	Y	11,051
3)	1318	1.12	179.73	201.30	17.0	7.8	36	Y	10,356
4)	0742	1.15	162.44	186.81	21.0	7.6	27	Y	13,066
5)	1350	1.16	193.63	224.61	18.0	7.5	30	Y	10,286
6)	1040	1.02	189.56	193.35	16.0	7.5	30	Y	10,078
7)	1345	1.19	159.15	189.38	17.0	7.5	30	Y	12,441
8)	1523	1.07	232.88	249.18	19.0	7.6	18	Y	9,244
9)	1718	1.08	163.86	176.97	17.0	7.5	30	Y	11,468
10)	1054	1.03	206.46	212.65	16.5	7.5	30	Y	9,661
11)	1300	1.06	179.73	190.51	15.5	7.4	30	Y	10,773
12)	1145	1.05	164.49	172.71	17.0	7.6	36	Y	11,607
13)	1100	0.93	216.73	201.56	17.0	7.5	15	Y	9,174
14)	0900	1.01	216.38	218.54	17.0	7.7	18	Y	9,452
15)	1519	1.01	170.80	172.50	16.0	7.4	30	Y	11,815
16)	1025	0.94	178.36	167.66	19.0	7.9	35	Y	10,703
17)	1350	1.00	154.03	154.03	18.0	7.7	36	Y	12,232
18)	0840	0.94	134.24	126.19	17.5	7.6	35	Y	14,456
19)	1045	1.06	153.07	162.25	17.0	7.5	30	Y	12,858
20)	1130	1.04	137.38	142.88	19.5	7.5	30	Y	14,248
21)	0945	1.11	126.71	140.65	20.0	7.5	22	Y	15,290
22)	1347	0.98	136.19	133.46	20.5	7.5	22	Y	15,082
23)	1648	1.00	129.45	129.45	20.0	7.5	22	Y	15,499
24)	1326	1.11	129.90	144.19	23.5	7.8	27	Y	15,360
25)	1310	1.05	133.79	140.48	21.5	7.4	22	Y	15,221
26)	1045	1.04	130.46	135.68	22.5	7.5	22	Y	15,151
27)	1000	1.13	140.09	158.30	26.5	7.7	18	Y	15,221
28)	1145	1.06	131.90	139.81	24.0	7.5	22	Y	15,499
29)	1125	1.08	113.86	122.97	24.0	7.6	27	Y	15,568
30)	1050	1.04	121.84	126.71	25.5	7.5	15	Y	15,429