


OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: July 2021
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	0.03	0.03	0.03	0.03	0.03	0.04
2	0.03	0.03	0.03	0.03	0.04	0.03	0.04
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.04	0.04	0.04
6	0.04	0.04	0.04	0.04	0.04	0.04	0.04
7	0.04	0.03	0.03	0.03	0.03	0.04	0.04
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.04
10	0.03	0.03	0.03	0.03	0.03	0.04	0.04
11	0.04	0.03	0.03	0.03	0.03	0.04	0.04
12	0.04	0.03	0.03	0.03	0.03	0.03	0.04
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.04
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.04	0.03	0.03	0.03	0.03	0.03	0.04
18	0.04	0.03	0.03	0.03	0.03	0.03	0.04
19	0.04	0.03	0.03	0.03	0.03	0.03	0.04
20	0.04	0.03	0.03	0.03	0.03	0.03	0.04
21	0.04	0.03	0.03	0.03	0.03	0.03	0.04
22	0.04	0.03	0.03	0.03	0.03	0.03	0.04
23	0.04	0.03	0.03	0.03	0.03	0.03	0.04
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.04
28	0.03	0.03	0.03	0.03	0.03	0.03	0.04
29	0.03	0.04	0.04	0.03	0.03	0.03	0.04
30	0.03	0.04	0.03	0.04	0.03	0.03	0.04
31	0.03	0.04	0.03	0.03	0.03	0.03	0.04

Conventional or Direct Filtration			Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL ₂ residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No			<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:		Printed Name: John Collins		
		Signature: 	8/3/2021	
		Phone: 503-657-5030	CERT #: 2053	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A						Month/Year:	Jul-21	Required Log Inactivation:	1.0
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1025	1.15	134.79	155.00	22.0	7.5	22	Y	15,012
2)	1300	1.00	138.09	138.09	21.5	7.5	22	Y	14,665
3)	0930	0.96	131.44	126.18	24.5	7.8	26	Y	14,595
4)	1430	1.04	137.68	143.18	23.0	7.6	27	Y	15,221
5)	0915	1.06	135.05	143.16	23.0	7.5	22	Y	15,012
6)	1440	1.04	131.82	137.09	23.0	7.5	22	Y	15,082
7)	1220	1.09	153.10	166.88	22.5	7.5	22	Y	12,788
8)	0900	1.11	154.88	171.92	22.5	7.5	22	Y	13,205
9)	1050	1.07	154.47	165.28	22.0	7.5	22	Y	12,510
10)	1300	1.03	136.96	141.07	23.0	7.5	22	Y	15,082
11)	1145	1.07	144.17	154.26	22.5	7.6	27	Y	13,761
12)	0930	1.11	159.64	177.21	23.0	7.6	27	Y	12,719
13)	1605	1.06	165.14	175.05	23.0	7.5	22	Y	12,371
14)	0803	1.00	148.67	148.67	22.0	7.5	22	Y	12,997
15)	0920	1.20	146.81	176.17	23.5	7.5	23	Y	13,136
16)	0900	1.05	143.59	150.77	22.0	7.5	22	Y	13,970
17)	0830	1.06	146.11	154.88	23.0	7.7	27	Y	13,900
18)	0900	0.98	158.31	155.15	23.0	7.6	26	Y	12,719
19)	1145	1.02	140.74	143.55	23.0	7.6	27	Y	14,387
20)	1210	1.10	131.04	144.14	23.5	7.5	22	Y	14,943
21)	1055	1.13	151.31	170.98	22.0	7.5	22	Y	13,275
22)	1025	1.05	135.10	141.85	21.0	7.6	27	Y	15,012
23)	1130	1.25	148.90	186.13	22.0	7.5	23	Y	13,831
24)	0915	1.24	138.85	172.17	23.0	7.5	23	Y	15,082
25)	0900	1.18	143.46	169.28	24.0	7.5	22	Y	14,665
26)	0845	1.17	138.73	162.31	23.0	7.5	22	Y	14,804
27)	1250	1.11	130.66	145.04	24.0	7.6	27	Y	15,012
28)	1050	1.17	128.23	150.03	23.0	7.8	27	Y	14,595
29)	1120	1.11	141.21	156.75	24.0	7.5	22	Y	13,970
30)	0920	1.14	132.26	150.70	24.0	7.6	27	Y	14,804
31)	1030	1.13	153.15	135.53	23.0	7.7	27	Y	15,151