


OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A

Month/Year: **Sept 2021**

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	OFF	0.03	0.03	0.03	0.03	0.03
12	0.03	OFF	0.03	0.03	0.04	0.03	0.03
13	0.03	OFF	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	OFF	0.03	0.03	0.03	0.03
15	0.03	0.03	OFF	0.03	0.03	0.03	0.03
16	0.03	OFF	0.03	0.03	0.03	0.03	0.03
17	0.03	OFF	0.03	0.03	0.03	0.03	0.03
18	0.03	OFF	0.03	0.03	0.03	0.03	0.03
19	0.03	OFF	0.03	0.03	0.04	0.03	0.04
20	0.03	OFF	0.03	0.03	0.03	OFF	0.03
21	0.03	0.03	OFF	0.03	0.03	0.03	0.03
22	OFF	0.03	OFF	0.03	0.03	0.03	0.04
23	0.04	OFF	0.03	0.03	0.03	0.04	0.04
24	0.04	OFF	0.04	0.03	0.03	0.03	0.04
25	0.03	OFF	0.03	0.03	0.03	0.03	0.03
26	OFF	OFF	0.03	0.03	0.03	0.03	0.03
27	0.03	OFF	OFF	0.03	0.03	0.03	0.03
28	0.03	OFF	OFF	0.03	0.03	OFF	0.03
29	0.04	OFF	OFF	0.03	0.03	0.03	0.04
30	0.03	OFF	OFF	0.03	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All CL ₂ residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
Notes:		Printed Name: John Collins	
		Signature: 	10/4/2021
		Phone: 503-657-5030	CERT #: 2053

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year: Sep-21	Required Log Inactivation: 1.0		
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1040	1.14	155.57	177.35	18.0	7.5	30	Y	12,649
2)	1045	1.10	169.75	186.72	18.5	7.4	30	Y	11,885
3)	0928	1.09	132.95	144.91	19.0	7.8	36	Y	14,804
4)	1130	1.04	156.97	163.25	18.5	7.5	30	Y	12,719
5)	1130	1.14	161.43	184.03	19.5	7.5	30	Y	12,649
6)	1100	1.00	160.87	160.87	20.5	7.5	22	Y	12,719
7)	1320	1.00	158.53	158.53	20.0	7.5	22	Y	12,093
8)	0800	1.17	167.35	195.80	20.0	7.5	22	Y	11,815
9)	0908	1.07	130.80	139.96	20.0	7.5	22	Y	14,526
10)	1145	0.98	161.43	158.20	20.0	7.5	22	Y	11,815
11)	1330	1.08	127.81	138.03	18.0	7.7	36	Y	15,012
12)	1215	1.07	135.53	145.01	19.0	7.8	36	Y	14,317
13)	0930	1.03	164.75	169.69	18.5	7.5	30	Y	12,302
14)	1125	1.06	160.37	169.99	18.0	7.5	30	Y	12,580
15)	1300	1.12	178.86	200.32	20.0	7.7	27	Y	11,051
16)	0829	1.07	169.35	181.20	17.0	7.6	36	Y	10,981
17)	1115	1.09	145.14	158.21	17.5	7.6	36	Y	13,692
18)	1215	1.01	205.60	207.66	18.0	7.7	36	Y	10,078
19)	1145	1.00	232.96	232.96	16.5	7.6	18	Y	8,827
20)	1245	1.05	225.69	236.98	16.0	7.5	15	Y	8,966
21)	1438	1.09	214.89	234.23	16.0	7.5	30	Y	9,522
22)	1154	1.09	223.65	243.78	17.5	7.7	18	Y	8,827
23)	1143	1.00	181.15	181.15	18.0	7.8	36	Y	11,329
24)	1800	1.09	181.69	198.04	18.0	8.0	36	Y	10,634
25)	1130	1.02	202.75	206.80	18.5	7.9	36	Y	10,564
26)	1030	1.00	229.91	229.91	18.0	7.8	18	Y	9,313
27)	1300	1.06	211.60	224.29	18.0	7.8	18	Y	9,452
28)	1435	1.02	258.97	264.15	15.5	7.4	15	Y	8,132
29)	1433	1.03	253.00	260.59	15.0	7.4	15	Y	8,549
30)	0955	1.00	254.55	254.55	16.0	7.6	18	Y	8,827