


OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: Nov 2021
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	OFF	OFF	OFF	0.03	0.03	0.03
2	0.03	OFF	OFF	OFF	0.03	0.04	0.04
3	0.03	OFF	OFF	OFF	0.03	0.03	0.03
4	0.03	0.03	OFF	0.03	OFF	0.03	0.03
5	0.03	OFF	OFF	OFF	0.03	0.03	0.03
6	0.03	OFF	OFF	OFF	0.03	0.03	0.03
7	0.03	OFF	OFF	OFF	0.03	0.03	0.03
8	OFF	OFF	OFF	0.03	0.03	0.03	0.03
9	0.03	OFF	OFF	OFF	0.03	0.04	0.04
10	0.03	OFF	OFF	0.03	OFF	OFF	0.03
11	0.03	OFF	OFF	OFF	0.03	0.05	0.05
12	OFF	0.05	OFF	0.05	0.04	0.04	0.06
13	0.06	OFF	OFF	0.04	0.03	0.03	0.06
14	0.03	OFF	OFF	0.03	0.03	0.03	0.03
15	0.03	OFF	OFF	OFF	0.03	0.03	0.03
16	0.03	OFF	0.03	0.03	OFF	OFF	0.03
17	0.03	OFF	OFF	OFF	OFF	OFF	0.03
18	0.03	0.03	OFF	OFF	0.03	0.03	0.03
19	0.03	OFF	OFF	0.03	0.03	0.03	0.03
20	0.03	OFF	OFF	0.03	0.03	0.03	0.03
21	0.03	OFF	OFF	0.03	0.03	0.03	0.03
22	0.03	OFF	OFF	OFF	0.03	0.03	0.03
23	0.03	OFF	OFF	OFF	OFF	0.03	0.03
24	0.03	OFF	OFF	OFF	0.03	0.04	0.04
25	0.03	0.03	OFF	OFF	0.03	OFF	0.03
26	0.03	0.03	OFF	0.03	0.03	0.03	0.03
27	0.03	OFF	OFF	0.03	OFF	0.03	0.03
28	0.03	OFF	OFF	0.03	0.03	0.03	0.03
29	0.03	OFF	OFF	OFF	0.03	0.02	0.03
30	0.03	OFF	OFF	OFF	0.03	0.03	0.03
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No				CT's met everyday? (see back) Yes / No		All CL ₂ residual at entry point ≥ 0.2 mg/l? Yes/No	
All the 4-hour turbidity readings ≤ 1 NTU? Yes / No							
All turbidity readings < IFE ² triggers? Yes / No²							
Notes:				Printed Name: John Collins			
				Signature: 		12/1/2021	
				Phone: 503-657-5030		CERT #: 2053	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year: Nov-21	Required Log Inactivation: 1.0		
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1125	0.97	237.37	230.25	11.5	7.6	26	Y	6,533
2)	1200	0.95	272.74	259.10	11.0	7.5	22	Y	6,950
3)	1200	0.96	246.38	236.53	11.0	7.6	26	Y	8,271
4)	1317	1.04	240.66	250.28	11.0	7.6	27	Y	6,811
5)	1045	1.00	241.71	241.71	11.0	7.9	27	Y	6,811
6)	1330	1.01	295.47	298.42	10.0	7.6	27	Y	7,367
7)	1500	1.08	308.87	333.58	10.0	7.7	27	Y	7,159
8)	1545	1.01	295.68	298.63	10.5	7.6	27	Y	7,159
9)	1320	1.03	265.18	273.14	10.0	7.7	27	Y	7,854
10)	1325	1.02	280.01	285.61	10.0	7.6	27	Y	7,437
11)	1235	1.01	286.48	289.34	10.0	7.6	27	Y	7,228
12)	1300	1.00	280.30	280.30	12.5	7.5	22	Y	5,630
13)	1345	0.98	240.66	235.85	12.0	7.6	26	Y	6,811
14)	1320	1.06	240.31	254.73	11.5	7.6	27	Y	6,533
15)	1700	1.05	262.73	250.22	12.0	7.9	27	Y	6,464
16)	1300	1.19	247.42	294.43	11.0	7.6	27	Y	6,186
17)	1202	1.06	261.30	276.98	10.5	7.5	22	Y	5,908
21)	1221	1.09	212.12	231.21	10.0	8.2	33	Y	7,089
19)	0915	1.21	235.24	284.64	10.0	7.8	28	Y	6,742
20)	1310	1.21	253.61	306.86	9.0	7.8	37	Y	6,603
21)	1315	1.19	231.03	274.93	8.5	8.0	36	Y	6,950
22)	1329	1.19	285.91	340.24	9.0	7.5	30	Y	7,298
23)	1425	1.14	248.37	283.14	9.0	7.8	36	Y	6,464
24)	1103	1.17	256.94	300.62	8.5	7.7	36	Y	7,020
25)	1053	1.22	212.95	259.80	9.0	7.8	37	Y	8,688
26)	0942	1.22	285.14	347.87	9.0	7.7	37	Y	7,020
27)	1200	1.11	271.02	300.83	9.0	7.8	36	Y	7,159
28)	1139	1.04	254.01	264.17	10.0	7.6	27	Y	7,506
29)	1430	1.22	233.82	285.26	10.5	7.5	27	Y	8,896
30)	1118	1.19	169.43	201.62	11.0	7.5	54	Y	12,371