


OHA- Drinking Water Program- Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A

Month/Year: December 2021

| Day | 12 AM (NTU) | 4 AM (NTU) | 8 AM (NTU) | NOON (NTU) | 4 PM (NTU) | 8 PM (NTU) | Highest Reading of the Day <sup>1</sup> (NTU) |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1   | OFF         | OFF        | OFF        | 0.03       | 0.03       | OFF        | 0.03  |
| 2   | OFF         | OFF        | OFF        | 0.03       | 0.04       | 0.03       | 0.04  |
| 3   | 0.03        | OFF        | OFF        | OFF        | OFF        | OFF        | 0.03  |
| 4   | 0.03        | OFF        | OFF        | 0.03       | 0.03       | 0.03       | 0.03  |
| 5   | 0.03        | OFF        | 0.03       | 0.03       | 0.03       | 0.03       | 0.03  |
| 6   | 0.03        | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |
| 7   | OFF         | OFF        | OFF        | OFF        | 0.03       | OFF        | 0.03  |
| 8   | OFF         | OFF        | 0.03       | 0.03       | 0.03       | OFF        | 0.03  |
| 9   | OFF         | OFF        | OFF        | 0.03       | 0.03       | 0.03       | 0.03  |
| 10  | 0.03        | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |
| 11  | OFF         | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |
| 12  | 0.03        | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |
| 13  | 0.03        | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |
| 14  | 0.03        | OFF        | OFF        | OFF        | OFF        | 0.03       | 0.03  |
| 15  | 0.03        | OFF        | OFF        | OFF        | OFF        | 0.03       | 0.03  |
| 16  | 0.03        | 0.04       | OFF        | OFF        | OFF        | 0.04       | 0.04  |
| 17  | 0.04        | 0.03       | OFF        | OFF        | 0.03       | 0.03       | 0.04  |
| 18  | 0.03        | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |
| 19  | OFF         | OFF        | OFF        | 0.03       | 0.03       | 0.03       | 0.03  |
| 20  | 0.03        | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |
| 21  | OFF         | OFF        | OFF        | OFF        | OFF        | 0.04       | 0.04  |
| 22  | 0.03        | OFF        | OFF        | 0.05       | 0.04       | 0.04       | 0.05  |
| 23  | 0.04        | OFF        | OFF        | 0.03       | 0.03       | 0.03       | 0.04  |
| 24  | 0.04        | OFF        | OFF        | 0.03       | 0.03       | 0.03       | 0.04  |
| 25  | OFF         | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |
| 26  | OFF         | OFF        | OFF        | 0.03       | 0.03       | 0.03       | 0.03  |
| 27  | OFF         | OFF        | OFF        | 0.03       | 0.03       | 0.03       | 0.03  |
| 28  | 0.03        | OFF        | OFF        | OFF        | OFF        | 0.03       | 0.03  |
| 29  | 0.03        | OFF        | OFF        | OFF        | OFF        | 0.03       | 0.04  |
| 30  | 0.03        | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.04  |
| 31  | 0.03        | OFF        | OFF        | OFF        | 0.03       | 0.03       | 0.03  |

| Conventional or Direct Filtration   | Monthly Summary (Answer Yes or No)  |   |
|---|---|---|
| 95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No     | CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No   | All CL <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input type="radio"/> Yes / <input checked="" type="radio"/> No |
| All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No          |   |   |
| All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No |   |   |
| Notes:  | Printed Name: John Collins  |   |
|   | Signature:  | 1/3/2022  |
|   | Phone: 503-657-5030   | CERT #: 2053  |

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

**OHA-Drinking Water Program-Surface Water Quality Data Form**

| SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A |   |                  |           |        |      | Month/Year: | Dec-21               | Required Log Inactivation: | 1.0    |
|--|---|------------------|-----------|--------|------|-------------|----------------------|----------------------------|--------|
| Date/Time  | Minimum CL <sub>2</sub> Residual at 1st User (C) <sup>3</sup> | Contact Time (T) | Actual CT | Temp   | pH   | Required CT | CT Met? <sup>3</sup> | Peak Hourly Demand Flow    |        |
|  | ppm or mg/L   | minutes          | C x T     | (°C)   |      | Use tables  | Yes / No             | [GPM]                      |        |
| 1)   | 1518  | 1.05             | 286.02    | 300.32 | 11.0 | 7.6         | 27                   | Y                          | 7,228  |
| 2)   | 1543  | 1.24             | 261.02    | 323.66 | 11.0 | 7.5         | 23                   | Y                          | 7,437  |
| 3)   | 1340  | 1.20             | 208.22    | 249.86 | 10.0 | 7.6         | 55                   | Y                          | 10,078 |
| 4)   | 1350  | 1.15             | 235.52    | 270.85 | 9.5  | 7.7         | 36                   | Y                          | 6,811  |
| 5)   | 1330  | 1.15             | 242.75    | 279.16 | 9.5  | 7.5         | 30                   | Y                          | 6,394  |
| 6)   | 1405  | 1.18             | 263.18    | 310.55 | 9.5  | 7.7         | 36                   | Y                          | 7,923  |
| 7)   | 1416  | 1.18             | 216.30    | 255.24 | 10.0 | 7.7         | 27                   | Y                          | 6,881  |
| 8)   | 1231  | 1.15             | 248.03    | 285.24 | 10.0 | 7.9         | 27                   | Y                          | 8,827  |
| 9)   | 1445  | 1.19             | 262.02    | 311.80 | 8.5  | 7.7         | 36                   | Y                          | 7,993  |
| 10)  | 1127  | 1.18             | 305.52    | 360.51 | 9.0  | 7.6         | 36                   | Y                          | 7,089  |
| 11)  | 1113  | 1.04             | 272.09    | 282.97 | 9.0  | 7.8         | 36                   | Y                          | 7,993  |
| 12)  | 1440  | 1.09             | 264.63    | 288.44 | 8.5  | 7.8         | 36                   | Y                          | 7,923  |
| 13)  | 1250  | 1.14             | 265.35    | 302.50 | 9.0  | 7.6         | 36                   | Y                          | 7,576  |
| 14)  | 1421  | 1.19             | 294.17    | 350.06 | 7.5  | 7.6         | 36                   | Y                          | 7,089  |
| 15)  | 1729  | 1.27             | 245.89    | 312.28 | 8.0  | 7.6         | 37                   | Y                          | 8,271  |
| 16)  | 0000  | 1.23             | 251.71    | 309.60 | 8.0  | 7.6         | 37                   | Y                          | 7,437  |
| 17)  | 1025  | 1.29             | 286.75    | 369.91 | 7.5  | 7.9         | 37                   | Y                          | 7,089  |
| 18)  | 1145  | 1.19             | 282.80    | 336.54 | 8.0  | 8.1         | 43                   | Y                          | 7,576  |
| 19)  | 1255  | 1.08             | 297.28    | 321.06 | 7.5  | 7.8         | 36                   | Y                          | 7,159  |
| 20)  | 1458  | 1.08             | 292.92    | 316.36 | 8.5  | 8.1         | 43                   | Y                          | 7,159  |
| 21)  | 1427  | 1.13             | 282.00    | 318.66 | 8.0  | 7.5         | 30                   | Y                          | 7,089  |
| 22)  | 1301  | 1.21             | 254.52    | 307.96 | 8.5  | 7.5         | 31                   | Y                          | 7,854  |
| 23)  | 1453  | 1.22             | 268.24    | 327.25 | 8.5  | 7.5         | 31                   | Y                          | 7,506  |
| 24)  | 1500  | 1.10             | 287.33    | 316.06 | 8.0  | 7.7         | 36                   | Y                          | 7,367  |
| 25)  | 1430  | 1.11             | 238.79    | 262.67 | 7.5  | 7.8         | 36                   | Y                          | 8,966  |
| 26)  | 1000  | 1.18             | 303.43    | 358.05 | 7.0  | 7.6         | 36                   | Y                          | 7,089  |
| 27)  | 1537  | 1.15             | 299.88    | 344.86 | 6.5  | 8.2         | 43                   | Y                          | 7,020  |
| 28)  | 1501  | 1.13             | 300.35    | 339.39 | 6.0  | 7.8         | 36                   | Y                          | 7,020  |
| 29)  | 1248  | 1.34             | 221.25    | 296.47 | 6.0  | 7.7         | 37                   | Y                          | 6,881  |
| 30)  | 1500  | 1.20             | 266.97    | 320.36 | 6.0  | 7.8         | 37                   | Y                          | 7,715  |
| 31)  | 1210  | 1.07             | 252.35    | 270.02 | 5.5  | 8.0         | 36                   | Y                          | 7,784  |