


OHA- Drinking Water Program- Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A Month/Year: January 2022

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	0.03	OFF	OFF	OFF	0.03	0.03	0.03
2	OFF	OFF	OFF	OFF	0.03	0.03	0.03
3	0.03	OFF	OFF	OFF	OFF	0.06	0.06
4	0.05	0.04	OFF	0.03	0.03	0.03	0.05
5	0.03	OFF	OFF	OFF	0.03	0.03	0.03
6	0.04	0.04	0.04	0.03	0.04	0.04	0.04
7	0.04	0.04	OFF	OFF	OFF	0.04	0.04
8	0.03	OFF	OFF	0.04	0.04	0.04	0.04
9	0.04	OFF	OFF	OFF	0.03	0.03	0.04
10	0.03	OFF	OFF	0.04	0.03	0.03	0.04
11	0.03	OFF	OFF	OFF	0.03	0.03	0.03
12	0.03	0.03	OFF	OFF	0.03	0.03	0.03
13	0.03	OFF	OFF	OFF	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.04	0.04	0.04
15	0.03	OFF	OFF	OFF	0.03	0.03	0.03
16	0.03	OFF	OFF	OFF	0.03	0.03	0.03
17	0.03	OFF	OFF	OFF	0.03	0.03	0.03
18	0.03	OFF	OFF	OFF	0.03	0.03	0.04
19	0.04	0.03	OFF	OFF	0.03	0.03	0.04
20	0.03	0.03	0.03	0.03	OFF	OFF	0.03
21	0.03	0.03	OFF	OFF	0.03	0.03	0.03
22	0.03	OFF	OFF	OFF	0.03	0.03	0.03
23	0.03	OFF	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	0.03	0.03	0.03
25	0.04	OFF	OFF	OFF	0.03	0.03	0.04
26	0.03	0.03	0.03	OFF	OFF	0.03	0.03
27	0.03	OFF	0.03	0.03	0.03	0.03	0.03
28	0.03	OFF	OFF	OFF	0.03	0.03	0.03
29	0.03	OFF	OFF	OFF	0.03	0.03	0.03
30	0.03	OFF	OFF	OFF	0.03	0.03	0.03
31	0.03	OFF	OFF	0.03	0.03	0.03	0.03

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL <sub>2</sub> residual at entry point ≥ 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
<b>Notes:</b>	Printed Name: Richard Mark Cage		
	Signature: 		2/1/2022
	Phone: 503-657-8030		CERT #: 2610

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

**OHA-Drinking Water Program-Surface Water Quality Data Form**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A						Month/Year:	Jan-22	Required Log Inactivation:	1.0
Date/Time	Minimum CL <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1530	1.09	292.81	319.17	5.0	8.1	43	Y	7,159
2)	0951	1.21	213.61	258.46	5.0	7.5	31	Y	8,757
3)	1921	1.21	260.57	315.28	6.0	7.4	31	Y	7,159
4)	1421	1.20	215.83	259.00	7.0	7.9	37	Y	6,811
5)	1506	1.30	259.23	337.00	6.5	7.8	37	Y	6,116
6)	1830	1.19	246.66	293.53	7.5	7.6	36	Y	6,672
7)	1528	1.18	302.39	356.82	7.5	7.7	36	Y	7,089
8)	1315	1.08	233.48	252.16	8.0	8.1	43	Y	6,811
9)	1155	1.24	302.84	375.52	7.0	8.0	37	Y	7,228
10)	1635	1.14	293.07	334.10	7.0	8.0	36	Y	7,506
11)	1248	1.32	275.37	363.49	7.5	7.7	37	Y	7,437
12)	1305	1.23	271.70	334.19	8.0	8.0	37	Y	7,159
13)	1227	1.38	262.68	362.50	7.5	7.9	37	Y	5,908
14)	1103	1.00	259.67	259.67	8.0	7.8	36	Y	6,047
15)	1100	1.04	280.98	292.22	7.0	8.1	43	Y	5,838
16)	1140	1.14	259.23	295.52	7.0	7.7	36	Y	7,854
17)	1020	1.26	260.68	328.46	7.5	7.9	37	Y	7,228
18)	1207	1.31	235.90	309.03	7.5	7.7	37	Y	6,603
19)	1552	1.28	237.20	303.62	7.5	7.6	37	Y	6,394
20)	1237	1.35	259.11	349.80	8.0	7.8	37	Y	5,769
21)	1315	1.09	270.37	294.71	8.0	7.9	36	Y	7,715
22)	1145	1.10	274.78	302.26	8.0	7.9	36	Y	7,228
23)	1049	1.19	281.14	334.56	7.5	7.6	36	Y	7,228
24)	1440	1.15	264.59	304.28	7.0	7.7	36	Y	7,784
25)	1350	1.22	254.82	310.88	6.5	7.5	31	Y	8,132
26)	1300	1.22	276.40	337.21	7.0	7.5	31	Y	7,576
27)	1456	1.26	269.82	339.97	6.0	7.9	37	Y	7,645
28)	1243	1.21	238.76	288.90	6.0	8.2	45	Y	6,811
29)	1145	1.24	260.03	322.44	5.5	8.0	37	Y	7,506
30)	1143	1.24	353.24	313.98	6.0	8.0	45	Y	7,576
31)	1600	1.18	281.29	331.92	6.0	7.8	36	Y	7,576